

OVDA, Israel

WMO: 401980

Lat: 29.940N

Lon: 34.936E

Elev: 455

StdP: 95.98

Time Zone: 2.00 (ISR)

Period: 94-11

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.9	4.0	-10.9	1.6	15.7	-8.2	2.0	19.3	10.8	12.3	9.4	12.8	2.6	220	0.432

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	38.7	18.7	37.6	18.4	36.2	18.2	21.9	30.9	21.2	30.0	20.6	29.5	4.5	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	14.8	25.0	18.8	14.4	24.7	17.9	13.6	24.4	66.3	30.9	63.5	30.2	61.5	29.6	30.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.4	8.0	7.0	DB	0.3	41.0	1.9	1.1	-1.1	41.8	-2.2	42.4	-3.2	43.0	-4.6	43.8	
			WB	-1.5	23.8	1.9	2.0	-2.8	25.3	-3.9	26.5	-5.0	27.6	-6.4	29.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.8	11.1	12.6	15.9	20.4	24.6	27.1	29.3	28.9	26.5	22.9	17.2	12.4
	DBStd	7.00	2.43	3.00	3.64	3.85	3.13	2.17	1.66	1.60	1.82	2.73	2.91	2.47
	HDD10.0	27	14	6	1	0	0	0	0	0	0	0	0	6
	HDD18.3	747	224	164	96	19	1	0	0	0	0	2	56	186
	CDD10.0	3964	48	79	184	312	452	514	599	587	495	399	216	79
	CDD18.3	1642	0	3	21	81	194	264	341	329	245	143	21	1
	CDH23.3	20453	6	44	291	1012	2374	3409	4709	4400	2737	1267	188	16
CDH26.7	10892	0	11	94	440	1198	1912	2827	2546	1346	475	41	2	
Wind	WSAvg	3.3	3.0	3.2	3.4	3.6	3.5	3.6	3.4	3.4	3.2	2.8	2.9	2.9
Precipitation	PrecAvg	20	4	3	4	2	1	0	0	0	0	3	1	4
	PrecMax	54	18	24	28	12	16	0	0	0	2	14	13	35
	PrecMin	4	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	13	4	6	7	3	4	0	0	0	1	4	3	8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.0	27.9	32.8	37.0	38.6	39.8	40.1	39.9	37.8	36.2	30.2	25.2
		MCWB	11.6	14.0	14.3	16.5	17.5	18.6	18.9	20.8	17.9	16.8	15.5	11.9
	2%	DB	20.9	24.0	29.1	34.0	36.3	37.9	38.7	38.0	35.9	33.2	27.5	22.2
		MCWB	11.0	12.1	14.0	15.7	16.9	17.8	18.7	19.4	18.8	17.0	14.7	11.6
	5%	DB	18.8	21.2	26.8	31.8	34.7	36.1	37.4	36.9	34.1	31.1	25.2	20.0
		MCWB	10.4	11.0	13.1	14.9	16.5	17.4	18.6	19.0	18.8	17.5	14.2	11.3
	10%	DB	17.0	19.1	24.0	29.0	32.9	34.8	36.2	35.8	32.9	29.1	23.4	18.2
		MCWB	9.6	10.1	12.1	14.0	16.1	17.2	18.3	18.9	18.5	17.4	13.7	10.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.4	16.8	16.5	19.1	19.7	20.6	23.0	23.2	22.7	20.7	17.4	15.2
		MCDB	19.0	25.6	25.7	30.7	33.7	31.9	33.4	33.2	31.5	28.1	25.3	19.4
	2%	WB	12.0	13.0	14.9	16.7	18.2	19.6	21.5	22.0	21.6	19.8	16.3	13.0
		MCDB	18.8	21.7	26.7	29.3	32.1	30.8	31.4	30.9	29.5	26.5	23.7	19.3
	5%	WB	11.1	11.7	13.7	15.5	17.4	18.9	20.7	21.3	20.8	19.2	15.5	12.0
		MCDB	17.2	19.3	24.8	28.6	31.1	30.7	30.8	30.0	28.5	26.2	22.4	18.0
	10%	WB	10.2	10.6	12.6	14.6	16.7	18.3	20.0	20.8	20.1	18.6	14.7	11.2
		MCDB	15.8	17.2	22.0	27.0	29.7	30.3	30.4	29.5	28.1	25.7	21.4	16.9
Mean Daily Temperature Range	5% DB	MDBR	11.5	11.9	12.9	13.8	14.4	14.7	14.3	13.8	12.8	12.1	12.1	12.0
		MCDBR	14.7	15.5	16.3	16.9	16.5	16.3	15.3	14.8	14.4	14.7	14.2	14.7
		MCWBR	7.6	7.4	6.9	6.8	5.9	5.0	4.8	4.4	4.7	5.4	6.3	7.9
	5% WB	MCDBR	12.2	13.2	14.5	14.8	14.9	14.7	14.2	13.6	12.9	12.2	12.0	12.0
		MCWBR	6.9	6.7	6.5	6.5	5.6	4.7	4.6	4.2	4.4	4.6	5.5	7.0
Clear-Sky Solar Irradiance	taub	0.342	0.379	0.432	0.459	0.463	0.391	0.395	0.402	0.402	0.408	0.352	0.328	
	taud	2.267	2.137	1.959	1.912	1.934	2.176	2.189	2.176	2.172	2.134	2.286	2.338	
	Ebn at Noon	880	875	849	840	836	893	889	880	869	833	862	879	
	Edh at Noon	112	140	179	195	192	150	147	147	143	139	109	100	
All-Sky Solar Radiation	RadAvg	3.70	4.63	5.98	7.02	7.79	8.46	8.17	7.56	6.58	5.25	4.12	3.48	
	RadStd	0.15	0.18	0.22	0.17	0.26	0.09	0.13	0.11	0.15	0.16	0.13	0.12	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (9 neighbors)	+0.42	N/A	-1.74	N/A	N/A	N/A	N/A	N/A	+135	+146

Nomenclature: See separate page