

RUWAISHED H4 AB, Jordan

WMO: 402500

Lat: 32.539N

Lon: 38.195E

Elev: 2250

StdP: 13.54

Time Zone: 2.00 (JOR)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	31.3	34.6	17.5	14.4	45.9	20.8	16.9	46.9	29.9	51.4	23.4	50.2	1.6	70	0.410

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	27.7	105.5	72.5	102.8	71.6	100.4	70.2	77.9	98.7	75.4	96.3	73.1	94.6	5.4	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
71.8	128.0	91.3	68.9	115.3	88.5	66.2	105.1	85.7	43.2	98.1	40.6	96.2	38.3	94.7	88.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
25.3	21.1	18.2	DB	27.2	107.5	3.4	3.3	24.7	109.8	22.8	111.7	20.8	113.5	18.4	115.9
			WB	25.3	78.6	2.4	4.3	23.5	81.7	22.1	84.3	20.8	86.7	19.0	89.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	67.8	46.8	51.0	58.1	65.9	75.6	81.7	86.0	86.3	80.7	71.6	58.7	50.1	(6)
(7)		DBStd	15.02	5.31	5.46	6.58	7.77	6.06	4.48	4.09	4.19	4.81	6.13	5.87	5.74	(7)
(8)		HDD50	258	125	48	8	2	0	0	0	0	0	7	68	(8)	
(9)		HDD65	1955	564	394	232	81	4	0	0	0	17	202	461	(9)	
(10)		CDD50	6750	27	75	258	479	792	950	1115	1125	922	669	266	72	(10)
(11)		CDD65	2971	0	0	18	108	331	500	650	660	472	220	12	0	(11)
(12)		CDH74	39253	0	3	223	1274	4083	6792	9412	9445	5775	2147	94	5	(12)
(13)		CDH80	22442	0	0	55	480	2016	3949	5935	5977	3173	848	9	0	(13)
(14)	Wind	WSAvg	5.1	5.1	6.4	7.2	6.6	5.6	4.8	4.3	3.5	4.2	4.1	4.4	4.6	(14)
(15)	Precipitation	PrecAvg	3.1	0.6	0.5	0.4	0.4	0.2	0.0	0.0	0.0	0.0	0.3	0.4	0.5	(15)
(16)		PrecMax	7.2	3.1	2.0	1.7	1.8	1.1	0.2	0.0	0.4	2.1	1.7	2.0	(16)	
(17)		PrecMin	0.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
(18)		PrecStd	1.3	0.6	0.6	0.4	0.5	0.3	0.0	0.0	0.0	0.5	0.5	0.5	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.7	73.3	86.6	95.3	100.1	104.3	109.7	109.1	103.6	95.7	80.8	73.7	(19)
(20)		MCWB	54.0	54.6	60.7	63.6	69.2	68.1	73.0	75.5	69.2	66.6	59.5	56.2	(20)	
(21)		2%	DB	64.0	68.9	79.9	89.6	96.5	101.4	105.7	105.8	99.8	91.7	76.5	67.8	(21)
(22)		MCWB	50.8	51.7	57.8	61.5	66.7	68.1	74.4	72.1	68.3	66.1	59.2	54.8	(22)	
(23)		5%	DB	60.4	65.1	75.5	85.7	93.7	98.6	102.5	103.2	96.5	88.4	73.2	63.7	(23)
(24)		MCWB	48.8	50.5	56.1	60.9	65.5	67.9	72.8	72.1	68.0	64.8	58.1	52.5	(24)	
(25)		10%	DB	57.4	62.2	71.8	81.8	90.6	95.9	99.9	100.4	93.7	85.0	70.1	60.4	(25)
(26)		MCWB	47.3	49.4	54.0	59.3	64.2	67.1	70.9	71.1	67.9	63.6	56.3	50.5	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.1	57.4	64.9	68.7	75.2	76.4	81.5	83.2	75.6	71.9	65.7	59.6	(27)
(28)		MCDWB	64.9	67.7	79.3	87.9	92.7	92.3	100.9	102.5	93.3	85.8	73.4	67.2	(28)	
(29)		2%	WB	52.3	54.4	60.4	65.1	69.2	72.7	77.4	78.6	72.9	69.6	62.1	56.4	(29)
(30)		MCDWB	61.3	65.6	75.3	82.9	90.8	94.3	100.9	98.9	91.3	84.5	71.1	64.5	(30)	
(31)		5%	WB	50.1	52.1	57.3	62.5	67.2	70.4	75.2	75.9	71.2	67.7	59.7	53.9	(31)
(32)		MCDWB	58.5	62.3	73.2	82.4	89.7	93.6	98.1	96.2	90.6	82.4	69.8	62.4	(32)	
(33)		10%	WB	48.3	49.9	54.9	60.2	65.3	68.6	72.7	73.3	69.6	65.8	57.6	51.6	(33)
(34)		MCDWB	55.7	59.9	69.8	79.4	88.0	92.8	96.1	94.7	89.3	80.7	67.7	59.3	(34)	
(35)	Mean Daily Temperature Range		MDBR	18.4	19.2	22.2	23.6	25.6	27.8	27.7	27.7	25.6	23.6	21.0	19.0	(35)
(36)		5% DB	MCDBR	22.6	23.9	27.1	27.1	27.9	29.7	29.5	29.3	27.5	26.7	24.7	22.4	(36)
(37)			MCWBR	12.7	12.4	14.1	12.8	13.1	12.9	13.3	12.0	12.3	13.1	13.7	13.7	(37)
(38)			MCDBR	21.3	21.8	24.8	25.9	26.6	29.2	28.8	28.8	26.4	23.7	22.3	21.5	(38)
(39)		5% WB	MCWBR	13.1	13.0	14.1	13.8	13.6	14.8	14.8	14.6	13.5	12.8	13.4	14.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.339	0.366	0.412	0.473	0.476	0.404	0.403	0.407	0.397	0.427	0.371	0.345	(40)	
(41)		taud	2.264	2.170	2.022	1.866	1.886	2.113	2.137	2.127	2.142	2.038	2.177	2.246	(41)	
(42)		Ebn at Noon	275	278	273	261	261	279	279	276	274	253	259	265	(42)	
(43)		Edh at Noon	35	42	52	64	63	50	49	49	46	47	37	33	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1046	1310	1742	2073	2363	2655	2544	2328	1995	1520	1154	960	(44)	
(45)		RadStd	48	95	70	72	115	39	44	49	68	73	73	49	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (6 neighbors)	+0.58	N/A	N/A	N/A	+0.97	+0.85	N/A	N/A	+209	+131	(47)

Nomenclature: See separate page