

RUWAISHED H4 AB, Jordan

WMO: 402500

Lat: 32.539N

Lon: 38.195E

Elev: 686

StdP: 93.35

Time Zone: 2.00 (JOR)

Period: 94-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.4	1.4	-8.1	2.1	7.7	-6.2	2.4	8.3	13.4	10.8	10.5	10.1	0.7	70	0.410

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.4	40.8	22.5	39.4	22.0	38.0	21.2	25.5	37.1	24.1	35.7	22.8	34.8	2.4	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.1	18.3	32.9	20.5	16.5	31.4	19.0	15.0	29.9	82.7	36.7	76.6	35.7	71.2	34.8	31.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.3	9.4	8.1	-2.7	41.9	1.9	1.8	-4.0	43.2	-5.1	44.3	-6.2	45.3	-7.6	46.6
			-3.7	25.9	1.3	2.4	-4.7	27.6	-5.5	29.0	-6.2	30.4	-7.2	32.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.9	8.2	10.5	14.5	18.8	24.2	27.6	30.0	30.2	27.1	22.0	14.8	10.1
	DBStd	8.34	2.95	3.03	3.65	4.32	3.37	2.49	2.27	2.33	2.67	3.40	3.26	3.19
	HDD10.0	143	69	27	4	1	0	0	0	0	0	4	38	
	HDD18.3	1086	313	219	129	45	2	0	0	0	9	112	256	
	CDD10.0	3750	15	42	143	266	440	528	619	625	512	372	148	40
	CDD18.3	1651	0	0	10	60	184	278	361	367	262	122	7	0
	CDH23.3	21807	0	2	124	708	2268	3773	5229	5247	3208	1193	52	3
	CDH26.7	12468	0	0	31	267	1120	2194	3297	3321	1763	471	5	0
Wind	WSAvg	2.3	2.3	2.9	3.2	3.0	2.5	2.1	1.9	1.6	1.9	1.8	2.0	2.1
Precipitation	PrecAvg	79	14	13	11	9	4	0	0	0	7	10	12	
	PrecMax	183	79	52	44	45	28	6	0	0	10	54	44	51
	PrecMin	17	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	34	14	14	11	12	7	1	0	0	1	12	12	13
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.4	23.0	30.3	35.1	37.8	40.2	43.2	42.9	39.8	35.4	27.1	23.2
		MCWB	12.2	12.6	15.9	17.5	20.6	20.0	22.8	24.2	20.6	19.2	15.3	13.5
	2%	DB	17.8	20.5	26.6	32.0	35.9	38.6	40.9	41.0	37.6	33.2	24.7	19.9
		MCWB	10.4	10.9	14.4	16.4	19.3	20.0	23.5	22.3	20.2	19.0	15.1	12.7
	5%	DB	15.8	18.4	24.1	29.8	34.3	37.0	39.2	39.6	35.9	31.3	22.9	17.6
		MCWB	9.4	10.3	13.4	16.0	18.6	19.9	22.7	22.3	20.0	18.2	14.5	11.4
	10%	DB	14.1	16.8	22.1	27.7	32.6	35.5	37.7	38.0	34.3	29.5	21.2	15.8
		MCWB	8.5	9.7	12.2	15.2	17.9	19.5	21.6	21.7	20.0	17.6	13.5	10.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.4	14.1	18.3	20.4	24.0	24.7	27.5	28.4	24.2	22.2	18.7	15.4
		MCDB	18.3	19.8	26.3	31.1	33.7	33.5	38.3	39.2	34.1	29.9	23.0	19.6
	2%	WB	11.3	12.5	15.8	18.4	20.7	22.6	25.2	25.9	22.7	20.9	16.7	13.5
		MCDB	16.3	18.7	24.0	28.3	32.7	34.6	38.3	37.1	33.0	29.2	21.7	18.0
	5%	WB	10.0	11.2	14.0	17.0	19.6	21.3	24.0	24.4	21.8	19.8	15.4	12.2
		MCDB	14.7	16.8	22.9	28.0	32.0	34.2	36.7	35.7	32.6	28.0	21.0	16.9
	10%	WB	9.0	10.0	12.7	15.7	18.5	20.3	22.6	22.9	20.9	18.8	14.2	10.9
		MCDB	13.2	15.5	21.0	26.3	31.1	33.8	35.6	34.8	31.8	27.0	19.9	15.1
Mean Daily Temperature Range	5% DB	MDBR	10.2	10.7	12.3	13.1	14.2	15.5	15.4	15.4	14.2	13.1	11.7	10.6
		MCDBR	12.6	13.3	15.0	15.1	15.5	16.5	16.4	16.3	15.3	14.8	13.7	12.5
		MCWBR	7.0	6.9	7.8	7.1	7.3	7.2	7.4	6.6	6.8	7.3	7.6	7.6
	5% WB	MCDBR	11.9	12.1	13.8	14.4	14.8	16.2	16.0	16.0	14.7	13.2	12.4	12.0
	MCWBR	7.3	7.2	7.8	7.7	7.6	8.2	8.2	8.1	7.5	7.1	7.5	8.0	
Clear-Sky Solar Irradiance	taub	0.339	0.366	0.412	0.473	0.476	0.404	0.403	0.407	0.397	0.427	0.371	0.345	
	taud	2.264	2.170	2.022	1.866	1.886	2.113	2.137	2.127	2.142	2.038	2.177	2.246	
	Ebn at Noon	866	877	861	822	822	880	879	871	865	797	817	834	
	Edh at Noon	109	132	165	202	200	159	154	153	145	149	118	105	
All-Sky Solar Radiation	RadAvg	3.30	4.13	5.49	6.53	7.45	8.37	8.02	7.34	6.29	4.79	3.64	3.03	
	RadStd	0.15	0.30	0.22	0.23	0.36	0.12	0.14	0.15	0.21	0.23	0.23	0.15	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	+0.32	N/A	N/A	N/A	+0.54	+0.47	N/A	N/A	+116

Nomenclature: See separate page