

PRINCE HASAN AB, Jordan

WMO: 402600

Lat: 32.161N

Lon: 37.149E

Elev: 2220

StdP: 13.55

Time Zone: 2.00 (JOR)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 33.5	(c) 36.1	(d) 8.5	(e) 9.2	(f) 58.2	(g) 13.8	(h) 12.0	(i) 57.7	(j) 34.7	(k) 48.9	(l) 30.4	(m) 47.9	(n) 3.4	(o) 350	(p) 0.477

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 26.2	(c) 104.1	(d) 71.7	(e) 101.8	(f) 70.9	(g) 99.4	(h) 69.9	(i) 77.5	(j) 99.2	(k) 75.4	(l) 96.6	(m) 73.6	(n) 94.0	(o) 8.1	(p) 250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.8	123.2	92.7	68.5	113.6	90.3	66.5	106.0	88.0	42.8	98.9	40.6	96.3	38.7	94.1	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years				
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
29.8	25.1	22.1	29.4	107.6	3.4	2.4	27.0	109.3	25.0	110.7	23.1	112.0	20.7	113.7
			25.7	78.1	3.4	4.2	23.2	81.1	21.3	83.6	19.4	86.0	16.9	89.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	68.1	47.6	51.6	58.5	65.7	75.9	81.9	85.6	85.9	81.0	72.5	59.4	50.7	(6)
	DBStd	14.76	4.64	5.50	6.52	7.82	6.94	5.08	4.44	4.34	4.79	5.96	5.75	5.22	(7)
	HDD50	210	101	41	8	2	0	0	0	0	0	0	5	53	(8)
	HDD65	1863	540	375	222	86	5	0	0	0	0	11	182	442	(9)
	CDD50	6817	26	86	270	474	802	956	1102	1112	931	697	286	75	(10)
	CDD65	2998	0	0	19	108	342	506	637	647	481	244	14	0	(11)
	CDH74	38962	0	5	205	1222	4288	6859	9006	9111	5898	2267	99	2	(12)
	CDH80	21655	0	0	42	425	2126	3915	5515	5612	3174	837	9	0	(13)
(14) Wind	WSAvg	8.0	6.8	7.8	9.3	10.2	9.9	9.6	9.8	8.2	7.3	6.2	6.0	5.6	(14)
(15) Precipitation	PrecAvg	2.6	0.6	0.5	0.4	0.1	0.0	0.0	0.0	0.0	0.0	0.2	0.3	0.5	(15)
	PrecMax	4.9	1.7	1.5	1.8	1.1	0.3	0.0	0.0	0.0	0.1	1.1	1.4	1.6	(16)
	PrecMin	1.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
	PrecStd	1.1	0.4	0.4	0.4	0.2	0.1	0.0	0.0	0.0	0.0	0.3	0.4	0.5	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.9	74.5	86.5	93.9	100.7	103.6	108.0	107.0	103.0	94.5	82.2	71.8	(19)
		MCWB	49.7	52.9	58.8	66.2	66.5	69.5	76.8	73.2	69.7	66.9	58.9	53.8	(20)
	2%	DB	63.2	69.9	80.2	88.5	96.7	101.0	104.5	103.9	99.3	91.1	77.2	66.9	(21)
		MCWB	49.4	50.7	56.2	61.6	66.0	68.9	72.9	72.3	69.1	65.5	57.1	52.2	(22)
	5%	DB	60.4	66.2	75.4	84.7	93.6	98.4	101.5	101.5	96.2	88.1	73.8	63.7	(23)
		MCWB	48.1	49.4	53.7	59.5	65.0	69.0	71.5	72.0	68.4	64.3	56.2	50.6	(24)
	10%	DB	57.6	63.0	71.8	81.5	90.6	95.5	98.6	98.9	93.6	84.9	70.9	60.7	(25)
		MCWB	46.9	48.1	52.7	57.9	64.0	67.7	70.0	70.4	67.7	62.9	55.6	49.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.9	56.2	61.6	67.2	71.3	75.4	80.2	80.8	76.2	71.3	61.8	57.4	(27)
		MCDB	62.1	67.9	79.0	91.1	94.9	97.0	104.8	101.6	95.7	89.0	72.3	66.7	(28)
	2%	WB	51.4	53.2	58.6	64.6	69.4	73.5	77.4	78.1	73.8	68.8	60.1	54.4	(29)
		MCDB	59.8	64.8	75.4	85.6	92.0	96.5	100.7	99.0	92.7	85.8	71.0	63.8	(30)
	5%	WB	49.5	51.2	56.1	62.3	67.5	71.8	75.4	75.7	72.0	66.8	58.8	52.3	(31)
		MCDB	57.3	62.1	71.7	80.6	89.2	94.6	97.8	96.3	90.3	83.0	69.4	60.9	(32)
	10%	WB	47.9	49.6	53.9	59.8	65.6	70.1	73.1	73.7	70.4	65.0	57.4	50.5	(33)
		MCDB	55.5	60.0	68.6	76.7	86.4	91.6	93.6	93.8	88.3	80.7	68.1	58.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	17.7	19.0	20.7	23.2	24.5	26.0	26.0	26.2	24.5	22.1	19.9	18.2	(35)
		MCDBR	21.8	23.8	25.7	26.2	25.8	27.4	27.8	27.1	25.7	24.4	23.1	21.3	(36)
	5% WB	MCWBR	12.3	12.3	12.3	13.4	12.3	12.3	13.1	12.4	11.6	11.9	12.3	12.1	(37)
		MCWBR	19.1	20.0	23.8	25.3	24.9	26.9	27.2	26.7	24.7	23.0	20.3	19.1	(38)
(40) Clear-Sky Solar Irradiance	taub		0.340	0.367	0.410	0.464	0.465	0.390	0.393	0.396	0.389	0.418	0.369	0.344	(40)
	taud		2.309	2.217	2.071	1.926	1.955	2.203	2.209	2.205	2.217	2.113	2.236	2.300	(41)
	Ebn at Noon		276	279	274	264	264	283	282	280	278	257	262	267	(42)
	Edh at Noon		33	40	50	60	59	46	46	45	43	44	36	32	(43)
(44) All-Sky Solar Radiation	RadAvg		1026	1288	1727	2067	2388	2660	2565	2345	2015	1537	1158	950	(44)
(45)	RadStd		52	94	78	87	107	31	38	41	57	64	63	49	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (12 neighbors)	+0.74	N/A	-2.95	N/A	N/A	N/A	N/A	N/A	+241	+160