

PRINCE HASAN AB, Jordan

WMO: 402600

Lat: 32.161N

Lon: 37.149E

Elev: 677

StdP: 93.46

Time Zone: 2.00 (JOR)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.8	2.3	-13.1	1.3	14.6	-10.1	1.7	14.3	15.5	9.4	13.6	8.8	1.5	350	0.477

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.6	40.0	22.1	38.8	21.6	37.4	21.0	25.3	37.3	24.1	35.9	23.1	34.5	3.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.5	17.6	33.7	20.3	16.2	32.4	19.2	15.1	31.1	81.7	37.2	76.5	35.7	72.2	34.5	29.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
13.3	11.2	9.9	-1.4	42.0	1.9	1.3	-2.8	42.9	-3.9	43.7	-4.9	44.4	-6.3	45.4	
			DB												
			WB	-3.5	25.6	1.9	2.4	-4.9	27.3	-6.0	28.7	-7.0	30.0	-8.4	31.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.1	8.7	10.9	14.7	18.7	24.4	27.7	29.8	29.9	27.2	22.5	15.2	10.4
	DBStd	8.20	2.58	3.06	3.62	4.35	3.85	2.82	2.47	2.41	2.66	3.31	3.19	2.90
	HDD10.0	117	56	23	4	1	0	0	0	0	0	0	3	29
	HDD18.3	1035	300	208	123	48	3	0	0	0	0	6	101	246
	CDD10.0	3787	14	48	150	263	446	531	612	618	517	387	159	42
	CDD18.3	1666	0	0	11	60	190	281	354	359	267	136	8	0
	CDH23.3	21646	0	3	114	679	2382	3811	5003	5062	3277	1259	55	1
	CDH26.7	12031	0	0	23	236	1181	2175	3064	3118	1763	465	5	0
Wind	WSAvg	3.6	3.0	3.5	4.1	4.5	4.4	4.3	4.4	3.7	3.2	2.8	2.7	2.5
Precipitation	PrecAvg	66	15	12	9	3	1	0	0	0	0	4	8	12
	PrecMax	124	42	38	46	28	8	0	0	0	2	28	36	40
	PrecMin	32	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	27	10	10	11	6	2	0	0	0	0	7	11	12
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.4	23.6	30.3	34.4	38.1	39.8	42.2	41.7	39.4	34.7	27.9	22.1
		MCWB	9.8	11.6	14.9	19.0	19.2	20.8	24.9	22.9	21.0	19.4	14.9	12.1
	2%	DB	17.3	21.1	26.8	31.4	35.9	38.3	40.3	40.0	37.4	32.8	25.1	19.4
		MCWB	9.7	10.4	13.4	16.4	18.9	20.5	22.7	22.4	20.6	18.6	14.0	11.2
	5%	DB	15.8	19.0	24.1	29.3	34.2	36.9	38.6	38.6	35.7	31.2	23.2	17.6
		MCWB	9.0	9.7	12.1	15.3	18.4	20.5	21.9	22.2	20.2	18.0	13.5	10.3
	10%	DB	14.2	17.2	22.1	27.5	32.5	35.3	37.0	37.2	34.2	29.4	21.6	15.9
		MCWB	8.3	9.0	11.5	14.4	17.8	19.8	21.1	21.4	19.8	17.2	13.1	9.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.2	13.4	16.4	19.6	21.8	24.1	26.8	27.1	24.6	21.8	16.6	14.1
		MCDB	16.7	19.9	26.1	32.8	35.0	36.1	40.5	38.6	35.4	31.6	22.4	19.3
	2%	WB	10.8	11.8	14.8	18.1	20.8	23.1	25.2	25.6	23.2	20.4	15.6	12.4
		MCDB	15.4	18.2	24.1	29.8	33.3	35.8	38.2	37.2	33.7	29.9	21.6	17.7
	5%	WB	9.7	10.7	13.4	16.8	19.7	22.1	24.1	24.3	22.2	19.4	14.9	11.3
		MCDB	14.1	16.7	22.1	27.0	31.8	34.8	36.6	35.7	32.4	28.4	20.8	16.1
	10%	WB	8.8	9.8	12.1	15.4	18.7	21.1	22.8	23.2	21.3	18.3	14.1	10.3
		MCDB	13.0	15.6	20.4	24.8	30.2	33.1	34.2	34.3	31.3	27.1	20.1	14.6
Mean Daily Temperature Range	5% DB	MDBR	9.9	10.6	11.5	12.9	13.6	14.4	14.4	14.6	13.6	12.3	11.1	10.1
		MCDBR	12.1	13.2	14.3	14.5	14.3	15.2	15.4	15.1	14.3	13.5	12.8	11.9
		MCWBR	6.8	6.8	6.8	7.4	6.8	6.9	7.3	6.9	6.4	6.6	6.8	6.7
	5% WB	MCDBR	10.6	11.1	13.2	14.1	13.8	15.0	15.1	14.8	13.7	12.8	11.3	10.6
		MCWBR	6.9	6.4	7.2	7.9	7.7	8.0	8.2	8.1	7.3	7.2	6.6	6.6
Clear-Sky Solar Irradiance	taub	0.340	0.367	0.410	0.464	0.465	0.390	0.393	0.396	0.389	0.418	0.369	0.344	
	taud	2.309	2.217	2.071	1.926	1.955	2.203	2.209	2.205	2.217	2.113	2.236	2.300	
	Ebn at Noon	870	880	864	831	832	893	888	883	875	811	825	842	
	Edh at Noon	105	127	158	190	187	145	144	142	135	139	112	101	
All-Sky Solar Radiation	RadAvg	3.23	4.06	5.44	6.51	7.53	8.38	8.09	7.39	6.35	4.84	3.65	3.00	
	RadStd	0.17	0.30	0.25	0.27	0.34	0.10	0.12	0.13	0.18	0.20	0.20	0.15	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (12 neighbors)	+0.41	N/A	-1.64	N/A	N/A	N/A	N/A	N/A	+134	+89	

Nomenclature: See separate page