

GAWR AL-SAFI, Jordan

WMO: 402960

Lat: 31.033N

Lon: 35.467E

Elev: -1148

StdP: 15.32

Time Zone: 2.00 (JOR)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	48.0	50.4	33.5	26.9	59.6	36.6	30.4	59.9	15.2	64.8	12.9	65.0	0.1	N/A	0.320

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.7	107.3	77.7	105.4	77.1	103.5	77.0	82.2	100.5	80.9	98.6	79.7	97.6	1.0	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.0	134.8	94.2	75.5	127.7	93.6	74.1	121.9	92.8	45.0	100.8	43.4	99.0	42.3	97.4	93.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.5	10.1	7.7	DB	39.6	112.8	5.5	2.7	35.7	114.7	32.4	116.3	29.3	117.8	25.3	119.7
			WB	36.5	85.7	5.0	2.6	32.9	87.6	30.0	89.1	27.2	90.5	23.6	92.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	78.7	60.9	64.1	70.1	76.9	84.6	90.2	94.0	94.0	90.2	83.4	71.9	63.4
	DBStd	12.52	3.55	3.89	4.96	5.72	4.64	3.44	2.55	2.66	3.10	4.39	4.91	4.62
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	292	132	55	12	1	0	0	0	0	0	0	7	85
	CDD50	10483	340	396	622	807	1071	1206	1365	1364	1206	1034	656	416
	CDD65	5298	6	30	169	358	606	756	900	899	756	569	213	36
	CDH74	73187	11	112	1098	3487	8035	11610	14682	14611	11359	6832	1260	90
	CDH80	44637	0	9	309	1482	4402	7403	10233	10159	7085	3268	280	7
Wind	WSAvg	1.1	0.8	1.3	1.8	1.7	1.5	1.3	1.0	0.9	1.0	0.9	0.8	0.7
Precipitation	PrecAvg	7.4	1.9	1.7	1.1	0.4	0.2	0.0	0.0	0.0	0.0	0.2	0.7	1.3
	PrecMax	13.1	3.0	4.3	5.2	2.1	1.9	0.0	0.0	0.0	0.2	2.0	3.9	3.3
	PrecMin	3.3	0.0	0.6	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	2.3	0.8	0.7	0.9	0.4	0.4	0.0	0.0	0.0	0.0	0.4	0.8	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.5	81.1	92.6	100.8	106.2	107.8	110.5	108.9	106.3	100.1	88.9	80.1
		MCWB	60.4	62.7	68.3	71.4	75.9	77.4	78.1	80.6	77.2	76.7	68.8	63.4
	2%	DB	72.9	77.4	86.8	95.6	100.9	105.0	107.9	106.2	102.4	96.2	85.6	76.3
		MCWB	59.4	60.6	65.8	69.8	74.5	76.3	77.5	78.1	77.6	74.3	68.3	61.9
	5%	DB	71.0	74.7	82.7	91.8	97.9	102.7	105.9	104.3	100.0	93.7	83.2	74.0
		MCWB	58.3	59.6	63.9	69.1	73.1	75.5	77.1	77.9	77.3	74.0	67.3	61.2
	10%	DB	69.1	72.5	79.6	88.0	95.2	100.2	103.7	102.5	98.0	91.6	80.8	71.9
		MCWB	57.5	58.9	62.6	67.4	72.5	75.1	76.9	77.8	76.6	73.5	66.3	60.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.0	64.9	70.0	75.2	79.9	81.2	82.7	84.0	83.0	83.1	73.4	66.4
		MCDB	71.9	76.9	88.7	95.9	96.8	101.1	104.0	102.2	97.9	93.0	83.8	75.4
	2%	WB	61.0	62.7	67.3	72.0	77.4	79.2	80.9	82.6	80.7	78.3	70.9	64.0
		MCDB	70.2	73.8	84.5	91.5	96.0	99.4	101.8	101.1	96.5	91.3	81.6	73.4
	5%	WB	59.7	61.0	65.3	70.0	75.6	78.0	79.8	81.3	79.3	76.4	69.2	62.5
		MCDB	68.8	72.0	79.8	88.7	93.6	97.8	100.6	98.8	95.5	89.6	80.1	71.8
	10%	WB	58.5	59.8	63.7	68.1	74.1	76.6	78.6	80.0	78.2	74.9	67.6	61.1
		MCDB	67.4	70.4	77.3	85.9	91.4	95.7	99.3	97.0	94.5	88.4	78.7	70.1
Mean Daily Temperature Range	5% DB	MDBR	16.8	16.0	17.3	18.8	20.2	20.6	20.7	18.6	16.5	16.0	16.9	16.6
		MCDBR	18.5	18.3	21.6	22.7	23.7	23.4	23.6	20.4	18.6	17.2	18.7	18.1
		MCWBR	9.8	8.7	9.1	9.4	9.3	8.4	8.3	6.8	7.1	7.3	8.8	9.8
	5% WB	MCDBR	17.0	16.4	20.1	21.1	21.7	21.3	21.1	18.4	16.8	16.0	17.2	16.4
		MCWBR	9.6	8.9	9.2	9.3	9.7	8.9	8.9	7.3	7.6	8.2	9.1	9.5
Clear-Sky Solar Irradiance	taub	0.408	0.453	0.515	0.574	0.572	0.478	0.484	0.495	0.493	0.512	0.436	0.407	
	taud	2.112	1.977	1.819	1.708	1.734	1.983	1.989	1.969	1.966	1.918	2.073	2.128	
	Ebn at Noon	252	251	244	236	237	259	257	253	247	230	239	244	
	Edh at Noon	41	52	65	75	74	57	57	57	56	54	43	39	
All-Sky Solar Radiation	RadAvg	1053	1326	1761	2120	2422	2666	2588	2385	2052	1589	1209	990	
	RadStd	56	72	90	68	90	32	34	30	49	57	51	52	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (19 neighbors)	+0.81	N/A	-3.47	N/A	N/A	N/A	N/A	-97	+272	+185

Nomenclature: See separate page