

AQABA KING HUSSEIN INTL, Jordan

WMO: 403400

Lat: 29.612N

Lon: 35.018E

Elev: 175

StdP: 14.60

Time Zone: 2.00 (JOR)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	46.1	48.1	22.8	17.3	66.5	26.5	20.5	65.2	23.4	64.3	21.8	64.4	4.1	0	0.487

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.2	107.6	74.7	105.7	73.6	103.9	73.1	82.1	96.7	80.3	94.7	78.7	94.5	11.7	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.8	150.3	89.3	76.6	139.8	89.2	74.2	128.5	88.5	46.2	96.9	44.2	95.3	42.4	94.5	93.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
24.9	22.3	20.2	DB	42.1	112.1	3.2	2.0	39.8	113.6	38.0	114.8	36.2	115.9	33.9	117.4	(4)
			WB	37.1	83.3	3.0	4.1	34.9	86.2	33.1	88.6	31.5	90.9	29.3	93.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	77.2	59.5	62.6	68.8	76.0	84.0	89.2	92.3	92.1	87.6	80.5	70.7	62.1	(6)
(7)		DBStd	12.55	3.92	5.05	5.97	6.23	5.40	4.01	2.91	2.92	3.28	4.92	5.09	4.29	(7)
(8)		HDD50	1	1	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	423	177	98	25	2	0	0	0	0	0	0	10	111	(9)
(10)		CDD50	9931	293	354	583	780	1054	1176	1313	1307	1128	947	621	375	(10)
(11)		CDD65	4878	5	31	143	332	589	726	848	842	678	482	181	21	(11)
(12)		CDH74	66801	41	260	1240	3508	7846	11007	13622	13291	9499	5140	1224	123	(12)
(13)	CDH80	40150	1	55	422	1646	4543	7068	9222	8880	5562	2405	330	16	(13)	
(14)	Wind	WSAvg	9.6	6.5	7.7	9.2	10.1	10.7	11.5	10.5	11.7	12.3	10.1	8.1	6.9	(14)
(15)	Precipitation	PrecAvg	0.9	0.1	0.2	0.1	0.1	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.2	(15)
(16)		PrecMax	2.4	0.9	2.6	0.9	1.1	0.5	0.0	0.0	0.0	1.4	1.1	1.7	(16)	
(17)		PrecMin	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	0.6	0.2	0.4	0.2	0.2	0.1	0.0	0.0	0.0	0.3	0.2	0.4	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.7	86.0	94.6	100.8	107.4	109.7	109.7	109.4	105.6	101.7	91.1	82.3	(19)
(20)		0.4%	MCWB	58.9	62.3	66.7	66.7	71.3	73.1	75.6	77.9	73.3	70.8	67.3	60.1	(20)
(21)		2%	DB	74.8	80.8	88.7	96.8	103.3	106.2	107.4	106.1	102.2	97.0	86.5	77.3	(21)
(22)		2%	MCWB	56.7	59.1	64.2	65.4	70.4	72.5	75.0	75.2	72.9	71.3	64.9	59.5	(22)
(23)		5%	DB	71.6	76.9	84.4	92.9	100.0	104.0	105.5	104.3	100.1	93.6	84.1	73.8	(23)
(24)		5%	MCWB	55.8	58.1	61.9	64.9	69.8	71.7	74.1	74.1	72.4	70.4	63.9	57.8	(24)
(25)		10%	DB	68.8	73.4	80.6	89.4	96.8	101.8	103.6	102.4	97.5	91.1	80.8	71.5	(25)
(26)		10%	MCWB	54.6	56.8	60.6	64.3	68.4	71.4	73.5	73.7	72.2	69.9	62.8	57.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.4	66.7	73.6	74.0	78.4	80.8	84.4	85.4	82.6	79.4	71.9	66.9	(27)
(28)		0.4%	MCDWB	70.7	78.5	84.6	85.1	92.4	99.4	101.3	98.2	92.8	88.8	82.6	73.9	(28)
(29)		2%	WB	59.6	62.4	69.1	71.0	75.3	78.0	81.2	82.6	80.0	76.3	69.0	62.7	(29)
(30)		2%	MCDWB	69.4	76.1	80.7	86.3	93.0	96.9	98.7	97.2	89.8	87.2	79.9	72.0	(30)
(31)		5%	WB	57.6	59.8	65.5	68.2	73.3	76.2	79.3	80.8	77.9	74.1	66.8	60.0	(31)
(32)		5%	MCDWB	67.6	72.4	78.9	85.3	92.2	94.5	97.2	94.6	89.7	86.0	78.4	70.6	(32)
(33)		10%	WB	55.8	57.9	62.7	66.0	71.3	74.4	77.5	79.0	75.9	72.3	65.0	58.1	(33)
(34)		10%	MCDWB	66.3	70.4	76.4	83.9	90.5	93.7	96.1	94.5	89.9	85.2	77.1	68.6	(34)
(35)	Mean Daily Temperature Range		MDBR	18.7	20.0	21.2	22.7	23.6	24.3	23.2	22.0	21.0	20.1	19.6	19.1	(35)
(36)		5% DB	MCDBR	22.1	24.2	25.3	26.3	26.6	26.4	24.7	23.0	22.7	22.7	21.8	21.6	(36)
(37)		5% DB	MCWBR	10.9	11.3	11.5	10.7	10.5	9.6	9.0	8.0	8.2	9.0	9.8	10.7	(37)
(38)		5% WB	MCDWR	19.5	21.4	21.7	22.7	24.0	24.8	23.4	21.6	21.1	20.2	19.9	19.4	(38)
(39)		5% WB	MCWBR	11.4	11.5	13.3	11.2	11.5	11.0	10.3	9.6	9.8	10.0	10.7	11.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.366	0.408	0.472	0.499	0.504	0.422	0.427	0.436	0.433	0.439	0.376	0.348	(40)	
(41)		taud	2.238	2.092	1.896	1.859	1.876	2.137	2.155	2.138	2.133	2.093	2.258	2.328	(41)	
(42)		Ebn at Noon	271	268	258	256	254	275	273	270	266	255	266	272	(42)	
(43)		Edh at Noon	37	47	61	65	64	49	48	49	47	46	36	32	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1211	1514	1945	2264	2493	2701	2609	2421	2116	1695	1343	1142	(44)	
(45)		RadStd	50	58	63	52	82	28	43	34	49	52	41	33	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.86	N/A	-4.00	N/A	-2.77	-4.19	N/A	N/A	N/A	N/A	(46)
(47)	Regional (11 neighbors)	+0.77	N/A	-2.84	N/A	N/A	N/A	N/A	N/A	+243	+263	(47)

Nomenclature: See separate page