

ERBIL INTL, Iraq

WMO: 406356

Lat: 36.233N

Lon: 43.967E

Elev: 409

StdP: 96.51

Time Zone: 3.00 (E03)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.2	0.8	-11.0	1.5	18.1	-8.8	1.9	19.4	11.5	10.6	10.1	10.0	1.6	300	0.466

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.9	45.0	19.7	43.9	19.7	42.2	19.2	22.1	39.2	21.0	39.0	20.1	39.8	4.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.8	12.6	26.8	15.5	11.6	23.8	14.4	10.8	23.0	66.9	39.1	62.5	39.0	59.3	39.8	27.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
8.8	7.5	6.3	-3.2	46.5	1.7	1.4	-4.5	47.5	-5.4	48.3	-6.4	49.1	-7.6	50.2	
			DB												
			WB	-3.8	23.9	1.5	2.5	-4.9	25.7	-5.8	27.2	-6.7	28.6	-7.8	30.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	21.0	8.2	10.0	13.2	18.3	24.7	31.3	34.5	34.3	29.3	22.7	14.6	10.1
	DBStd	9.87	2.75	3.21	3.44	3.24	3.31	2.42	2.06	1.91	2.79	3.36	3.56	2.74
	HDD10.0	151	67	36	11	0	0	0	0	0	0	0	6	31
	HDD18.3	1129	314	234	162	39	1	0	0	0	5	118	256	
	CDD10.0	4165	12	36	110	248	456	638	760	753	581	395	144	34
	CDD18.3	2101	0	0	3	37	198	388	502	494	331	141	7	0
	CDH23.3	33742	0	1	41	511	2804	6416	8896	8566	4837	1577	89	4
	CDH26.7	22446	0	0	3	144	1507	4358	6501	6171	3053	701	7	1
(14) Wind	WSAvg	2.6	2.5	2.5	2.8	2.8	2.9	3.1	2.9	2.7	2.4	2.5	2.1	2.3
(15) Precipitation	PrecAvg	476	59	60	65	69	40	12	12	8	11	32	50	59
	PrecMax	634	94	114	133	122	120	37	25	18	33	82	120	119
	PrecMin	285	24	14	27	23	9	3	2	2	1	6	5	13
	PrecStd	84	21	23	27	29	23	9	6	4	7	20	30	30
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.7	22.1	27.0	32.8	38.9	44.2	46.3	46.2	42.8	36.2	27.9	22.1
		MCWB	9.8	11.8	14.7	15.3	17.7	19.5	19.9	20.1	19.1	17.4	14.5	11.5
	2%	DB	16.2	20.1	24.2	30.1	37.0	42.8	45.1	45.0	41.1	34.0	26.0	19.0
		MCWB	9.7	11.6	13.5	15.7	17.6	19.1	19.6	19.9	18.3	16.4	13.3	10.9
	5%	DB	15.0	18.2	22.2	28.1	35.2	41.1	44.0	43.9	39.2	32.4	24.0	17.1
		MCWB	9.7	11.1	12.8	15.5	17.2	18.7	19.6	19.9	18.3	16.0	12.7	10.0
	10%	DB	13.8	16.1	20.8	26.2	33.9	39.8	42.8	42.6	37.9	30.9	21.9	15.8
		MCWB	9.3	10.2	12.5	15.2	16.9	18.1	19.2	19.7	17.7	15.5	12.6	9.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.2	14.1	16.2	19.2	20.7	22.3	23.3	24.4	22.2	20.1	17.2	13.7
		MCDB	14.5	19.1	21.5	26.5	32.8	37.3	40.2	40.9	36.2	31.3	22.0	17.3
	2%	WB	12.0	12.7	15.1	17.7	19.4	20.6	21.6	22.6	20.2	18.6	15.8	12.6
		MCDB	14.2	17.4	21.4	25.6	32.1	37.4	40.4	39.7	36.0	28.0	20.6	16.0
	5%	WB	10.7	11.9	14.1	16.9	18.5	19.7	20.6	21.1	19.2	17.7	14.8	11.7
		MCDB	13.8	16.4	20.6	24.3	31.0	38.5	41.4	40.4	36.6	27.1	20.2	15.1
	10%	WB	9.8	11.0	13.2	16.1	17.7	18.8	19.8	20.1	18.4	16.9	13.9	11.0
		MCDB	12.7	15.3	19.4	23.1	30.0	37.8	41.4	41.3	36.0	25.9	19.7	14.2
(35) Mean Daily Temperature Range	5% DB	MDBR	9.7	10.5	11.5	13.8	15.1	15.7	15.9	16.0	15.5	13.3	12.2	10.2
		MCDBR	12.5	13.5	14.6	16.6	17.1	17.5	17.7	17.7	17.2	15.6	15.1	13.4
		MCWBR	7.3	7.0	6.9	6.8	6.7	6.5	6.7	6.9	7.0	7.4	8.0	7.7
	5% WB	MCDBR	9.2	10.8	12.1	14.1	15.5	15.6	16.1	15.7	15.2	12.0	11.3	9.6
		MCWBR	6.3	6.1	6.5	6.8	6.7	7.2	7.4	7.8	7.6	7.0	6.8	6.2
(40) Clear-Sky Solar Irradiance	taub		0.403	0.434	0.471	0.553	0.544	0.481	0.504	0.470	0.435	0.465	0.399	0.395
	taud		2.057	1.987	1.918	1.757	1.797	1.940	1.892	1.976	2.054	1.964	2.115	2.090
	Ebn at Noon		752	778	789	747	761	811	788	807	814	735	752	731
	Edh at Noon		127	153	179	222	217	188	196	176	154	155	119	116
(44) All-Sky Solar Radiation	RadAvg		2.40	3.25	4.46	5.53	6.81	8.04	7.68	6.98	5.82	4.07	2.96	2.22
	RadStd		0.23	0.35	0.42	0.40	0.39	0.36	0.21	0.23	0.27	0.30	0.30	0.29

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)	N/A	-1.79	N/A	+1.25	N/A	-0.38	N/A	N/A	N/A	N/A

Nomenclature: See separate page