

PARSABAD MOGHAN, Iran, Islamic Republic of

WMO: 407000

Lat: 39.6064N

Lon: 47.8822E

Elev: 105

StdP: 14.64

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.9	26.9	18.4	14.0	31.1	21.4	16.1	31.7	25.4	44.7	22.3	42.0	6.3	240	0.433

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.9	96.7	73.8	94.6	73.2	92.5	72.5	77.3	90.9	76.0	89.3	74.7	87.6	8.4	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.5	125.3	83.2	71.9	118.5	82.8	70.5	112.9	81.9	40.9	90.9	39.6	89.6	38.3	87.6	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.4	18.5	15.6	DB	19.2	100.3	5.1	2.1	15.5	101.8	12.6	103.0	9.7	104.1	6.0	105.7
			WB	17.9	79.9	5.0	2.0	14.3	81.3	11.4	82.5	8.5	83.7	4.9	85.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.0	39.0	41.7	48.7	56.8	68.8	77.2	81.1	80.5	72.6	61.3	49.7	42.1	(6)
	DBStd	16.09	6.20	5.85	5.63	6.91	5.09	4.39	3.89	4.01	5.33	6.32	6.23	5.60	(7)
	HDD50	1027	344	238	91	19	0	0	0	0	0	5	78	252	(8)
	HDD65	3570	806	654	506	258	23	0	0	0	8	145	460	710	(9)
	CDD50	4695	3	4	51	222	583	815	965	945	677	355	68	7	(10)
	CDD65	1762	0	0	0	11	141	365	500	480	235	30	0	0	(11)
	CDH74	18150	0	0	11	135	1146	3816	5708	5350	1794	187	3	0	(12)
	CDH80	8403	0	0	0	19	317	1845	2903	2712	577	30	0	0	(13)
(14) Wind	WSAvg	6.1	6.1	6.2	6.8	6.0	6.4	6.9	7.3	6.8	5.9	5.1	4.8	5.4	(14)
(15) Precipitation	PrecAvg	10.7	0.7	0.8	1.2	1.1	1.2	1.0	0.2	0.2	1.1	1.5	1.1	0.7	(15)
	PrecMax	16.3	2.4	2.8	3.3	3.6	3.2	2.8	1.0	0.9	5.6	3.5	3.6	2.2	(16)
	PrecMin	6.7	0.1	0.2	0.3	0.0	0.1	0.1	0.0	0.0	0.0	0.2	0.0	0.0	(17)
	PrecStd	2.1	0.5	0.5	0.7	0.9	0.7	0.7	0.3	0.2	1.5	0.9	1.0	0.5	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	63.9	65.9	75.1	82.5	90.5	98.7	100.2	99.0	91.8	84.1	71.3	64.4	(19)
		MCWB	48.8	51.2	59.5	66.1	71.4	72.1	74.7	75.6	73.8	67.7	58.1	52.2	(20)
	2%	DB	56.4	58.9	68.5	77.9	86.4	95.0	96.6	96.5	88.9	78.7	65.9	58.0	(21)
		MCWB	46.0	49.0	55.3	64.3	69.7	71.2	74.6	73.9	72.4	66.3	57.0	49.7	(22)
	5%	DB	51.5	54.1	64.0	73.8	83.7	92.6	94.4	94.6	86.1	75.2	62.0	53.9	(23)
		MCWB	43.3	46.5	53.2	61.9	68.1	70.4	73.9	73.4	71.0	64.4	55.3	47.7	(24)
	10%	DB	47.7	50.4	59.6	69.9	80.7	89.7	92.2	92.1	83.4	72.0	58.9	50.3	(25)
		MCWB	41.6	44.9	50.9	60.1	67.0	69.7	73.1	73.0	69.9	62.9	53.7	45.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.1	52.7	60.5	68.6	74.4	76.3	79.3	79.3	77.1	69.3	60.9	53.6	(27)
		MCDB	62.7	61.4	70.4	79.6	86.7	89.9	92.1	92.8	87.6	79.4	67.9	60.6	(28)
	2%	WB	46.5	49.4	56.4	65.2	71.4	74.1	77.2	77.5	74.6	67.6	58.4	50.6	(29)
		MCDB	54.5	57.5	66.5	76.2	82.5	88.3	91.8	91.2	84.5	76.7	63.4	56.8	(30)
	5%	WB	44.3	47.2	53.8	62.8	69.7	72.6	75.9	76.2	72.9	65.8	56.2	48.4	(31)
		MCDB	49.0	53.0	62.6	72.2	80.9	87.4	90.2	89.4	82.8	73.2	60.7	52.6	(32)
	10%	WB	42.5	45.3	51.4	60.6	68.1	71.2	74.5	74.8	71.1	64.0	54.4	46.4	(33)
		MCDB	46.4	49.5	58.6	69.1	78.4	85.9	88.5	87.4	80.2	70.4	58.6	49.8	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	15.4	14.8	17.8	19.3	20.5	22.4	20.9	22.2	18.4	16.3	15.2	15.2	(35)
		MCDBR	22.6	23.1	27.0	25.8	25.4	27.5	25.1	26.6	22.9	22.2	20.4	21.1	(36)
	5% WB	MCWBR	14.1	14.1	15.1	13.8	11.4	10.0	9.5	10.3	10.0	11.0	12.5	13.8	(37)
		MCWBR	19.3	19.7	24.4	23.9	22.5	24.3	23.2	23.5	20.5	19.9	18.3	18.7	(38)
(40) Clear-Sky Solar Irradiance	taub		0.385	0.426	0.476	0.555	0.531	0.525	0.575	0.552	0.523	0.472	0.414	0.385	(40)
		taud	2.174	2.063	1.961	1.814	1.926	1.965	1.863	1.916	1.968	2.057	2.155	2.186	(41)
	Ebn at Noon		237	243	245	233	243	244	231	232	228	225	224	226	(42)
		Edh at Noon	34	43	53	66	60	58	63	59	52	43	34	31	(43)
(44) All-Sky Solar Radiation	RadAvg		617	809	1155	1483	1924	2226	2145	1908	1428	947	682	558	(44)
	RadStd		69	115	121	202	108	127	128	154	123	124	72	67	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page