

BARZARGAN, Iran, Islamic Republic of

WMO: 407010

Lat: 39.3795N

Lon: 44.3923E

Elev: 4629

StdP: 12.40

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.0	9.3	-1.8	5.9	11.5	1.8	7.1	14.1	30.1	34.6	23.0	33.4	0.5	240	0.483

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	20.4	91.6	61.8	89.1	61.7	86.3	61.0	65.1	84.8	63.8	83.4	62.7	82.0	10.7	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
58.7	87.7	72.2	56.7	81.5	72.2	55.2	77.1	71.8	32.7	85.0	31.5	83.4	30.7	82.2	77.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
26.8	21.8	17.2	2.5	96.1	8.0	2.8	-3.3	98.0	-8.0	99.7	-12.5	101.2	-18.3	103.2		
			1.6	68.2	7.6	3.3	-3.8	70.6	-8.3	72.5	-12.5	74.3	-18.0	76.7		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.1	25.4	31.7	42.0	51.1	59.5	68.7	75.1	75.7	66.8	54.7	41.7	31.1	(6)
	DBStd	18.21	8.70	8.19	7.63	6.92	5.37	5.12	4.70	4.33	6.17	6.57	6.75	8.90	(7)
	HDD50	2486	764	513	266	66	3	0	0	0	31	257	586		(8)
	HDD65	5629	1229	933	713	420	184	23	1	52	323	699	1051		(9)
	CDD50	3239	0	0	18	99	298	561	779	796	505	176	7	0	(10)
	CDD65	907	0	0	0	3	13	134	315	332	106	4	0	0	(11)
	CDH74	8631	0	0	0	22	100	1148	3061	3377	898	25	0	0	(12)
	CDH80	3005	0	0	0	2	8	297	1150	1331	216	1	0	0	(13)
(14) Wind	WSAvg	5.1	2.9	4.1	7.5	7.1	6.0	6.1	5.9	5.7	5.1	4.1	3.7	3.0	(14)
(15) Precipitation	PrecAvg	12.2	0.7	0.7	1.2	1.8	2.3	1.5	0.7	0.4	0.6	1.1	0.9	0.6	(15)
	PrecMax	20.1	1.5	2.1	3.2	4.0	5.1	3.2	2.4	2.0	2.2	3.2	2.9	1.5	(16)
	PrecMin	7.5	0.1	0.0	0.4	0.4	1.2	0.2	0.1	0.0	0.0	0.2	0.0	0.0	(17)
	PrecStd	2.9	0.4	0.5	0.7	0.9	0.9	0.7	0.6	0.4	0.6	0.8	0.7	0.4	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.9	52.1	66.8	77.2	80.5	90.0	95.1	95.1	89.7	77.0	61.2	53.8	(19)
		MCWB	36.5	40.4	47.2	52.3	56.5	60.5	63.2	62.0	60.2	54.6	47.0	42.4	(20)
	2%	DB	42.0	48.4	60.6	70.7	76.8	86.3	91.7	91.7	85.5	73.1	57.5	48.8	(21)
		MCWB	34.6	38.4	44.6	50.4	55.2	59.5	62.4	61.7	59.5	53.4	45.3	39.5	(22)
	5%	DB	39.4	46.0	57.0	66.4	73.4	83.2	89.0	89.4	82.2	69.3	54.7	45.2	(23)
		MCWB	33.6	36.9	43.2	48.9	54.7	59.0	62.3	61.6	58.1	52.2	44.2	37.7	(24)
	10%	DB	37.1	43.0	53.6	62.7	70.1	80.5	86.0	86.9	79.2	66.1	52.0	42.5	(25)
		MCWB	32.3	35.2	42.0	48.0	53.4	58.4	61.5	61.3	57.1	51.3	43.0	36.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.3	42.7	48.6	54.0	60.2	64.7	67.4	71.3	64.2	57.6	49.6	43.5	(27)
		MCDB	42.8	48.8	62.3	68.9	75.6	84.1	89.0	85.2	83.2	69.6	57.4	50.5	(28)
	2%	WB	36.1	39.5	45.9	52.0	58.0	62.4	65.1	65.4	61.7	55.3	47.2	40.8	(29)
		MCDB	40.2	46.4	58.0	65.0	70.8	81.3	85.3	84.1	80.1	67.5	53.8	46.1	(30)
	5%	WB	34.3	37.7	44.3	50.5	56.3	61.0	64.0	63.7	60.1	53.7	45.5	38.9	(31)
		MCDB	38.6	44.4	54.9	62.9	68.9	78.9	83.5	83.7	78.0	65.6	52.3	43.8	(32)
	10%	WB	32.4	35.8	42.7	49.1	54.9	59.8	62.9	62.6	58.7	52.3	43.9	37.0	(33)
		MCDB	36.8	42.3	52.5	60.7	67.0	76.7	81.9	82.4	76.2	63.5	51.0	41.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	13.1	14.0	14.5	15.7	16.7	19.6	19.4	20.4	19.5	16.5	14.7	12.2	(35)
		MCDBR	13.2	15.5	18.6	20.7	21.7	23.5	22.1	23.4	23.4	21.2	17.9	15.6	(36)
	5% WB	MCWBR	8.7	9.3	9.0	8.9	8.9	8.6	7.3	8.0	9.0	9.5	10.0	9.4	(37)
		MCWBR	11.6	14.1	15.9	17.3	18.6	21.1	20.1	20.9	21.4	18.0	15.2	13.1	(38)
(40) Clear-Sky Solar Irradiance	taub		0.296	0.331	0.391	0.460	0.436	0.415	0.461	0.442	0.378	0.376	0.318	0.293	(40)
		taud	2.355	2.253	2.095	1.941	2.078	2.191	2.067	2.110	2.278	2.219	2.371	2.389	(41)
	Ebn at Noon		277	279	272	259	269	274	260	262	273	259	266	269	(42)
		Edh at Noon	28	36	46	58	51	46	52	48	38	36	27	25	(43)
(44) All-Sky Solar Radiation	RadAvg		766	1093	1319	1557	1903	2356	2364	2155	1750	1154	780	590	(44)
	RadStd		64	99	101	162	112	144	76	70	91	78	94	74	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)	
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47)	Regional (11 neighbors)		N/A	N/A	N/A	+1.51	-0.97	-1.48	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page