

KHOY, Iran, Islamic Republic ofWMO: **407030**Lat: **38.5581N**Lon: **44.9960E**Elev: **3619**StdP: **12.87**Time Zone: **3.50 (IRN)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.9	12.2	0.4	6.4	9.5	5.2	8.2	17.2	26.8	46.4	22.0	43.2	0.8	180	0.439

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.3	96.9	65.1	94.1	64.9	91.5	64.6	68.5	90.1	67.3	88.7	66.2	87.4	7.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
61.1	92.1	78.2	59.5	87.0	76.7	58.3	83.2	76.0	35.0	90.4	33.9	88.3	33.0	87.6	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.6	18.3	15.1	2.1	100.7	8.4	3.4	-3.9	103.2	-8.9	105.2	-13.6	107.1	-19.7	109.5		
(5)			1.8	72.1	8.4	2.1	-4.2	73.6	-9.1	74.9	-13.8	76.1	-19.9	77.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	55.5	29.9	35.5	45.4	54.8	63.7	72.7	78.5	78.1	69.3	57.9	44.9	34.1	
	DBStd	17.97	9.01	8.43	7.42	6.52	5.32	5.08	4.36	4.06	5.49	6.27	6.56	9.59	
	HDD50	1917	623	407	181	25	0	0	0	0	0	12	175	494	
	HDD65	4742	1088	827	609	311	87	6	0	0	24	230	603	957	
	CDD50	3930	0	1	37	170	426	681	883	871	580	257	22	2	
	CDD65	1279	0	0	1	6	48	237	418	406	154	9	0	0	
	CDH74	15185	0	0	4	89	534	2572	4923	5008	1884	171	0	0	
	CDH80	6959	0	0	0	16	101	1046	2481	2580	712	23	0	0	
Wind	WSAvg	4.0	3.2	4.0	5.6	5.1	4.8	4.8	4.3	3.8	3.4	3.2	2.7	3.0	
Precipitation	PrecAvg	13.1	0.7	0.7	1.3	2.2	2.5	1.4	0.6	0.3	0.5	1.0	1.1	0.8	
	PrecMax	18.0	3.0	1.5	3.2	4.5	5.2	3.8	1.4	2.0	2.7	3.4	2.9	2.1	
	PrecMin	9.1	0.1	0.3	0.2	0.9	1.0	0.2	0.0	0.0	0.0	0.1	0.0	0.0	
	PrecStd	2.5	0.6	0.4	0.7	0.9	1.1	1.0	0.4	0.4	0.6	0.7	0.8	0.6	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.3	59.4	73.1	82.2	86.3	95.5	101.1	100.6	94.8	83.1	67.2	59.0	
		MCWB	41.4	44.5	51.4	57.7	58.9	63.1	65.9	65.2	61.9	57.3	50.5	46.2	
	2%	DB	49.0	55.1	67.1	75.9	82.8	92.1	97.4	97.0	90.3	78.6	63.1	53.6	
		MCWB	39.9	42.3	48.4	54.1	58.8	62.8	65.9	64.8	61.8	56.6	48.5	43.2	
	5%	DB	45.7	52.0	62.8	71.4	80.0	89.1	94.1	94.3	87.2	75.1	60.0	50.0	
		MCWB	38.4	40.8	46.4	52.4	58.3	62.2	65.9	65.1	60.9	55.4	47.7	41.8	
	10%	DB	42.5	48.6	59.2	67.9	76.8	86.1	91.2	91.7	84.2	71.6	56.8	46.7	
		MCWB	36.4	39.3	45.0	51.5	57.3	61.6	65.6	64.8	60.4	54.5	46.5	39.8	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.0	46.6	52.3	59.3	63.9	67.3	70.6	70.6	65.9	60.5	53.0	47.2
			MCDB	50.1	55.9	68.3	74.1	77.7	89.5	92.0	90.6	88.0	76.6	62.6	56.3
2%		WB	40.7	43.8	50.0	56.0	61.5	65.4	69.0	68.3	64.1	58.4	50.7	44.5	
		MCDB	47.1	52.3	64.5	69.9	76.8	86.3	90.9	89.8	84.9	73.7	59.6	52.3	
5%		WB	38.8	41.7	47.7	54.2	59.9	64.1	67.8	67.1	62.7	56.8	48.8	42.2	
		MCDB	45.1	50.2	60.6	67.5	75.2	83.7	89.2	88.9	83.1	71.4	57.4	48.4	
10%		WB	36.7	39.7	45.8	52.7	58.5	62.9	66.6	66.0	61.4	55.4	47.1	40.4	
		MCDB	42.0	47.8	57.5	65.0	73.1	81.9	87.5	87.9	80.6	69.0	55.7	46.0	
Mean Daily Temperature Range		5% DB	MDBR	15.1	17.9	20.1	20.4	21.5	23.8	24.3	26.3	27.0	23.5	19.5	15.1
			MCDBR	18.2	22.9	25.6	26.2	26.1	27.9	28.2	30.0	31.6	29.0	24.1	19.2
	MCWBR		11.0	12.7	12.1	10.9	9.5	8.9	8.8	9.0	10.8	11.8	12.5	11.5	
	5% WB	MCDBR	16.9	20.5	22.7	21.9	23.3	25.3	25.4	26.8	28.7	25.8	20.9	17.2	
		MCWBR	10.6	11.8	11.5	9.9	9.7	8.9	9.0	9.3	10.6	11.2	11.5	10.7	
Clear-Sky Solar Irradiance	taub	0.306	0.339	0.395	0.465	0.451	0.431	0.471	0.445	0.392	0.388	0.330	0.305		
	taud	2.374	2.279	2.120	1.954	2.054	2.155	2.054	2.121	2.257	2.208	2.357	2.395		
	Ebn at Noon	275	279	272	259	265	270	258	261	270	256	262	267		
	Edh at Noon	28	35	45	57	53	48	52	48	39	37	28	25		
All-Sky Solar Radiation	RadAvg	807	1122	1351	1651	2004	2458	2431	2223	1818	1214	822	644		
	RadStd	52	101	112	144	109	138	73	65	94	86	95	75		