

KHOY, Iran, Islamic Republic ofWMO: **407030**Lat: **38.5581N**Lon: **44.9960E**Elev: **1103**StdP: **88.76**Time Zone: **3.50 (IRN)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.1	-11.0	-17.6	0.9	-12.5	-14.9	1.2	-8.2	12.0	8.0	9.8	6.2	0.4	180	0.439

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.5	36.1	18.4	34.5	18.3	33.0	18.1	20.3	32.3	19.6	31.5	19.0	30.8	3.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.2	13.2	25.6	15.3	12.4	24.9	14.6	11.9	24.4	63.6	32.5	61.0	31.3	58.8	30.9	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.1	8.2	6.7	-16.6	38.2	4.7	1.9	-20.0	39.5	-22.7	40.6	-25.3	41.7	-28.7	43.1		
(5)			-16.8	22.3	4.7	1.2	-20.1	23.1	-22.8	23.8	-25.5	24.5	-28.8	25.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.1	-1.2	1.9	7.4	12.7	17.6	22.6	25.8	25.6	20.7	14.4	7.2	1.2		
	DBStd	9.98	5.00	4.68	4.12	3.62	2.95	2.82	2.42	2.26	3.05	3.48	3.64	5.33		
	HDD10.0	1065	346	226	101	14	0	0	0	0	7	97	274			
	HDD18.3	2634	604	459	338	173	48	3	0	13	128	335	532			
	CDD10.0	2183	0	1	21	94	237	378	491	484	322	143	12	1		
	CDD18.3	711	0	0	1	3	27	132	232	226	86	5	0	0		
	CDH23.3	8436	0	0	2	49	297	1429	2735	2782	1047	95	0	0		
	CDH26.7	3866	0	0	0	9	56	581	1378	1433	396	13	0	0		
(14) Wind	WSAvg	1.8	1.4	1.8	2.5	2.3	2.1	2.1	1.9	1.7	1.5	1.4	1.2	1.4		
(15) Precipitation	PrecAvg	334	17	19	33	57	64	36	14	8	13	25	27	20		
	PrecMax	458	75	39	82	115	131	97	35	50	68	87	74	54		
	PrecMin	230	2	7	6	22	25	4	0	0	0	3	0	0		
	PrecStd	63	14	9	19	23	28	25	10	10	15	18	20	14		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.8	15.2	22.8	27.9	30.2	35.3	38.4	38.1	34.9	28.4	19.6	15.0		
		MCWB	5.2	7.0	10.8	14.3	14.9	17.3	18.8	18.4	16.6	14.1	10.3	7.9		
	2%	DB	9.4	12.9	19.5	24.4	28.2	33.4	36.3	36.1	32.4	25.9	17.3	12.0		
		MCWB	4.4	5.7	9.1	12.3	14.9	17.1	18.9	18.2	16.6	13.7	9.2	6.2		
	5%	DB	7.6	11.1	17.1	21.9	26.7	31.7	34.5	34.6	30.7	23.9	15.6	10.0		
		MCWB	3.6	4.9	8.0	11.3	14.6	16.8	18.9	18.4	16.0	13.0	8.7	5.4		
	10%	DB	5.8	9.2	15.1	19.9	24.9	30.1	32.9	33.2	29.0	22.0	13.8	8.2		
		MCWB	2.5	4.0	7.2	10.8	14.1	16.5	18.7	18.2	15.8	12.5	8.0	4.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.1	8.1	11.3	15.1	17.7	19.6	21.5	21.4	18.8	15.8	11.7	8.4		
		MCDB	10.1	13.3	20.2	23.4	25.4	32.0	33.4	32.5	31.1	24.8	17.0	13.5		
	2%	WB	4.8	6.5	10.0	13.3	16.4	18.6	20.6	20.2	17.8	14.7	10.4	6.9		
		MCDB	8.4	11.3	18.0	21.1	24.9	30.1	32.7	32.1	29.4	23.2	15.3	11.3		
	5%	WB	3.8	5.4	8.7	12.4	15.5	17.8	19.9	19.5	17.1	13.8	9.3	5.7		
		MCDB	7.3	10.1	15.9	19.7	24.0	28.7	31.8	31.6	28.4	21.9	14.1	9.1		
	10%	WB	2.6	4.3	7.7	11.5	14.7	17.2	19.2	18.9	16.3	13.0	8.4	4.6		
		MCDB	5.5	8.8	14.2	18.3	22.8	27.7	30.8	31.0	27.0	20.5	13.2	7.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.4	9.9	11.1	11.3	12.0	13.2	13.5	14.6	15.0	13.1	10.8	8.4		
		MCDBR	10.1	12.7	14.2	14.6	14.5	15.5	15.6	16.6	17.6	16.1	13.4	10.7		
	5% WB	MCWBR	6.1	7.1	6.7	6.1	5.3	4.9	4.9	5.0	6.0	6.6	6.9	6.4		
		MCWBR	9.4	11.4	12.6	12.1	12.9	14.0	14.1	14.9	15.9	14.3	11.6	9.6		
(40) Clear-Sky Solar Irradiance	taub	0.306	0.339	0.395	0.465	0.451	0.431	0.471	0.445	0.392	0.388	0.330	0.305			
	taud	2.374	2.279	2.120	1.954	2.054	2.155	2.054	2.121	2.257	2.208	2.357	2.395			
	Ebn at Noon	867	878	856	815	835	850	812	824	850	807	827	841			
	Edh at Noon	88	110	143	180	166	150	165	151	124	117	89	80			
(44) All-Sky Solar Radiation	RadAvg	2.54	3.54	4.26	5.21	6.32	7.75	7.66	7.01	5.73	3.83	2.59	2.03			
	RadStd	0.16	0.32	0.35	0.45	0.34	0.43	0.23	0.20	0.29	0.27	0.30	0.23			

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	+1.20	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)		N/A	N/A	N/A	+0.86	N/A	-0.61	N/A	N/A	N/A	N/A

Nomenclature: See separate page