

ANZALI, Iran, Islamic Republic of

WMO: 407180

Lat: 37.4797N

Lon: 49.4579E

Elev: -79

StdP: 14.74

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	34.3	37.0	29.2	23.2	41.8	32.1	26.5	40.8	34.3	38.5	31.3	39.8	9.6	330	0.376

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.0	88.8	78.1	87.2	77.5	85.8	77.0	80.6	86.3	79.5	85.3	78.4	84.3	8.4	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.8	149.2	85.0	77.6	143.3	84.2	76.5	137.7	83.3	44.1	86.2	43.0	85.5	41.9	84.5	86.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	22.0	17.7	31.4	91.5	4.1	2.2	28.4	93.1	26.0	94.4	23.7	95.7	20.8	97.3
			30.8	82.1	3.6	1.7	28.3	83.3	26.2	84.3	24.2	85.3	21.6	86.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.4	46.6	45.8	49.8	56.7	67.3	75.6	79.7	79.8	73.9	65.8	56.8	50.3	(6)
	DBStd	13.24	5.03	5.09	4.96	5.15	4.83	4.27	3.43	3.52	4.31	4.83	5.41	5.22	(7)
	HDD50	386	125	131	58	6	0	0	0	0	0	0	9	57	(8)
	HDD65	2630	572	536	475	255	32	1	0	0	1	48	252	458	(9)
	CDD50	4928	19	15	51	206	537	768	921	925	717	491	213	65	(10)
	CDD65	1697	1	0	3	6	104	319	456	460	268	74	5	1	(11)
	CDH74	13745	5	4	32	34	212	2193	4645	4848	1626	123	20	3	(12)
	CDH80	3552	0	0	10	9	10	422	1328	1543	216	9	5	0	(13)
(14) Wind	WSAvg	6.3	7.1	6.8	6.6	5.9	5.8	6.0	5.7	5.8	6.3	6.4	6.4	6.4	(14)
(15) Precipitation	PrecAvg	51.5	4.3	3.8	3.6	2.9	1.7	1.7	2.3	3.1	6.9	8.0	7.6	5.6	(15)
	PrecMax	84.3	10.9	9.0	5.6	6.8	4.0	6.4	6.7	16.0	17.8	15.9	17.6	12.1	(16)
	PrecMin	35.4	1.3	0.5	0.2	0.3	0.6	0.0	0.2	0.0	0.7	0.0	0.0	0.0	(17)
	PrecStd	9.5	2.5	2.1	1.5	1.8	0.9	1.5	1.7	3.0	3.9	4.2	4.1	3.2	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.1	70.7	78.5	79.6	81.3	89.6	91.3	90.6	86.3	80.3	76.1	73.2	(19)
		MCWB	52.6	53.0	57.8	61.9	70.5	76.4	78.5	78.9	77.9	71.2	60.0	55.7	(20)
	2%	DB	59.7	58.3	63.0	68.7	78.5	86.1	88.9	88.8	84.1	77.1	68.9	64.5	(21)
		MCWB	50.0	50.4	55.7	61.1	70.8	75.1	78.2	78.6	76.7	71.7	63.1	54.2	(22)
	5%	DB	54.2	53.2	57.7	65.3	76.2	84.1	87.1	87.4	82.5	75.1	66.3	59.4	(23)
		MCWB	50.0	49.6	53.6	60.5	69.8	74.4	77.4	78.2	75.6	70.2	62.3	55.3	(24)
	10%	DB	52.0	51.2	54.9	63.2	74.2	82.3	85.6	86.1	80.8	73.2	64.2	56.7	(25)
		MCWB	49.4	48.8	52.0	59.3	68.8	73.8	76.7	77.9	74.7	68.8	60.9	53.8	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.7	54.6	59.2	65.1	73.8	79.1	82.7	81.9	79.7	74.4	66.7	59.3	(27)
		MCDB	64.2	65.9	74.1	72.2	78.0	85.6	88.0	87.4	84.6	78.0	69.5	62.9	(28)
	2%	WB	52.0	51.3	55.7	62.6	72.1	77.4	80.6	80.8	78.0	72.5	64.3	57.0	(29)
		MCDB	56.3	55.0	61.2	66.6	76.5	83.6	86.6	86.3	82.8	75.9	67.2	60.2	(30)
	5%	WB	50.6	50.2	53.8	61.0	70.7	76.3	79.1	79.9	76.5	70.8	62.7	55.3	(31)
		MCDB	53.4	52.8	57.6	64.8	75.0	82.2	85.2	85.5	81.4	74.0	65.4	58.9	(32)
	10%	WB	49.6	49.0	52.2	59.6	69.4	75.0	77.9	79.0	75.3	69.3	61.0	53.8	(33)
		MCDB	51.8	51.3	55.0	62.9	73.5	80.6	84.0	84.8	80.0	72.5	63.8	56.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	7.2	6.6	6.7	6.9	7.1	8.3	8.6	9.0	8.6	8.4	8.1	7.3	(35)
		MCDBR	12.8	12.2	14.4	11.8	9.7	11.0	10.7	10.9	10.4	10.4	11.4	11.5	(36)
	5% WB	MCWBR	7.3	7.2	7.4	6.0	5.3	5.7	6.0	6.6	6.3	6.6	7.4	7.2	(37)
		MCWBR	9.2	9.8	12.7	9.8	8.4	9.3	9.4	9.2	9.1	9.1	9.5	9.5	(38)
(40) Clear-Sky Solar Irradiance	taub		0.396	0.440	0.492	0.577	0.560	0.559	0.602	0.576	0.552	0.505	0.434	0.398	(40)
		taud	2.187	2.070	1.971	1.822	1.907	1.937	1.860	1.917	1.952	2.026	2.149	2.201	(41)
	Ebn at Noon		240	244	243	230	237	237	225	228	224	220	224	230	(42)
		Edh at Noon	35	44	54	66	62	60	64	59	54	46	36	32	(43)
(44) All-Sky Solar Radiation	RadAvg		604	774	1054	1371	1800	2012	1953	1744	1311	909	652	528	(44)
	RadStd		66	110	123	169	123	124	149	198	108	125	83	65	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.59	N/A	N/A	+1.82	N/A	N/A	N/A	N/A	N/A	N/A
Regional (8 neighbors)	+0.72	N/A	N/A	+1.76	+0.77	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page