

ANZALI, Iran, Islamic Republic of

WMO: 407180

Lat: 37.4797N

Lon: 49.4579E

Elev: -24

StdP: 101.61

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	1.3	2.8	-1.5	3.3	5.4	0.1	3.8	4.9	15.3	3.6	14.0	4.3	4.3	330	0.376

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.0	31.6	25.6	30.7	25.3	29.9	25.0	27.0	30.1	26.4	29.6	25.8	29.1	3.8	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.0	21.3	29.4	25.4	20.5	29.0	24.7	19.7	28.5	84.8	30.1	82.2	29.7	79.7	29.2	30.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.2	9.9	7.9	-0.4	33.0	2.3	1.2	-2.0	33.9	-3.3	34.7	-4.6	35.4	-6.2	36.3		
(5)			-0.6	27.8	2.0	0.9	-2.1	28.5	-3.2	29.1	-4.4	29.6	-5.8	30.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	16.9	8.1	7.7	9.9	13.7	19.6	24.2	26.5	26.6	23.3	18.8	13.8	10.2	(6)
(7)		DBStd	7.36	2.80	2.83	2.75	2.86	2.69	2.37	1.91	1.95	2.39	2.68	3.00	2.90	(7)
(8)		HDD10.0	214	69	73	32	3	0	0	0	0	0	0	5	32	(8)
(9)		HDD18.3	1461	318	298	264	142	18	1	0	1	27	140	254		(9)
(10)		CDD10.0	2738	11	8	28	114	298	427	512	514	398	273	118	36	(10)
(11)		CDD18.3	943	1	0	2	3	58	177	253	256	149	41	3	1	(11)
(12)		CDH23.3	7636	3	2	18	19	118	1218	2581	2693	903	68	11	2	(12)
(13)		CDH26.7	1973	0	0	6	5	6	234	738	857	120	5	3	0	(13)
(14)	Wind	WSAvg	2.8	3.2	3.0	2.9	2.6	2.6	2.7	2.5	2.6	2.8	2.9	2.9	2.9	(14)
(15)	Precipitation	PrecAvg	1308	110	97	91	73	44	44	58	78	174	204	193	141	(15)
(16)		PrecMax	2142	277	229	141	173	102	162	171	407	451	404	446	307	(16)
(17)		PrecMin	898	32	13	4	8	15	0	5	0	17	0	0	0	(17)
(18)		PrecStd	241	64	54	37	45	23	39	44	77	98	106	103	82	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.2	21.5	25.8	26.4	27.4	32.0	32.9	32.5	30.2	26.8	24.5	22.9	(19)
(20)			MCWB	11.4	11.7	14.3	16.6	21.4	24.7	25.8	26.0	25.5	21.8	15.6	13.1	(20)
(21)		2%	DB	15.4	14.6	17.2	20.4	25.8	30.0	31.6	31.6	29.0	25.0	20.5	18.1	(21)
(22)			MCWB	10.0	10.2	13.1	16.2	21.6	24.0	25.7	25.9	24.8	22.0	17.3	12.3	(22)
(23)		5%	DB	12.3	11.8	14.3	18.5	24.6	28.9	30.6	30.8	28.0	23.9	19.0	15.2	(23)
(24)			MCWB	10.0	9.8	12.0	15.8	21.0	23.6	25.2	25.7	24.2	21.2	16.8	13.0	(24)
(25)		10%	DB	11.1	10.7	12.7	17.3	23.5	27.9	29.8	30.1	27.1	22.9	17.9	13.7	(25)
(26)			MCWB	9.6	9.3	11.1	15.2	20.5	23.2	24.8	25.5	23.7	20.4	16.1	12.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.6	12.5	15.1	18.4	23.2	26.1	28.2	27.7	26.5	23.6	19.3	15.2	(27)
(28)			MADB	17.9	18.9	23.4	22.3	25.5	29.8	31.1	30.8	29.2	25.5	20.8	17.2	(28)
(29)		2%	WB	11.1	10.7	13.2	17.0	22.3	25.2	27.0	27.1	25.5	22.5	18.0	13.9	(29)
(30)			MADB	13.5	12.8	16.2	19.2	24.7	28.7	30.4	30.1	28.2	24.4	19.6	15.7	(30)
(31)		5%	WB	10.3	10.1	12.1	16.1	21.5	24.6	26.2	26.6	24.7	21.6	17.0	12.9	(31)
(32)			MADB	11.9	11.5	14.2	18.2	23.9	27.9	29.6	29.7	27.4	23.3	18.6	15.0	(32)
(33)		10%	WB	9.8	9.5	11.2	15.3	20.8	23.9	25.5	26.1	24.0	20.7	16.1	12.1	(33)
(34)			MADB	11.0	10.7	12.8	17.2	23.0	27.0	28.9	29.3	26.7	22.5	17.7	13.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.0	3.7	3.7	3.8	4.0	4.6	4.8	4.8	4.7	4.5	4.1	(35)	
(36)			MCDBR	7.1	6.8	8.0	6.6	5.4	6.1	6.0	6.1	5.8	5.8	6.3	6.4	(36)
(37)			MCWBR	4.0	4.0	4.1	3.3	2.9	3.2	3.3	3.7	3.5	3.7	4.1	4.0	(37)
(38)		5% WB	MCDBR	5.1	5.4	7.0	5.5	4.7	5.2	5.2	5.1	5.0	5.1	5.3	5.3	(38)
(39)			MCWBR	3.4	3.4	3.9	3.2	3.0	3.2	3.4	3.4	3.5	3.7	4.0	3.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.396	0.440	0.492	0.577	0.560	0.559	0.602	0.576	0.552	0.505	0.434	0.398	(40)	
(41)		taud	2.187	2.070	1.971	1.822	1.907	1.937	1.860	1.917	1.952	2.026	2.149	2.201	(41)	
(42)		Ebn at Noon	758	769	767	725	748	748	710	718	706	694	707	724	(42)	
(43)		Edh at Noon	110	139	169	207	194	188	201	186	171	144	114	102	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.91	2.44	3.32	4.32	5.68	6.34	6.16	5.50	4.13	2.87	2.05	1.67	(44)	
(45)		RadStd	0.21	0.35	0.39	0.53	0.39	0.39	0.47	0.62	0.34	0.39	0.26	0.20	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		+0.33	N/A	N/A	+1.01	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (8 neighbors)	+0.40	N/A	N/A	+0.98	+0.43	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page