

TEHRAN KHOMEINI INTL, Iran, Islamic Republic of

WMO: 407300

Lat: 35.416N

Lon: 51.152E

Elev: 3305

StdP: 13.02

Time Zone: 3.50 (IRN)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.3	24.7	4.7	7.9	38.5	8.4	9.6	42.0	29.2	45.6	26.0	42.7	10.8	270	0.589

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.4	105.8	63.0	103.7	62.5	100.8	61.8	65.2	94.5	64.4	94.9	63.5	93.2	12.3	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.0	78.3	73.5	55.3	73.6	72.0	53.7	69.2	71.1	31.8	94.5	31.1	93.7	30.5	92.6	68.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 28.6	25.1	22.0	DB	17.5	109.5	6.5	2.0	12.8	111.0	9.0	112.2	5.3	113.3	0.6	114.7	(4)
(5)			WB	14.9	67.0	5.5	0.8	10.9	67.6	7.6	68.1	4.5	68.6	0.5	69.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	64.3	39.4	44.1	54.2	63.2	74.4	83.8	88.2	85.5	78.1	66.3	51.3	42.4		
	DBStd	18.02	8.20	7.00	7.39	6.50	5.05	4.32	3.91	3.63	4.33	6.17	6.99	5.25		
	HDD50	863	332	181	39	4	0	0	0	0	0	1	65	241		
	HDD65	3003	793	586	346	103	2	0	0	0	0	59	413	701		
	CDD50	6096	4	15	168	400	755	1014	1183	1099	843	508	102	5		
	CDD65	2762	0	0	10	49	292	564	718	634	393	101	1	0		
	CDH74	38775	0	0	136	614	3355	8154	11236	9301	4817	1148	14	0		
	CDH80	23153	0	0	31	162	1501	5090	7534	5895	2564	376	0	0		
(14) Wind	WSAvg	10.4	9.0	9.9	11.0	11.1	11.9	12.5	12.8	10.3	9.9	9.4	8.8	8.1		
(15) Precipitation	PrecAvg	11.0	1.5	1.5	1.9	1.5	0.8	0.2	0.2	0.2	0.1	0.7	1.2	1.3		
	PrecMax	16.5	2.8	3.0	4.6	3.9	2.9	0.7	0.8	1.2	0.7	3.9	4.3	2.7		
	PrecMin	6.7	0.5	0.2	0.2	0.1	0.1	0.0	0.0	0.0	0.0	0.1	0.1	0.2		
	PrecStd	2.6	0.7	0.7	0.9	0.9	0.6	0.2	0.2	0.3	0.2	0.8	0.9	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.6	68.1	84.3	91.0	96.7	105.7	109.4	106.1	99.0	91.3	75.6	64.1		
		MCWB	45.3	47.5	53.8	56.4	59.0	62.3	63.7	62.9	60.1	57.5	51.4	45.6		
	2%	DB	58.7	62.6	77.3	84.3	93.3	102.6	107.2	103.8	96.9	87.7	71.8	59.1		
		MCWB	43.4	44.9	50.4	54.9	58.1	61.6	63.4	62.5	59.7	56.4	50.3	44.5		
	5%	DB	55.3	59.2	73.1	80.5	91.2	100.6	104.4	101.8	94.8	84.3	67.9	55.7		
		MCWB	41.8	43.4	49.0	53.6	57.9	61.1	62.8	62.1	59.1	55.2	48.5	43.1		
	10%	DB	51.9	56.8	68.3	77.0	88.1	98.5	102.4	99.0	91.8	80.7	64.3	53.2		
		MCWB	40.3	42.8	47.3	52.5	57.0	60.6	62.4	61.3	58.4	53.9	47.3	41.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.0	49.5	54.4	59.2	62.1	64.9	66.6	66.5	63.7	59.7	55.4	48.5		
		MCDB	55.9	58.3	76.7	79.2	84.2	93.9	94.7	94.9	87.3	77.0	68.3	57.8		
	2%	WB	45.5	47.3	52.2	57.2	60.8	63.5	65.4	65.2	62.1	58.2	52.4	46.5		
		MCDB	54.6	56.7	71.2	72.7	84.9	93.9	95.3	93.6	85.7	77.7	64.5	54.6		
	5%	WB	43.4	45.8	50.8	56.0	59.6	62.6	64.6	64.1	61.1	56.9	50.7	44.9		
		MCDB	52.5	55.8	67.5	72.5	82.7	92.9	96.1	92.6	85.4	76.3	62.7	53.4		
	10%	WB	41.1	43.9	49.0	54.7	58.6	61.8	63.9	63.1	60.2	55.8	49.1	43.3		
		MCDB	50.6	53.8	64.7	71.5	81.1	91.8	95.3	90.4	84.8	74.4	60.7	50.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	19.3	19.4	21.9	22.9	24.5	27.3	27.4	27.0	26.6	23.7	19.9	18.6		
		MCDBR	22.8	23.2	27.4	26.8	26.8	29.3	29.3	29.0	28.8	28.2	24.6	22.4		
		MCWBR	12.2	11.2	10.7	9.0	8.1	7.9	8.0	8.4	10.2	11.4	11.0	11.9		
		MCDBR	19.8	18.8	22.7	22.3	24.9	28.2	28.3	27.7	26.1	23.8	19.6	19.1		
	5% WB	MCWBR	11.1	10.1	10.0	8.2	7.5	7.1	7.2	7.2	8.7	9.3	9.1	10.6		
(40) Clear-Sky Solar Irradiance	taub		0.332	0.366	0.425	0.501	0.500	0.489	0.526	0.475	0.420	0.417	0.372	0.335		
	taud		2.314	2.202	2.017	1.867	1.890	1.927	1.861	1.987	2.114	2.097	2.213	2.332		
	Ebn at Noon		272	274	266	251	253	255	245	255	264	252	252	262		
	Edh at Noon		31	39	52	63	63	60	64	56	46	43	35	29		
(44) All-Sky Solar Radiation	RadAvg		878	1144	1501	1807	2199	2550	2448	2271	1912	1394	955	788		
	RadStd		65	89	121	150	110	89	63	61	57	69	88	83		

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (8 neighbors)	N/A	N/A	N/A	+0.92	-0.79	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page