

TEHRAN KHOMEINI INTL, Iran, Islamic Republic of

WMO: 407300

Lat: 35.416N

Lon: 51.152E

Elev: 1007

StdP: 89.79

Time Zone: 3.50 (IRN)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -7.0	(c) -4.1	(d) -15.2	(e) 1.1	(f) 3.6	(g) -13.1	(h) 1.4	(i) 5.5	(j) 13.1	(k) 7.6	(l) 11.6	(m) 5.9	(n) 4.8	(o) 270	(p) 0.589

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 15.2	(c) 41.0	(d) 17.2	(e) 39.8	(f) 17.0	(g) 38.2	(h) 16.5	(i) 18.5	(j) 34.7	(k) 18.0	(l) 35.0	(m) 17.5	(n) 34.0	(o) 5.5	(p) 110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 13.9	(b) 11.2	(c) 23.1	(d) 13.0	(e) 10.5	(f) 22.2	(g) 12.0	(h) 9.9	(i) 21.7	(j) 56.1	(k) 34.7	(l) 54.5	(m) 34.3	(n) 53.0	(o) 33.7	(p) 20.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 12.8	(b) 11.2	(c) 9.8	(e) -8.1	(f) 43.1	(g) 3.6	(h) 1.1	(i) -10.7	(j) 43.9	(k) -12.8	(l) 44.5	(m) -14.8	(n) 45.2	(o) -17.5	(p) 46.0		
(a) 12.8	(b) 11.2	(c) 9.8	(e) -9.5	(f) 19.5	(g) 3.1	(h) 0.5	(i) -11.7	(j) 19.8	(k) -13.5	(l) 20.1	(m) -15.3	(n) 20.3	(o) -17.5	(p) 20.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.0	4.1	6.7	12.3	17.3	23.5	28.8	31.2	29.7	25.6	19.1	10.7	5.8		
	DBStd	10.01	4.55	3.89	4.11	3.61	2.81	2.40	2.17	2.02	2.41	3.43	3.88	2.92		
	HDD10.0	479	184	101	22	2	0	0	0	0	0	1	36	134		
	HDD18.3	1668	441	326	192	57	1	0	0	0	0	33	229	389		
	CDD10.0	3387	2	8	93	222	419	563	657	611	468	282	57	3		
	CDD18.3	1534	0	0	6	27	162	313	399	352	218	56	1	0		
	CDH23.3	21542	0	0	76	341	1864	4530	6242	5167	2676	638	8	0		
	CDH26.7	12863	0	0	17	90	834	2828	4186	3275	1424	209	0	0		
(14) Wind	WSAvg	4.6	4.0	4.4	4.9	5.0	5.3	5.6	5.7	4.6	4.4	4.2	3.9	3.6		
(15) Precipitation	PrecAvg	280	37	37	47	39	21	4	5	4	3	17	31	34		
	PrecMax	419	72	77	116	98	74	18	21	30	17	99	108	68		
	PrecMin	171	12	6	5	3	2	0	0	0	0	2	3	4		
	PrecStd	65	17	19	23	24	14	4	6	7	4	20	23	17		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.0	20.1	29.1	32.8	35.9	41.0	43.0	41.2	37.2	33.0	24.2	17.8		
		MCWB	7.4	8.6	12.1	13.6	15.0	16.8	17.6	17.2	15.6	14.1	10.8	7.6		
	2%	DB	14.8	17.0	25.1	29.1	34.1	39.2	41.8	39.9	36.1	31.0	22.1	15.1		
		MCWB	6.3	7.1	10.2	12.7	14.5	16.4	17.4	17.0	15.4	13.6	10.2	6.9		
	5%	DB	13.0	15.1	22.8	26.9	32.9	38.1	40.2	38.8	34.9	29.1	19.9	13.2		
		MCWB	5.4	6.4	9.5	12.0	14.4	16.2	17.1	16.7	15.1	12.9	9.2	6.1		
	10%	DB	11.1	13.8	20.2	25.0	31.1	36.9	39.1	37.2	33.2	27.1	17.9	11.8		
		MCWB	4.6	6.0	8.5	11.4	13.9	15.9	16.9	16.3	14.7	12.2	8.5	5.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.9	9.7	12.4	15.1	16.7	18.3	19.2	19.2	17.6	15.4	13.0	9.2		
		MCDB	13.3	14.6	24.9	26.2	29.0	34.4	34.8	35.0	30.7	25.0	20.2	14.3		
	2%	WB	7.5	8.5	11.2	14.0	16.0	17.5	18.6	18.4	16.7	14.5	11.3	8.0		
		MCDB	12.5	13.7	21.8	22.6	29.4	34.4	35.2	34.2	29.9	25.4	18.0	12.6		
	5%	WB	6.3	7.7	10.4	13.3	15.3	17.0	18.1	17.9	16.2	13.9	10.4	7.2		
		MCDB	11.4	13.2	19.7	22.5	28.2	33.9	35.6	33.7	29.7	24.6	17.0	11.9		
	10%	WB	5.1	6.6	9.5	12.6	14.8	16.5	17.7	17.3	15.6	13.2	9.5	6.3		
		MCDB	10.3	12.1	18.2	22.0	27.3	33.2	35.2	32.5	29.3	23.6	15.9	10.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.7	10.8	12.1	12.7	13.6	15.1	15.2	15.0	14.8	13.2	11.0	10.3		
		MCDBR	12.7	12.9	15.2	14.9	14.9	16.3	16.3	16.1	16.0	15.7	13.7	12.4		
	5% WB	MCWBR	6.8	6.2	5.9	5.0	4.5	4.4	4.5	4.7	5.7	6.4	6.1	6.6		
		MCWBR	11.0	10.5	12.6	12.4	13.8	15.7	15.7	15.4	14.5	13.2	10.9	10.6		
(40) Clear-Sky Solar Irradiance	taub		0.332	0.366	0.425	0.501	0.500	0.489	0.526	0.475	0.420	0.417	0.372	0.335		
	taud		2.314	2.202	2.017	1.867	1.890	1.927	1.861	1.987	2.114	2.097	2.213	2.332		
	Ebn at Noon		857	863	837	792	799	805	772	805	832	793	796	827		
	Edh at Noon		99	124	163	200	198	190	202	175	146	136	109	92		
(44) All-Sky Solar Radiation	RadAvg		2.77	3.61	4.73	5.70	6.93	8.04	7.72	7.16	6.03	4.40	3.01	2.48		
	RadStd		0.21	0.28	0.38	0.47	0.35	0.28	0.20	0.19	0.18	0.22	0.28	0.26		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	N/A	N/A	N/A	+0.51	-0.44	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page