

RAMSAR, Iran, Islamic Republic of

WMO: 407320

Lat: 36.9046N

Lon: 50.6840E

Elev: -66

StdP: 14.73

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	34.3	37.1	29.1	23.0	38.5	31.8	26.1	39.8	27.8	45.8	21.7	48.4	2.3	240	0.354

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.3	88.8	78.2	87.5	77.8	86.0	77.0	80.3	86.6	79.1	85.4	78.0	84.3	8.9	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.6	148.1	85.7	77.1	140.7	84.4	75.6	133.8	83.1	44.0	86.6	42.7	85.5	41.5	84.6	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.5	16.1	12.9	DB	31.3	92.4	2.3	3.9	29.6	95.2	28.3	97.5	27.0	99.6	25.3	102.4	(4)
(5)			WB	29.7	81.8	2.3	1.6	28.0	82.9	26.7	83.8	25.4	84.7	23.7	85.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.3	46.8	46.3	50.1	56.1	66.2	74.6	78.9	79.8	74.3	66.4	56.9	50.3		
	DBStd	12.89	4.40	4.53	4.87	4.98	4.74	4.03	3.31	3.21	4.06	4.66	5.13	4.49		
	HDD50	352	115	117	54	8	0	0	0	0	0	0	8	50		
	HDD65	2608	563	524	464	271	43	1	0	0	1	40	246	455		
	CDD50	4848	17	13	57	189	501	738	895	924	730	509	215	60		
	CDD65	1630	0	0	2	3	79	289	430	459	281	83	4	0		
	CDH74	12633	1	0	17	18	196	1896	4028	4601	1680	186	9	1		
	CDH80	3308	0	0	6	5	12	366	1158	1473	271	16	1	0		
(14) Wind	WSAvg	4.3	4.0	4.2	4.9	4.6	4.4	4.6	4.8	4.4	4.2	3.9	3.9	3.8		
(15) Precipitation	PrecAvg	47.5	3.2	3.7	3.7	2.7	1.9	2.2	2.4	1.9	6.0	9.3	6.3	4.2		
	PrecMax	66.8	7.1	7.1	5.8	6.4	5.0	9.6	5.6	5.5	14.1	27.4	13.7	9.4		
	PrecMin	28.8	1.7	0.4	0.0	0.1	0.7	0.0	0.3	0.0	0.4	0.0	0.8	0.7		
	PrecStd	11.1	1.3	1.9	1.4	1.8	1.1	2.0	1.7	1.5	3.8	7.0	3.3	2.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.4	66.4	73.6	75.4	81.4	88.0	90.7	91.1	86.5	82.1	75.0	67.9		
		MCWB	53.3	52.5	56.4	62.2	70.7	76.9	79.4	79.1	77.8	72.0	63.8	57.5		
	2%	DB	57.9	58.7	64.3	69.4	78.5	85.8	88.7	89.3	84.6	78.0	69.6	62.5		
		MCWB	52.0	50.5	54.8	61.7	70.3	75.4	77.8	78.6	76.4	71.0	63.7	55.9		
	5%	DB	55.3	54.2	59.3	66.2	75.7	83.9	87.4	87.8	82.8	75.6	66.6	59.3		
		MCWB	50.8	49.7	54.1	60.4	69.4	74.3	77.3	78.4	75.5	69.6	61.4	54.5		
	10%	DB	53.4	52.1	55.8	63.3	73.7	82.1	85.7	86.3	81.0	73.7	64.6	57.3		
		MCWB	49.6	48.7	52.2	59.1	68.1	73.7	76.5	77.7	74.2	68.2	60.1	53.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.8	54.0	59.4	65.1	73.8	79.2	82.1	82.1	79.6	74.5	66.5	59.2		
		MCDB	60.1	61.4	70.1	70.5	78.7	85.4	88.8	88.3	85.2	79.4	71.1	64.4		
	2%	WB	52.9	51.8	56.4	62.8	71.8	77.2	80.0	80.6	77.9	72.1	64.1	56.8		
		MCDB	57.2	56.7	62.0	67.9	76.4	83.9	86.2	87.0	83.4	76.6	68.4	61.0		
	5%	WB	51.3	50.4	54.3	60.9	70.1	75.7	78.6	79.7	76.4	70.5	62.4	55.2		
		MCDB	54.6	53.5	58.9	65.0	74.5	82.0	84.8	86.0	81.9	74.7	65.6	58.8		
	10%	WB	50.1	49.4	52.6	59.3	68.7	74.5	77.3	78.6	75.0	69.0	60.6	53.7		
		MCDB	52.7	51.8	56.2	62.9	73.0	80.4	83.7	85.0	80.3	73.2	64.0	57.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.5	9.7	9.0	9.0	9.7	10.2	10.2	10.3	9.5	10.4	10.9	11.0		
		MCDBR	14.6	14.8	17.4	14.9	12.6	12.4	12.4	12.2	11.3	12.6	13.7	14.4		
	5% WB	MCWBR	10.6	9.7	9.9	8.6	8.3	7.4	7.5	8.3	7.4	8.7	9.8	10.4		
		MCWBR	12.7	12.2	15.0	12.8	11.7	11.4	11.0	11.3	10.9	11.9	11.9	13.1		
(40) Clear-Sky Solar Irradiance	taub		0.399	0.450	0.511	0.596	0.588	0.592	0.644	0.611	0.572	0.526	0.446	0.402		
	taud		2.140	2.016	1.905	1.777	1.837	1.860	1.779	1.846	1.903	1.970	2.091	2.147		
	Ebn at Noon		239	241	238	226	231	229	216	220	219	215	220	228		
	Edh at Noon		37	47	57	69	66	64	69	64	57	49	39	35		
(44) All-Sky Solar Radiation	RadAvg		677	861	1158	1505	1945	2211	2107	1948	1563	1104	736	591		
	RadStd		65	106	123	189	116	116	122	155	84	102	95	80		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.59	N/A	N/A	+1.55	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)		+0.54	N/A	N/A	+1.26	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page