

NOSHAHR, Iran, Islamic Republic of

WMO: 407340

Lat: 36.6614N

Lon: 51.4663E

Elev: -69

StdP: 14.73

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	33.6	36.0	27.0	20.9	39.6	30.2	24.2	39.5	23.3	46.5	19.3	45.4	3.6	180	0.360

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.8	89.2	79.1	87.8	78.7	86.2	77.5	80.6	87.2	79.6	86.0	78.5	84.8	7.6	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.8	149.3	86.2	77.3	141.7	84.7	76.6	138.4	84.0	44.5	87.1	43.2	86.3	42.0	85.2	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.5	14.9	12.4	31.6	90.9	3.1	1.8	29.4	92.1	27.6	93.2	25.9	94.1	23.6	95.4		
(5)			29.6	82.6	2.7	2.1	27.7	84.2	26.1	85.4	24.6	86.6	22.6	88.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.4	46.9	46.4	50.8	56.7	67.2	75.4	78.8	79.2	74.2	66.0	56.2	50.2		
	DBStd	12.81	4.39	4.38	5.13	5.27	4.54	3.48	3.28	3.35	3.74	4.62	5.35	4.10		
	HDD50	335	113	113	43	6	0	0	0	0	0	0	12	48		
	HDD65	2576	562	522	442	255	28	0	0	0	0	41	266	460		
	CDD50	4870	16	11	68	208	534	762	892	905	726	497	198	53		
	CDD65	1639	0	0	3	6	98	312	427	440	277	74	2	0		
	CDH74	12887	0	0	28	33	298	2248	4017	4329	1715	213	6	0		
	CDH80	3571	0	0	9	7	23	442	1229	1525	310	26	0	0		
(14) Wind	WSAvg	4.8	4.6	5.2	5.7	5.4	5.2	4.9	4.9	4.7	4.4	4.4	4.4	4.2		
(15) Precipitation	PrecAvg	43.9	3.3	3.1	3.2	2.3	1.7	1.7	2.0	1.8	5.4	7.9	6.5	4.4		
	PrecMax	60.2	6.4	6.1	5.8	4.9	3.8	6.6	8.1	6.8	11.7	19.3	12.8	11.5		
	PrecMin	25.3	1.0	0.9	0.4	0.2	0.7	0.1	0.3	0.0	0.7	0.8	0.0	0.2		
	PrecStd	7.4	1.3	1.3	1.4	1.3	0.7	1.4	1.9	1.5	2.9	4.3	3.0	2.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.1	64.4	76.9	79.0	82.6	87.5	90.0	91.2	87.8	83.2	73.7	68.1		
		MCWB	53.6	51.8	58.6	62.6	71.1	77.5	79.8	79.7	79.0	71.2	64.8	58.0		
	2%	DB	59.0	57.7	66.6	71.3	79.2	85.9	89.0	89.5	85.2	78.6	69.8	62.9		
		MCWB	52.3	50.4	55.6	62.4	70.4	76.2	79.2	79.2	77.2	71.7	64.1	56.1		
	5%	DB	55.7	54.7	61.1	67.5	77.2	84.3	87.6	88.0	83.7	75.7	66.6	59.4		
		MCWB	50.6	49.4	54.6	60.8	69.9	75.1	78.3	79.0	76.0	69.4	61.1	54.6		
	10%	DB	53.8	52.7	57.2	64.3	75.1	82.6	85.9	87.2	81.6	73.8	64.7	57.4		
		MCWB	49.5	48.9	52.7	59.4	68.8	74.3	77.3	78.5	74.4	68.0	59.8	53.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.1	54.0	60.0	65.5	74.3	79.2	82.2	82.4	80.1	74.6	67.2	60.0		
		MCDB	60.4	59.3	72.3	74.6	79.6	85.1	88.6	88.1	86.2	79.5	71.7	65.0		
	2%	WB	53.0	51.9	56.9	63.1	72.4	77.9	80.4	80.9	78.2	72.4	64.5	57.2		
		MCDB	57.4	55.5	65.1	69.6	77.5	84.0	86.8	87.5	84.0	76.8	68.4	61.4		
	5%	WB	51.6	50.6	54.7	61.2	70.8	76.6	79.3	79.9	76.5	70.7	62.9	55.5		
		MCDB	55.0	53.3	60.1	65.8	75.6	82.6	85.5	86.6	82.1	74.8	66.4	59.1		
	10%	WB	50.5	49.6	53.0	59.8	69.3	75.3	78.2	79.0	75.2	69.1	60.6	53.9		
		MCDB	53.3	51.9	57.0	63.6	73.9	81.4	84.3	85.6	80.3	73.2	64.0	57.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.1	9.9	10.0	9.7	10.2	10.8	10.6	11.8	11.0	12.2	12.5	12.4		
		MCDBR	15.8	14.8	19.5	15.9	13.7	12.5	12.6	13.9	13.2	14.6	15.1	16.2		
		MCWBR	11.9	10.3	10.4	9.5	9.1	8.3	8.5	9.9	9.4	10.2	11.0	12.5		
		MCDBR	14.3	11.2	16.5	13.6	12.6	11.9	11.9	13.3	12.3	13.8	13.5	14.5		
	5% WB	MCWBR	11.1	8.4	9.9	8.6	9.0	8.4	8.4	10.0	9.2	10.2	10.4	11.8		
(40) Clear-Sky Solar Irradiance	taub		0.399	0.449	0.512	0.596	0.598	0.607	0.660	0.625	0.583	0.534	0.454	0.404		
	taud		2.130	2.011	1.899	1.775	1.817	1.833	1.754	1.820	1.883	1.953	2.073	2.137		
	Ebn at Noon		240	242	238	226	228	226	213	217	217	213	219	228		
	Edh at Noon		37	47	58	69	67	66	71	65	58	50	39	35		
(44) All-Sky Solar Radiation	RadAvg		695	875	1186	1524	1883	2098	1994	1866	1493	1096	749	607		
	RadStd		61	100	120	184	101	127	141	184	87	94	82	80		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	+0.83	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page