

QAEMSHAHR, Iran, Islamic Republic of

WMO: 407370

Lat: 36.450N

Lon: 52.817E

Elev: 14

StdP: 101.16

Time Zone: 3.50 (IRN)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.7	0.7	-2.3	3.1	1.4	-0.9	3.5	2.6	8.6	7.9	7.8	9.0	0.9	180	0.356

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.8	34.3	25.8	33.1	25.3	32.0	24.9	27.2	32.2	26.5	31.2	25.8	30.3	3.4	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.9	21.3	30.4	25.2	20.3	29.6	24.5	19.5	28.7	86.5	32.2	83.1	31.2	79.9	30.5	30.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.2	6.0	5.2	-2.6	37.1	1.0	1.3	-3.3	38.1	-3.8	38.8	-4.4	39.6	-5.1	40.6		
			-3.2	28.4	1.4	0.9	-4.1	29.0	-5.0	29.6	-5.7	30.1	-6.7	30.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	17.5	7.7	8.2	11.5	15.5	21.1	24.9	26.6	27.4	24.3	19.2	13.2	9.4	(6)
(7)		DBStd	7.60	2.80	2.68	3.29	3.35	2.80	1.98	2.03	1.94	2.32	2.87	3.36	2.67	(7)
(8)		HDD10.0	214	81	60	18	2	0	0	0	0	0	0	9	44	(8)
(9)		HDD18.3	1391	330	282	216	97	7	0	0	0	0	24	156	278	(9)
(10)		CDD10.0	2939	9	11	63	166	344	447	514	541	429	284	106	25	(10)
(11)		CDD18.3	1074	0	0	3	12	93	197	256	282	179	49	3	0	(11)
(12)		CDH23.3	9347	0	1	32	124	580	1605	2422	2989	1321	254	18	1	(12)
(13)	CDH26.7	3463	0	0	9	42	158	526	932	1342	402	48	3	0	(13)	
(14)	Wind	WSAvg	2.2	2.1	2.2	2.5	2.4	2.4	2.3	2.2	2.1	1.9	1.8	2.0	(14)	
(15)	Precipitation	PrecAvg	844	66	66	78	50	39	44	51	49	108	105	119	70	(15)
(16)		PrecMax	1607	144	137	164	113	74	136	128	133	356	252	210	122	(16)
(17)		PrecMin	637	13	18	25	1	12	12	13	2	20	41	24	20	(17)
(18)		PrecStd	193	30	31	30	27	15	29	30	30	64	53	42	28	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.2	21.2	27.4	32.1	33.0	33.2	35.8	35.8	33.9	30.7	25.7	21.7	(19)
(20)		0.4%	MCWB	12.9	13.3	18.6	21.0	23.4	24.6	26.3	25.7	24.8	21.7	18.2	15.0	(20)
(21)		2%	DB	16.7	17.4	22.9	26.4	30.1	31.9	33.8	34.5	31.9	27.7	22.2	18.1	(21)
(22)		2%	MCWB	11.7	11.8	15.4	18.9	22.3	24.3	26.1	26.0	24.7	21.2	17.1	13.0	(22)
(23)		5%	DB	14.2	14.7	20.0	23.6	28.4	30.8	32.4	33.5	30.3	26.0	20.3	15.8	(23)
(24)		5%	MCWB	10.3	10.8	14.7	17.9	21.6	23.9	25.4	25.8	24.2	20.6	16.1	12.3	(24)
(25)		10%	DB	12.4	12.7	17.0	21.3	26.6	29.7	31.1	32.5	29.0	24.5	18.8	14.2	(25)
(26)		10%	MCWB	9.5	9.8	13.1	16.9	20.8	23.5	24.9	25.3	23.4	19.9	15.6	11.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.9	14.3	19.1	21.5	24.6	26.9	28.5	28.2	27.0	23.3	19.6	15.5	(27)
(28)		0.4%	MCDWB	18.9	19.8	26.5	28.6	30.6	31.4	33.6	33.4	31.7	27.9	23.5	19.7	(28)
(29)		2%	WB	12.1	12.5	16.6	19.7	23.4	25.7	27.2	27.4	25.8	22.2	18.1	14.0	(29)
(30)		2%	MCDWB	15.7	16.2	21.7	25.5	28.7	30.2	32.0	32.5	30.1	26.2	20.9	16.7	(30)
(31)		5%	WB	10.8	11.1	14.7	18.1	22.2	24.8	26.2	26.7	25.0	21.3	17.1	13.0	(31)
(32)		5%	MCDWB	13.3	13.8	19.1	23.0	26.9	29.1	30.6	31.6	28.7	25.0	19.4	15.4	(32)
(33)		10%	WB	9.9	10.2	13.2	17.0	21.3	24.0	25.5	26.1	24.2	20.5	15.9	11.9	(33)
(34)		10%	MCDWB	11.9	12.2	16.8	20.6	25.7	28.3	29.6	30.8	27.8	23.6	18.2	13.8	(34)
(35)	Mean Daily Temperature Range	MDBR	9.3	8.2	8.3	8.6	8.3	8.0	7.5	8.8	8.0	8.8	8.9	9.0	(35)	
(36)		5% DB	MCDBR	13.0	13.3	14.5	14.0	11.9	10.0	9.9	11.0	10.0	11.4	11.8	12.3	(36)
(37)		5% DB	MCWBR	8.5	8.4	8.5	7.5	5.8	4.5	4.3	4.9	4.5	5.8	7.0	8.3	(37)
(38)		5% WB	MCDBR	11.1	11.3	13.6	12.2	10.6	9.0	9.1	9.7	9.0	9.5	9.4	10.6	(38)
(39)		5% WB	MCWBR	7.8	7.7	8.5	7.1	5.6	4.9	4.5	5.1	4.7	5.2	6.1	7.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.385	0.429	0.489	0.562	0.573	0.577	0.623	0.583	0.552	0.511	0.438	0.390	(40)	
(41)		taud	2.212	2.089	1.956	1.833	1.854	1.876	1.799	1.879	1.927	1.986	2.117	2.206	(41)	
(42)		Ebn at Noon	781	787	774	740	739	735	697	715	709	693	710	744	(42)	
(43)		Edh at Noon	109	138	173	206	205	200	215	194	176	152	119	103	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.36	2.93	3.82	4.77	5.77	6.40	6.10	5.79	4.67	3.58	2.55	2.08	(44)	
(45)		RadStd	0.20	0.33	0.34	0.55	0.33	0.44	0.51	0.65	0.29	0.25	0.22	0.21	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (9 neighbors)	+0.25	N/A	-0.82	+0.61	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page