

MEHRABAD INTL, Iran, Islamic Republic ofWMO: **407540**Lat: **35.689N**Lon: **51.313E**Elev: **1208**StdP: **87.63**Time Zone: **3.50 (IRN)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.2	-1.2	-13.9	1.3	8.9	-11.9	1.6	8.8	12.1	8.0	10.5	8.2	2.5	280	0.467

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	39.0	17.6	37.9	17.4	36.8	17.3	21.7	32.7	20.2	33.3	19.3	32.7	3.9	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.9	15.0	30.3	15.3	12.6	28.2	14.0	11.5	28.0	69.7	32.4	64.0	33.3	60.4	32.9	26.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.8	9.4	7.7	-5.3	40.6	2.6	1.1	-7.2	41.4	-8.7	42.0	-10.1	42.7	-12.0	43.4		
(5)			-6.7	20.9	1.9	2.2	-8.0	22.4	-9.1	23.7	-10.2	24.9	-11.5	26.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.4	5.2	7.3	12.1	17.5	23.2	28.6	31.1	30.4	26.2	19.9	11.8	6.9
	DBStd	9.77	3.57	3.82	4.30	3.93	3.24	2.81	2.45	2.15	2.78	3.49	3.89	3.09
	HDD10.0	400	153	88	27	3	0	0	0	0	0	0	25	105
	HDD18.3	1554	408	309	197	58	3	0	0	0	0	25	197	355
	CDD10.0	3471	3	12	93	229	409	557	653	633	487	307	79	8
	CDD18.3	1582	0	0	5	34	155	307	395	374	237	73	1	0
	CDH23.3	21025	0	0	25	223	1482	4333	6145	5594	2723	497	2	0
	CDH26.7	11539	0	0	2	43	516	2428	3883	3336	1221	109	0	0
Wind	WSAvg	2.9	2.3	2.9	3.5	3.5	3.8	3.4	3.1	2.7	2.6	2.5	2.2	2.0
Precipitation	PrecAvg	215	32	27	35	32	15	2	2	2	2	10	22	34
	PrecMax	389	117	108	142	131	50	13	15	22	22	49	78	78
	PrecMin	98	2	0	5	2	0	0	0	0	0	0	0	4
	PrecStd	83	25	21	33	27	12	4	3	4	5	12	19	20
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.8	18.2	26.1	30.2	34.1	38.9	40.9	39.7	35.9	31.0	23.1	17.2
		MCWB	7.1	7.7	10.8	13.5	15.1	17.2	18.0	18.0	16.8	14.1	10.4	8.6
	2%	DB	13.8	16.0	23.0	27.9	32.2	37.2	39.6	38.1	34.4	29.2	21.1	14.9
		MCWB	6.1	6.9	10.4	13.5	14.7	16.9	17.8	17.7	16.1	13.4	10.2	7.2
	5%	DB	12.0	14.6	20.9	25.9	31.0	36.1	38.2	37.1	33.2	27.9	19.2	13.1
		MCWB	5.3	6.4	9.5	12.9	14.4	16.4	17.5	17.7	15.8	13.1	9.6	6.6
	10%	DB	10.4	13.1	18.9	24.0	29.8	35.0	37.1	36.0	32.1	26.1	17.8	11.8
		MCWB	4.7	5.7	8.5	12.1	14.0	15.9	17.4	17.3	15.5	12.7	9.1	5.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.7	9.5	14.6	18.0	19.4	21.3	23.3	24.5	22.4	17.1	13.1	9.5
		MCDB	12.4	15.1	20.3	24.6	29.6	34.4	34.7	33.5	31.4	25.5	18.4	15.3
	2%	WB	7.4	8.2	11.8	15.4	16.8	19.5	21.4	22.1	20.1	15.5	11.7	8.2
		MCDB	11.5	13.6	19.1	23.4	28.3	32.1	34.2	31.4	30.1	24.7	17.2	13.0
	5%	WB	6.3	7.3	10.6	14.0	15.7	18.2	20.2	19.7	18.2	14.6	10.7	7.5
		MCDB	10.4	13.0	18.5	22.7	27.6	31.7	34.1	33.8	29.5	24.3	17.0	11.6
	10%	WB	5.3	6.4	9.5	13.0	14.9	17.3	19.3	18.9	16.7	13.7	9.7	6.7
		MCDB	9.6	12.0	17.1	22.2	26.8	31.5	33.4	33.1	29.0	23.5	16.3	10.3
Mean Daily Temperature Range	5% DB	MDBR	7.0	7.9	8.8	9.3	10.1	11.1	11.0	10.4	10.1	9.2	7.6	6.8
		MCDBR	8.3	9.0	10.0	10.2	10.9	11.4	11.5	10.9	10.6	10.4	8.9	8.5
		MCWBR	4.3	4.5	4.4	4.1	3.8	3.4	3.1	3.3	3.9	3.8	3.6	4.4
	5% WB	MCDWR	7.1	7.8	8.7	9.4	10.3	11.6	11.1	10.5	10.4	9.4	7.6	7.1
	MCWBR	4.3	4.6	4.6	4.5	4.3	4.6	4.3	4.2	5.0	4.6	3.5	4.1	
Clear-Sky Solar Irradiance	taub	0.314	0.348	0.406	0.474	0.476	0.467	0.504	0.459	0.404	0.400	0.355	0.318	
	taud	2.337	2.229	2.067	1.935	1.958	2.003	1.931	2.053	2.190	2.169	2.281	2.369	
	Ebn at Noon	877	882	856	815	818	823	788	818	849	811	817	848	
	Edh at Noon	96	120	155	186	185	176	188	163	135	126	101	88	
All-Sky Solar Radiation	RadAvg	2.65	3.42	4.52	5.52	6.75	7.76	7.43	6.91	5.78	4.22	2.88	2.36	
	RadStd	0.19	0.30	0.39	0.51	0.34	0.32	0.25	0.27	0.20	0.23	0.28	0.26	