

BANDAR MAHSHAHR, Iran, Islamic Republic of

WMO: 407801

Lat: 30.556N

Lon: 49.152E

Elev: 8

StdP: 14.69

Time Zone: 3.50 (IRN)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 39.1	(c) 41.4	(d) 23.3	(e) 17.6	(f) 69.4	(g) 28.0	(h) 22.0	(i) 64.3	(j) 26.6	(k) 62.2	(l) 23.0	(m) 61.0	(n) 5.2	(o) 300	(p) 0.508

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 27.2	(c) 118.2	(d) 75.3	(e) 116.2	(f) 75.5	(g) 113.4	(h) 74.6	(i) 89.2	(j) 99.6	(k) 87.3	(l) 97.1	(m) 85.8	(n) 95.9	(o) 16.6	(p) 300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
87.4	199.4	96.1	85.6	187.7	95.1	82.8	171.3	93.7	54.4	99.7	52.1	96.3	50.1	95.2	96.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 26.0	(b) 22.5	(c) 19.7	(e) 35.2	(f) 122.0	(g) 3.3	(h) 1.2	(i) 32.9	(j) 122.9	(k) 31.0	(l) 123.6	(m) 29.1	(n) 124.2	(o) 26.8	(p) 125.1		
(a) 26.0	(b) 22.5	(c) 19.7	(e) 32.6	(f) 91.7	(g) 3.8	(h) 2.2	(i) 29.9	(j) 93.3	(k) 27.6	(l) 94.6	(m) 25.5	(n) 95.9	(o) 22.7	(p) 97.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	79.5	56.2	60.5	69.3	78.8	90.3	97.3	99.6	98.7	92.3	82.7	68.0	59.0		
	DBStd	16.43	6.04	6.13	5.67	5.77	4.70	3.49	2.98	2.70	3.93	5.60	6.27	5.18		
	HDD50	23	17	4	0	0	0	0	0	0	0	0	0	2		
	HDD65	683	277	145	24	1	0	0	0	0	0	0	41	195		
	CDD50	10786	208	300	599	865	1250	1418	1536	1508	1269	1013	539	281		
	CDD65	5969	3	20	158	416	785	968	1071	1043	819	548	129	9		
	CDH74	94121	5	97	1381	4767	12385	17110	19134	18109	12978	6955	1154	46		
	CDH80	65509	0	2	434	2322	8266	12832	14671	13651	8988	3987	356	0		
(14) Wind	WSAvg	8.3	7.5	7.9	8.5	8.4	9.7	11.3	10.6	8.9	7.8	6.8	5.8	6.6		
(15) Precipitation	PrecAvg	8.2	2.1	1.1	1.0	0.5	0.1	0.0	0.0	0.0	0.0	0.3	1.1	1.9		
	PrecMax	13.1	5.4	3.5	3.5	2.1	0.4	0.0	0.0	0.0	0.1	3.3	8.0	4.8		
	PrecMin	3.4	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	2.8	1.3	1.0	0.9	0.6	0.1	0.0	0.0	0.0	0.0	0.7	1.9	1.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.8	79.2	93.3	100.7	113.3	119.9	121.6	119.9	114.8	107.3	91.2	77.4		
		MCWB	59.7	59.6	64.0	68.4	74.2	74.7	76.1	77.8	75.1	69.3	65.6	61.1		
	2%	DB	71.5	77.0	88.1	98.4	109.6	116.9	118.4	116.7	111.3	102.6	87.8	75.2		
		MCWB	59.5	58.8	62.7	67.4	72.0	74.5	75.9	76.0	73.8	70.1	67.2	61.6		
	5%	DB	69.5	74.9	84.4	94.8	107.0	114.8	116.3	114.7	109.2	100.2	84.2	71.9		
		MCWB	58.3	58.6	61.3	66.2	70.7	74.0	76.1	75.0	73.0	70.4	66.1	60.0		
	10%	DB	66.6	71.7	80.9	91.2	103.9	112.6	113.3	112.7	106.1	96.8	80.7	69.6		
		MCWB	57.1	57.6	59.9	65.7	70.5	72.7	75.3	75.4	73.2	70.3	65.1	59.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	65.0	65.7	68.3	73.6	81.0	85.5	92.2	90.8	90.8	82.6	77.1	68.1		
		MCDB	69.8	72.9	79.6	87.2	100.2	99.4	109.6	102.4	103.1	90.6	84.5	73.5		
	2%	WB	63.1	63.7	66.8	71.5	77.4	83.4	88.4	89.4	87.4	80.6	73.3	65.2		
		MCDB	68.1	70.2	78.2	86.5	96.0	98.6	100.5	99.2	95.2	89.3	80.4	70.6		
	5%	WB	61.1	61.6	65.3	69.9	75.6	81.3	86.3	88.1	85.5	79.0	69.8	62.9		
		MCDB	66.5	69.3	77.2	86.7	94.0	97.7	97.2	97.9	94.4	88.1	79.2	68.3		
	10%	WB	59.2	59.9	63.7	68.8	74.0	79.0	84.3	86.5	83.6	76.8	67.1	60.8		
		MCDB	64.7	68.3	76.2	85.2	94.3	99.8	96.8	96.2	93.6	86.5	76.3	67.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	17.8	18.9	21.3	21.9	24.3	29.1	27.2	26.8	28.5	26.2	21.8	19.0		
		MCDBR	18.9	20.9	25.6	25.1	28.9	32.3	31.7	31.8	32.0	29.9	26.3	22.4		
		MCWBR	11.4	9.7	9.9	9.2	11.5	11.9	12.0	12.5	13.8	13.2	13.7	12.7		
		MCDBR	14.3	15.9	19.2	20.4	23.8	26.0	23.0	21.5	21.9	21.3	19.7	15.6		
	5% WB	MCWBR	11.0	9.4	9.6	9.0	11.7	12.6	11.8	11.6	13.0	12.9	13.3	11.3		
(40) Clear-Sky Solar Irradiance	taub		0.473	0.513	0.571	0.665	0.655	0.605	0.666	0.619	0.542	0.546	0.503	0.468		
	taud		1.918	1.829	1.691	1.558	1.573	1.636	1.555	1.642	1.775	1.777	1.871	1.944		
	Ebn at Noon		229	233	229	214	218	228	214	222	234	220	217	222		
	Edh at Noon		51	61	74	88	87	82	88	80	67	63	53	47		
(44) All-Sky Solar Radiation	RadAvg		1042	1353	1733	1931	2303	2574	2449	2307	2029	1579	1152	971		
	RadStd		70	87	75	110	95	53	53	49	47	56	86	92		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)	+0.52	N/A	N/A	+0.79	N/A	N/A	N/A	N/A	+153	+149

Nomenclature: See separate page