

QESHM INTL, Iran, Islamic Republic of

WMO: 407808

Lat: 26.751N

Lon: 55.898E

Elev: 13

StdP: 101.17

Time Zone: 3.50 (IRN)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.1	12.2	-2.1	3.2	19.9	0.2	3.8	18.2	12.3	21.3	11.0	22.2	1.5	330	0.486

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.1	41.8	25.2	40.0	27.1	38.9	27.8	31.9	35.6	31.3	35.2	30.9	34.9	5.3	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
31.1	29.1	34.3	30.2	27.6	33.8	30.0	27.3	33.6	109.2	36.3	106.7	34.7	104.0	35.2	34.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.9	10.4	9.6	8.5	45.2	1.6	1.2	7.3	46.1	6.3	46.8	5.4	47.5	4.2	48.4		
			5.0	32.8	1.4	1.0	3.9	33.6	3.1	34.2	2.3	34.7	1.3	35.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.1	18.3	19.4	22.7	26.4	29.8	32.8	34.8	34.4	32.5	29.3	24.0	20.2	
	DBStd	6.07	2.07	2.37	2.02	2.15	1.57	1.77	1.23	1.25	1.33	1.55	2.17	1.85	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD18.3	46	27	14	1	0	0	0	0	0	0	0	0	4	
	CDD10.0	6243	256	263	393	492	615	685	770	757	677	599	420	316	
	CDD18.3	3247	24	44	135	242	357	435	512	498	427	341	170	62	
	CDH23.3	43829	94	195	828	2358	4782	6660	8228	7893	6464	4473	1487	366	
CDH26.7	25853	1	24	184	852	2450	4273	5748	5413	4077	2316	479	35		
Wind	WSAvg	4.4	3.4	4.3	5.0	5.2	5.5	5.1	4.7	4.9	4.4	3.8	3.3	3.1	
Precipitation	PrecAvg	146	54	32	28	3	0	0	1	1	1	2	5	22	
	PrecMax	315	194	168	112	14	2	3	19	4	9	18	23	70	
	PrecMin	38	2	0	0	0	0	0	0	0	0	0	0	0	
	PrecStd	78	46	40	35	4	0	1	4	1	2	4	7	26	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.2	29.2	32.2	36.9	38.9	44.2	43.9	43.0	40.2	37.2	33.1	29.1	
		MCWB	18.8	20.2	20.9	22.2	23.3	21.8	22.2	23.6	23.9	22.1	20.4	18.5	
	2%	DB	25.2	27.0	30.2	34.1	37.0	40.9	41.2	41.1	38.9	35.9	31.9	27.2	
		MCWB	19.4	20.3	21.0	23.1	24.4	25.2	27.3	26.0	26.1	24.7	22.0	19.1	
	5%	DB	24.2	25.2	28.8	32.8	35.2	38.9	39.9	39.2	37.2	34.8	30.8	26.2	
		MCWB	18.7	19.9	21.3	23.1	25.3	27.0	28.5	28.1	27.4	26.1	23.0	18.9	
	10%	DB	23.2	24.2	27.1	31.0	34.1	37.1	38.7	38.0	36.1	33.8	29.2	25.2	
		MCWB	17.9	19.2	21.4	23.7	25.8	27.9	29.0	29.2	28.2	26.7	21.9	18.6	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.1	23.1	25.2	27.4	30.2	31.9	32.5	32.9	32.0	30.7	26.5	24.2
			MCDB	24.8	26.2	28.1	30.6	33.4	35.3	36.2	36.2	35.1	33.4	30.3	26.7
2%		WB	21.1	21.9	23.7	26.2	29.1	30.9	31.8	31.9	31.1	29.8	25.5	22.4	
		MCDB	24.1	25.3	26.9	30.1	32.4	35.2	35.7	35.7	34.6	33.0	29.7	25.3	
5%		WB	20.2	21.0	23.0	25.3	28.3	30.3	31.2	31.3	30.6	29.2	24.6	21.3	
		MCDB	23.3	24.1	26.2	29.3	31.6	34.6	35.5	35.1	34.1	32.3	29.1	24.6	
10%		WB	19.3	20.3	22.2	24.6	27.6	29.8	30.8	30.7	30.1	28.5	23.7	20.2	
		MCDB	22.7	23.4	25.6	28.6	31.1	33.9	35.2	34.7	33.6	31.9	28.1	24.0	
Mean Daily Temperature Range		5% DB	MDBR	9.9	9.2	8.6	8.4	8.6	8.9	8.1	7.9	8.2	9.2	10.4	10.6
			MCDBR	10.6	10.4	11.4	11.9	11.3	12.3	10.4	10.3	10.1	10.6	11.2	11.6
	MCWBR		7.0	6.3	6.1	5.2	5.2	5.6	5.0	5.3	5.1	6.3	6.5	7.0	
	5% WB	MCDBR	9.3	9.1	9.2	9.1	8.6	9.1	8.1	8.2	8.0	7.9	9.7	9.6	
		MCWBR	7.2	6.2	6.0	5.1	4.9	4.9	4.1	4.5	4.5	5.2	6.7	7.3	
Clear-Sky Solar Irradiance	taub	0.431	0.498	0.554	0.585	0.587	0.639	0.721	0.680	0.600	0.517	0.444	0.422		
	taud	2.139	1.956	1.819	1.779	1.781	1.715	1.609	1.684	1.799	1.948	2.129	2.169		
	Ebn at Noon	799	771	752	743	740	698	642	665	706	743	779	789		
	Edh at Noon	134	174	210	225	224	238	264	244	212	173	135	125		
All-Sky Solar Radiation	RadAvg	3.95	4.71	5.78	6.75	7.65	7.77	7.21	6.89	6.29	5.45	4.32	3.76		
	RadStd	0.25	0.37	0.40	0.35	0.17	0.16	0.18	0.18	0.10	0.10	0.14	0.23		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (10 neighbors)		+0.40	+0.45	N/A	N/A	N/A	N/A	N/A	N/A	+139	+134

Nomenclature: See separate page