

LAR, Iran, Islamic Republic of

WMO: 407823

Lat: 27.674N

Lon: 54.383E

Elev: 2600

StdP: 13.37

Time Zone: 3.50 (IRN)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.5	38.1	13.7	12.1	55.6	17.3	14.5	57.6	16.1	62.1	14.2	63.2	0.5	270	0.423

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	28.1	111.5	69.4	110.8	69.2	109.2	68.9	77.4	97.3	76.0	96.8	74.6	96.5	6.3	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.0	130.4	88.4	69.9	121.4	89.4	67.7	112.2	90.3	42.9	95.6	41.4	97.1	40.0	95.7	81.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.8	14.7	12.8	DB	29.7	114.8	2.7	0.8	27.7	115.4	26.2	115.9	24.6	116.4	22.7	117.0	
			WB	25.6	79.4	2.9	1.4	23.5	80.5	21.8	81.3	20.2	82.1	18.1	83.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	75.5	53.8	57.5	65.9	74.4	85.5	92.7	95.8	93.4	87.7	77.9	64.1	56.2
	DBStd	15.56	4.73	5.75	5.40	5.38	4.62	2.98	2.12	2.74	3.30	4.27	5.37	4.52
	HDD50	29	17	7	0	0	0	0	0	0	0	0	0	5
	HDD65	980	346	217	55	5	0	0	0	0	0	0	83	274
	CDD50	9342	136	217	493	732	1101	1280	1420	1347	1132	863	423	198
	CDD65	4819	0	7	83	288	636	830	955	882	682	398	56	2
	CDH74	79116	21	151	1278	3716	10139	14788	17080	15126	10665	5196	868	88
	CDH80	53234	2	17	430	1801	6681	10722	12651	10785	7051	2852	234	8
Wind	WSAvg	3.5	2.2	3.4	3.8	4.5	4.8	4.3	4.5	4.2	3.3	2.6	2.2	1.7
Precipitation	PrecAvg	8.4	2.0	1.6	1.5	0.3	0.0	0.1	0.3	0.2	0.2	0.1	0.2	1.8
	PrecMax	16.9	3.9	10.0	5.8	0.9	0.3	0.9	2.3	1.1	0.9	1.3	1.6	8.1
	PrecMin	2.2	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	4.5	1.3	2.2	1.5	0.3	0.1	0.2	0.5	0.3	0.2	0.3	0.4	2.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.8	82.6	91.8	98.4	109.4	113.2	113.4	112.7	107.9	100.6	87.7	80.8
		MCWB	55.1	57.0	59.4	63.2	65.5	67.9	71.4	69.8	69.7	64.9	61.2	57.3
	2%	DB	73.3	78.8	88.0	95.4	106.1	111.4	111.6	109.8	105.8	98.5	85.6	76.3
		MCWB	53.6	55.8	57.8	62.3	65.5	67.9	70.4	69.3	68.4	64.0	59.6	55.5
	5%	DB	70.1	75.3	84.5	93.2	104.1	109.7	111.1	109.0	104.0	95.4	82.7	73.2
		MCWB	51.9	54.6	56.9	61.4	65.0	67.6	70.1	69.3	67.7	63.7	58.7	53.7
	10%	DB	67.6	71.7	81.0	89.8	101.9	107.9	109.4	107.3	102.2	93.1	80.2	69.8
		MCWB	51.4	53.0	56.7	60.6	64.1	67.1	70.0	69.3	67.0	63.5	57.8	52.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.3	61.0	64.5	67.3	69.2	75.0	79.3	79.2	75.4	72.5	64.6	60.9
		MCDB	68.6	72.2	74.9	86.5	102.2	98.2	97.0	96.7	92.4	87.7	79.4	71.3
	2%	WB	56.3	58.9	62.0	65.6	67.9	72.5	77.8	77.3	73.5	69.2	62.2	58.1
		MCDB	67.3	69.4	74.7	87.2	99.3	98.3	98.8	95.2	95.0	85.9	77.4	70.0
	5%	WB	54.6	57.3	60.1	64.2	66.7	70.7	76.5	75.9	72.0	67.3	60.7	56.2
		MCDB	66.0	69.4	74.0	85.8	97.5	100.8	98.6	95.1	95.2	87.3	76.0	68.0
	10%	WB	52.7	55.7	58.7	62.7	65.6	69.3	75.2	74.5	70.2	65.5	59.2	54.7
		MCDB	64.6	67.4	73.8	84.1	96.2	102.6	98.0	95.3	95.3	87.7	74.7	65.8
Mean Daily Temperature Range	5% DB	MDBR	25.8	25.0	27.2	27.0	29.5	31.2	28.1	27.9	29.6	29.9	27.5	27.9
		MCDBR	29.9	29.9	33.2	30.3	32.0	32.3	29.8	29.5	30.1	31.4	31.2	31.9
		MCWBR	15.5	13.9	13.6	10.9	11.2	11.1	10.0	9.9	10.9	12.5	14.6	15.9
	5% WB	MCDBR	24.7	22.5	24.7	26.7	30.1	30.1	27.0	26.2	28.1	27.7	25.2	25.4
		MCWBR	13.8	11.8	11.2	10.7	11.4	11.8	10.0	9.9	11.3	11.6	12.6	13.5
Clear-Sky Solar Irradiance	taub		0.356	0.416	0.470	0.520	0.510	0.539	0.625	0.591	0.506	0.432	0.370	0.350
	taud		2.236	2.037	1.877	1.785	1.808	1.763	1.637	1.706	1.847	2.010	2.203	2.263
	Ebn at Noon		278	268	260	251	253	245	224	231	247	259	270	274
	Edh at Noon		38	50	62	70	69	72	82	75	63	51	39	35
All-Sky Solar Radiation	RadAvg		1260	1493	1846	2124	2413	2510	2333	2226	2024	1746	1358	1173
	RadStd		81	115	138	112	55	53	48	59	34	45	65	70

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page