

LAR, Iran, Islamic Republic of

WMO: 407823

Lat: 27.674N

Lon: 54.383E

Elev: 793

StdP: 92.16

Time Zone: 3.50 (IRN)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.0	3.4	-10.2	1.7	13.1	-8.2	2.1	14.2	7.2	16.7	6.3	17.4	0.2	270	0.423

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.6	44.2	20.8	43.8	20.7	42.9	20.5	25.2	36.3	24.5	36.0	23.7	35.8	2.8	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.2	18.6	31.3	21.1	17.3	31.9	19.8	16.0	32.4	82.0	35.4	78.3	36.2	75.1	35.4	27.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.0	6.6	5.7	DB	-1.3	46.0	1.5	0.5	-2.4	46.3	-3.2	46.6	-4.1	46.9	-5.2	47.2
			WB	-3.5	26.4	1.6	0.8	-4.7	26.9	-5.6	27.4	-6.5	27.8	-7.7	28.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.2	12.1	14.2	18.8	23.6	29.7	33.7	35.5	34.1	31.0	25.5	17.8	13.5
	DBStd	8.64	2.63	3.19	3.00	2.99	2.56	1.66	1.18	1.52	1.83	2.37	2.99	2.51
	HDD10.0	16	9	4	0	0	0	0	0	0	0	0	0	3
	HDD18.3	544	192	121	31	3	0	0	0	0	0	0	46	152
	CDD10.0	5190	76	121	274	407	612	711	789	748	629	479	235	110
	CDD18.3	2677	0	4	46	160	353	461	531	490	379	221	31	1
	CDH23.3	43953	12	84	710	2064	5633	8216	9489	8403	5925	2887	482	49
	CDH26.7	29574	1	9	239	1001	3712	5957	7028	5992	3917	1584	130	4
Wind	WSAvg	1.5	1.0	1.5	1.7	2.0	2.1	1.9	2.0	1.9	1.5	1.2	1.0	0.8
Precipitation	PrecAvg	214	50	41	37	7	1	2	7	6	5	2	6	45
	PrecMax	429	99	254	148	24	7	22	58	29	23	33	40	206
	PrecMin	56	5	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	115	33	56	39	8	2	5	13	7	6	7	10	59
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.9	28.1	33.2	36.9	43.0	45.1	45.2	44.9	42.2	38.1	31.0	27.1
		MCWB	12.9	13.9	15.2	17.3	18.6	19.9	21.9	21.0	20.9	18.3	16.2	14.1
	2%	DB	22.9	26.0	31.1	35.2	41.2	44.1	44.2	43.2	41.0	37.0	29.8	24.6
		MCWB	12.0	13.2	14.3	16.8	18.6	19.9	21.3	20.7	20.2	17.8	15.3	13.0
	5%	DB	21.2	24.0	29.2	34.0	40.0	43.2	43.9	42.8	40.0	35.2	28.2	22.9
		MCWB	11.1	12.5	13.9	16.3	18.3	19.8	21.2	20.7	19.8	17.6	14.8	12.1
	10%	DB	19.8	22.1	27.2	32.1	38.8	42.2	43.0	41.8	39.0	34.0	26.8	21.0
		MCWB	10.8	11.7	13.7	15.9	17.8	19.5	21.1	20.7	19.4	17.5	14.3	11.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.6	16.1	18.1	19.6	20.7	23.9	26.3	26.2	24.1	22.5	18.1	16.1
		MCDB	20.3	22.4	23.8	30.3	39.0	36.8	36.1	36.0	33.5	30.9	26.3	21.9
	2%	WB	13.5	14.9	16.7	18.6	19.9	22.5	25.4	25.2	23.1	20.7	16.8	14.5
		MCDB	19.6	20.8	23.7	30.7	37.4	36.8	37.1	35.1	35.0	30.0	25.2	21.1
	5%	WB	12.6	14.1	15.6	17.9	19.3	21.5	24.7	24.4	22.2	19.6	15.9	13.4
		MCDB	18.9	20.8	23.3	29.9	36.4	38.2	37.0	35.1	35.1	30.7	24.4	20.0
	10%	WB	11.5	13.1	14.8	17.0	18.6	20.7	24.0	23.6	21.2	18.6	15.1	12.6
		MCDB	18.1	19.7	23.2	29.0	35.6	39.2	36.7	35.2	35.2	31.0	23.7	18.8
Mean Daily Temperature Range	5% DB	MDBR	14.3	13.9	15.1	15.0	16.4	17.3	15.6	15.5	16.5	16.6	15.3	15.5
		MCDBR	16.6	16.6	18.5	16.8	17.8	17.9	16.5	16.4	16.7	17.5	17.3	17.7
		MCWBR	8.6	7.7	7.6	6.0	6.2	6.2	6.2	5.6	5.5	6.0	6.9	8.1
	5% WB	MCDBR	13.7	12.5	13.7	14.8	16.7	16.7	15.0	14.5	15.6	15.4	14.0	14.1
		MCWBR	7.7	6.5	6.2	5.9	6.3	6.6	5.5	5.5	6.3	6.5	7.0	7.5
Clear-Sky Solar Irradiance	taub		0.356	0.416	0.470	0.520	0.510	0.539	0.625	0.591	0.506	0.432	0.370	0.350
	taud		2.236	2.037	1.877	1.785	1.808	1.763	1.637	1.706	1.847	2.010	2.203	2.263
	Ebn at Noon		877	845	821	792	799	771	706	727	778	817	852	865
	Edh at Noon		119	158	197	222	218	227	257	238	200	160	122	111
All-Sky Solar Radiation	RadAvg		3.97	4.71	5.82	6.70	7.61	7.91	7.36	7.02	6.38	5.50	4.28	3.70
	RadStd		0.26	0.36	0.43	0.35	0.17	0.17	0.15	0.19	0.11	0.14	0.20	0.22

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page