

TABAS, Iran, Islamic Republic of

WMO: 407910

Lat: 33.6033N

Lon: 56.9508E

Elev: 711

StdP: 93.07

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.9	1.1	-17.6	0.9	13.4	-15.0	1.1	14.3	8.1	9.6	6.6	9.6	0.8	300	0.436

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.6	44.8	19.3	43.7	18.9	42.4	18.5	20.5	41.6	19.7	41.2	19.1	40.4	2.7	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.1	10.2	23.2	11.7	9.3	24.0	10.2	8.4	24.6	62.2	42.0	59.5	41.4	57.3	40.4	26.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.2	6.9	5.9	DB	-2.5	46.7	1.2	0.7	-3.4	47.2	-4.1	47.7	-4.8	48.1	-5.6	48.6	(4)
			WB	-5.5	21.5	1.3	1.7	-6.5	22.8	-7.2	23.8	-7.9	24.7	-8.9	26.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	23.3	8.8	11.9	18.0	23.7	30.2	35.1	36.6	34.5	30.4	24.2	15.5	10.2	(6)
(7)		DBStd	10.30	3.58	4.04	4.10	4.07	2.98	2.47	2.11	2.41	2.58	3.50	3.94	3.12	(7)
(8)		HDD10.0	129	64	24	1	0	0	0	0	0	0	4	36	(8)	
(9)		HDD18.3	897	296	181	56	8	0	0	0	0	2	102	253	(9)	
(10)		CDD10.0	4984	27	78	250	409	625	752	826	758	611	439	168	41	(10)
(11)		CDD18.3	2711	0	2	46	168	367	502	568	500	361	183	16	0	(11)
(12)		CDH23.3	42024	0	16	389	1852	5377	8707	10098	8393	5164	1914	113	1	(12)
(13)	CDH26.7	28125	0	1	105	824	3262	6333	7620	5943	3140	872	24	0	(13)	
(14)	Wind	WSAvg	2.0	1.2	1.5	2.0	2.2	2.8	2.9	2.8	2.1	1.7	1.3	1.1	(14)	
(15)	Precipitation	PrecAvg	110	24	20	25	14	5	0	0	0	1	6	16	(15)	
(16)		PrecMax	245	54	45	99	61	30	5	0	3	0	17	24	45	(16)
(17)		PrecMin	66	8	0	3	0	0	0	0	0	0	0	0	0	(17)
(18)		PrecStd	36	13	13	18	14	6	1	0	1	0	3	6	13	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	20.3	25.7	33.1	37.2	41.2	45.4	46.2	45.5	41.2	37.4	29.9	21.4	(19)	
(20)		MCWB	9.9	11.6	14.2	16.2	17.2	19.2	19.8	19.9	17.8	16.2	14.3	10.1	(20)	
(21)		DB	18.2	22.4	29.1	34.9	39.8	44.1	45.1	43.7	39.8	35.0	26.5	19.1	(21)	
(22)		MCWB	8.7	10.6	13.2	15.8	17.4	18.6	19.4	19.2	17.1	15.7	12.9	8.9	(22)	
(23)		DB	16.4	20.5	27.2	33.0	38.3	43.0	44.1	42.1	38.5	33.2	24.1	17.3	(23)	
(24)		MCWB	8.0	9.8	12.3	15.2	17.0	18.4	19.1	18.7	16.7	15.0	11.7	8.3	(24)	
(25)		DB	14.8	18.7	25.2	31.1	36.9	41.9	42.9	40.6	37.1	31.4	22.2	15.7	(25)	
(26)		MCWB	7.1	9.1	11.9	14.6	16.8	17.9	18.9	18.1	16.2	14.4	10.9	7.5	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	11.7	13.3	16.4	17.7	19.2	21.1	21.6	21.6	19.8	17.3	15.3	11.3	(27)	
(28)		MCDWB	17.1	19.7	23.4	31.5	37.4	39.3	42.5	42.0	38.4	34.2	26.6	17.3	(28)	
(29)		WB	10.2	12.2	15.1	16.8	18.4	19.7	20.5	20.2	18.1	16.2	13.8	10.1	(29)	
(30)		MCDWB	15.6	18.9	23.5	31.2	36.7	41.2	42.5	41.3	37.9	33.1	23.0	16.2	(30)	
(31)		WB	9.1	11.2	13.9	16.1	17.7	19.0	19.9	19.4	17.3	15.5	12.9	9.2	(31)	
(32)		MCDWB	15.0	18.2	24.2	29.8	35.7	40.7	42.0	40.2	36.8	31.8	22.1	15.4	(32)	
(33)		WB	7.9	10.1	12.9	15.4	17.2	18.4	19.2	18.6	16.6	14.8	11.9	8.4	(33)	
(34)		MCDWB	13.8	16.9	23.8	28.4	34.6	39.9	41.1	39.0	35.8	30.2	20.6	14.4	(34)	
(35)	Mean Daily Temperature Range	MDBR	10.2	10.7	11.6	11.7	11.4	12.1	11.6	11.7	13.2	13.1	11.4	10.4	(35)	
(36)		5% DB	11.8	12.5	13.5	13.1	12.6	13.3	13.1	12.7	14.3	14.4	13.0	12.0	(36)	
(37)		MCWBR	6.5	6.1	5.9	5.3	4.8	4.8	4.6	4.6	5.6	6.2	6.5	6.5	(37)	
(38)		5% WB	10.0	10.6	11.9	11.8	11.7	12.7	12.5	12.0	13.7	13.4	11.1	10.3	(38)	
(39)		MCWBR	5.8	5.5	5.5	4.9	4.5	4.7	4.6	4.7	5.6	5.9	5.7	5.8	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.351	0.395	0.473	0.539	0.546	0.524	0.522	0.476	0.423	0.427	0.387	0.342	(40)	
(41)		taud	2.218	2.074	1.857	1.747	1.747	1.798	1.821	1.924	2.039	2.018	2.130	2.269	(41)	
(42)		Ebn at Noon	842	837	797	764	764	778	777	807	835	790	789	830	(42)	
(43)		Edh at Noon	112	144	194	227	229	217	211	188	159	150	122	101	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.19	4.05	5.28	6.36	7.38	8.24	8.01	7.50	6.36	4.94	3.62	2.98	(44)	
(45)		RadStd	0.24	0.29	0.24	0.29	0.29	0.23	0.13	0.21	0.13	0.15	0.20	0.21	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page