

FERDOWS, Iran, Islamic Republic of

WMO: 407920

Lat: 34.0306N

Lon: 58.1834E

Elev: 1293

StdP: 86.73

Time Zone: 3.50 (IRN)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.2	-4.0	-17.5	0.9	3.3	-15.1	1.2	4.9	9.0	10.5	7.9	9.4	1.7	270	0.450

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.5	38.6	17.1	37.4	16.6	36.2	16.2	18.3	35.5	17.6	34.8	17.0	34.0	4.1	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.6	9.9	23.1	10.4	9.2	23.1	9.4	8.6	23.1	57.2	35.9	54.5	34.8	52.5	34.1	23.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
8.1	7.2	6.4	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-7.5	41.0	1.8	1.2	-8.8	41.9	-9.8	42.6	-10.8	43.3	-12.0	44.2
			-10.2	19.3	3.3	1.5	-12.6	20.4	-14.5	21.3	-16.4	22.2	-18.8	23.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.2	4.6	7.2	13.2	18.8	24.6	29.2	30.4	28.0	24.5	18.9	11.3	6.8
	DBStd	9.63	4.78	4.70	4.47	4.00	3.09	2.56	2.00	2.24	2.57	3.73	4.20	3.84
	HDD10.0	437	173	97	21	1	0	0	0	0	0	0	33	113
	HDD18.3	1555	424	311	167	41	1	0	0	0	1	39	212	359
	CDD10.0	3426	6	19	119	266	452	576	631	558	436	277	73	13
	CDD18.3	1502	0	0	8	55	194	326	373	300	186	58	2	0
	CDH23.3	19308	0	3	68	503	2148	4590	5438	3867	2096	576	19	0
	CDH26.7	10249	0	0	16	136	952	2675	3257	2082	961	168	1	0
Wind	WSAvg	2.9	2.3	2.6	3.0	2.9	3.2	3.3	3.6	3.5	2.9	2.8	2.4	2.3
Precipitation	PrecAvg	167	33	32	36	21	7	1	0	0	0	3	10	24
	PrecMax	273	76	76	119	84	43	6	0	4	4	33	36	71
	PrecMin	87	9	2	4	0	0	0	0	0	0	0	0	0
	PrecStd	47	18	20	28	17	8	1	0	1	1	6	11	18
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.2	22.4	28.9	32.2	36.0	40.2	40.0	39.4	36.2	32.5	25.6	19.6
		MCWB	7.2	9.6	11.9	14.1	15.1	18.1	17.6	17.3	15.1	14.3	11.7	8.5
	2%	DB	16.1	18.7	24.9	30.0	34.4	38.5	38.7	36.8	34.3	30.2	22.8	17.2
		MCWB	6.6	8.0	10.6	13.7	15.2	17.0	17.2	16.5	15.0	13.5	10.6	7.0
	5%	DB	14.1	16.5	22.6	28.1	33.0	37.3	37.7	35.4	33.0	28.6	20.6	15.5
		MCWB	5.8	7.2	10.2	13.1	15.0	16.5	16.8	15.9	14.6	13.1	9.6	6.3
	10%	DB	12.0	14.6	20.8	26.3	31.6	36.0	36.5	34.1	31.7	26.8	18.6	13.5
		MCWB	4.8	6.5	9.6	12.6	14.5	16.0	16.5	15.2	14.2	12.4	9.0	5.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.3	10.9	13.7	15.8	16.9	20.6	19.0	19.0	17.6	15.1	12.9	9.3
		MCDB	14.3	18.5	20.2	27.1	33.0	37.3	37.1	34.2	32.6	30.3	22.0	16.2
	2%	WB	7.7	9.5	12.4	14.7	16.1	18.2	18.2	17.7	16.3	14.2	11.6	8.2
		MCDB	14.5	16.0	21.1	26.7	31.7	35.5	36.2	34.1	31.6	29.0	20.1	14.9
	5%	WB	6.5	8.5	11.3	14.0	15.5	17.2	17.7	16.9	15.3	13.4	10.6	7.2
		MCDB	12.9	14.5	20.6	26.0	30.5	34.7	35.4	33.3	31.2	27.3	18.6	13.8
	10%	WB	5.2	7.4	10.3	13.2	14.9	16.5	17.1	16.1	14.5	12.6	9.6	6.2
		MCDB	10.8	13.4	19.4	24.3	29.5	33.9	34.5	32.5	30.6	25.7	17.2	12.4
Mean Daily Temperature Range	5% DB	MDBR	10.1	10.0	10.9	11.2	11.4	12.0	11.5	11.9	13.7	12.7	11.1	10.5
		MCDBR	12.0	12.3	12.6	12.6	12.5	13.2	12.9	12.7	14.6	13.9	12.8	12.2
		MCWBR	6.5	6.3	5.5	5.2	4.4	4.5	4.3	4.4	5.9	6.2	6.6	6.6
	5% WB	MCDBR	10.5	10.2	10.8	11.6	11.9	12.6	12.0	12.0	14.3	13.4	11.3	10.3
		MCWBR	6.2	5.6	5.2	4.9	4.4	4.5	4.3	4.3	6.2	6.1	6.0	5.9
Clear-Sky Solar Irradiance	taub	0.317	0.355	0.425	0.477	0.488	0.463	0.456	0.417	0.373	0.381	0.348	0.310	
	taud	2.355	2.223	1.995	1.897	1.884	1.954	1.986	2.096	2.202	2.163	2.268	2.398	
	Ebn at Noon	888	883	842	816	810	828	831	859	885	840	837	875	
	Edh at Noon	97	123	168	195	200	186	179	157	135	129	105	88	
All-Sky Solar Radiation	RadAvg	3.08	3.96	5.17	6.29	7.30	8.24	8.04	7.51	6.38	4.90	3.56	2.90	
	RadStd	0.28	0.30	0.24	0.32	0.33	0.21	0.12	0.21	0.13	0.15	0.21	0.23	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	+0.46	N/A	-2.01	+0.79	N/A	-0.69	N/A	N/A	N/A	N/A

Nomenclature: See separate page