

SAFIABAD, Iran, Islamic Republic of

WMO: 407940

Lat: 32.267N

Lon: 48.417E

Elev: 272

StdP: 14.55

Time Zone: 3.50 (IRN)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	37.4	40.2	24.9	19.2	65.3	30.1	24.4	62.2	21.9	56.3	17.5	56.3	2.2	20	0.422

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.0	116.9	72.9	114.9	73.2	112.9	73.2	81.6	101.9	79.5	102.2	77.6	102.2	8.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.3	138.5	95.3	72.9	123.3	94.5	70.0	111.3	93.4	45.7	101.1	43.4	100.9	41.4	101.9	96.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.9	15.2	12.5	32.4	120.6	2.4	2.2	30.6	122.1	29.2	123.4	27.8	124.6	26.1	126.2		
(5)			31.2	86.0	2.8	4.1	29.2	89.0	27.6	91.3	26.0	93.7	24.0	96.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	76.5	53.6	57.4	64.9	73.8	86.1	94.2	98.0	96.7	89.5	79.6	66.1	56.9		
	DBStd	16.49	4.89	5.05	5.46	5.79	5.37	3.83	3.25	3.10	4.36	5.12	5.85	4.89		
	HDD50	36	23	7	0	0	0	0	0	0	0	0	0	6		
	HDD65	955	354	215	69	6	0	0	0	0	0	0	57	254		
	CDD50	9710	134	214	463	714	1120	1327	1488	1447	1184	918	482	219		
	CDD65	5153	0	2	66	270	655	877	1023	982	734	453	89	2		
	CDH74	78999	1	22	686	2983	9564	14760	17864	16637	10734	5042	674	32		
(13)	CDH80	54516	0	0	178	1365	6274	10775	13472	12281	7222	2772	175	2		
(14)	Wind	WSAvg	5.0	4.4	4.8	5.1	5.5	6.2	5.7	5.5	4.2	4.5	3.7	3.8		
(15) Precipitation	PrecAvg	14.8	3.3	1.9	2.4	1.3	0.3	0.0	0.0	0.0	0.0	0.5	1.9	3.0		
	PrecMax	23.5	7.6	6.5	8.1	4.4	1.8	0.1	0.0	0.1	0.5	2.7	9.4	8.8		
	PrecMin	6.1	0.7	0.1	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	4.5	1.7	1.5	2.0	1.0	0.4	0.0	0.0	0.0	0.1	0.7	2.0	2.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.3	77.1	89.6	100.3	111.3	117.8	120.5	118.0	112.7	102.8	87.9	77.9		
		MCWB	57.1	59.1	65.6	70.1	70.3	73.0	73.0	73.3	72.8	70.4	65.0	59.3		
	2%	DB	68.2	73.6	84.7	95.2	107.8	114.9	118.0	115.6	109.2	99.1	84.9	72.6		
		MCWB	55.8	58.9	65.1	68.4	69.9	71.9	72.9	73.7	73.9	70.7	64.5	58.4		
	5%	DB	65.5	71.0	80.8	91.2	104.7	112.9	115.9	113.5	106.5	96.3	81.3	68.9		
		MCWB	55.4	58.1	63.2	67.5	69.0	71.6	73.0	74.5	74.0	70.3	64.1	57.6		
	10%	DB	63.0	68.3	77.5	87.8	102.1	110.8	113.7	111.4	103.9	93.3	77.5	66.0		
		MCWB	54.8	56.8	61.3	66.8	68.8	71.2	73.2	74.9	73.6	69.5	62.5	57.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.2	64.2	69.7	74.8	76.4	83.0	81.6	83.5	86.3	79.1	70.7	63.7		
		MCDB	65.6	71.8	83.8	93.4	100.6	108.1	105.6	102.7	102.1	93.8	80.0	69.3		
	2%	WB	59.5	62.0	67.0	71.7	73.7	76.9	78.6	80.9	82.2	75.2	68.2	61.7		
		MCDB	64.4	68.8	80.4	89.6	99.6	105.4	107.1	103.7	98.7	90.9	78.5	67.9		
	5%	WB	57.6	60.1	65.2	69.7	71.9	74.5	76.5	79.3	79.1	73.0	66.4	60.2		
		MCDB	62.4	67.2	77.5	86.1	98.0	105.9	107.3	103.9	97.4	90.3	76.5	65.9		
	10%	WB	56.1	58.3	63.4	68.2	70.5	72.7	74.8	77.7	76.6	71.2	64.5	58.7		
		MCDB	61.1	65.9	74.6	83.9	96.1	105.8	107.7	103.5	97.3	89.1	74.9	64.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	18.5	20.4	23.6	25.4	29.2	33.6	33.0	31.8	31.5	27.5	22.0	19.1		
		MCDBR	22.1	23.7	27.9	29.9	33.1	35.1	34.5	33.1	32.2	30.6	26.4	24.0		
		MCWBR	12.0	11.9	13.5	12.4	10.1	10.3	9.3	10.8	12.3	12.5	10.8	12.1		
		MCDBR	16.7	18.9	24.4	26.1	29.7	33.7	32.4	30.2	29.4	28.2	20.9	17.4		
	5% WB	MCWBR	10.7	11.2	13.4	12.6	11.4	12.9	11.5	13.1	15.9	14.1	10.7	10.2		
(40) Clear-Sky Solar Irradiance	taub		0.442	0.482	0.540	0.636	0.604	0.553	0.628	0.570	0.498	0.529	0.473	0.442		
	taud		1.979	1.885	1.752	1.607	1.672	1.747	1.623	1.733	1.863	1.814	1.933	1.992		
	Ebn at Noon		235	239	236	220	229	240	222	233	244	221	222	226		
	Edh at Noon		47	56	69	83	79	73	82	72	61	60	48	44		
(44) All-Sky Solar Radiation	RadAvg		959	1259	1641	1875	2223	2601	2456	2308	2015	1505	1090	899		
	RadStd		72	90	111	134	125	78	62	60	62	92	89	88		

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page