

SHAHRE KORD, Iran, Islamic Republic of

WMO: 407980

Lat: 32.2927N

Lon: 50.8396E

Elev: 6722

StdP: 11.46

Time Zone: 3.50 (IRN)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -1.8	(c) 8.5	(d) -8.1	(e) 4.6	(f) 17.2	(g) -3.0	(h) 6.0	(i) 24.5	(j) 28.7	(k) 42.4	(l) 24.6	(m) 41.1	(n) 0.1	(o) 120	(p) 0.526

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 35.1	(c) 94.8	(d) 58.4	(e) 92.9	(f) 57.7	(g) 91.1	(h) 56.9	(i) 60.7	(j) 90.1	(k) 59.3	(l) 88.6	(m) 58.1	(n) 87.0	(o) 8.7	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
49.2	66.8	69.0	46.6	60.4	67.6	44.7	56.2	65.7	30.2	90.1	29.1	88.7	28.1	87.1	68.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.3	19.6	16.5	DB	-6.5	97.7	11.7	1.6	-14.9	98.9	-21.8	99.8	-28.3	100.7	-36.9	101.8
			WB	-7.3	62.2	11.2	1.9	-15.4	63.6	-21.9	64.7	-28.2	65.7	-36.4	67.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.4	29.8	35.5	43.1	50.7	59.5	68.6	74.2	71.5	63.9	54.6	42.8	34.0
	DBStd	15.85	10.43	6.96	6.07	4.88	4.22	3.79	3.08	3.26	3.66	3.99	6.11	7.95
	HDD50	2038	627	407	226	50	0	0	0	0	0	8	223	497
	HDD65	5225	1092	826	679	429	174	11	0	1	63	323	666	961
	CDD50	2931	0	1	12	71	296	558	750	667	416	151	8	1
	CDD65	641	0	0	0	0	5	119	285	203	29	0	0	0
	CDH74	14182	0	0	1	17	517	3112	4803	3909	1681	142	0	0
	CDH80	6555	0	0	0	0	81	1405	2584	1942	539	4	0	0
Wind	WSAvg	5.3	5.0	6.0	7.2	6.8	6.1	5.2	5.1	4.7	4.5	4.8	4.4	4.3
Precipitation	PrecAvg	15.2	2.4	2.3	2.9	1.8	0.5	0.0	0.1	0.0	0.0	0.4	2.0	2.8
	PrecMax	22.5	5.5	5.7	6.1	4.2	2.1	0.4	0.9	0.1	0.3	2.4	8.0	8.2
	PrecMin	6.6	0.5	0.2	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1
	PrecStd	3.8	1.3	1.4	1.4	1.1	0.5	0.1	0.2	0.0	0.1	0.6	1.8	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.8	61.1	71.6	76.8	85.9	94.9	97.2	95.7	89.8	80.2	68.3	61.1
		MCWB	39.4	42.2	46.1	50.8	54.6	57.8	59.5	58.9	53.8	51.5	45.2	43.4
	2%	DB	52.2	56.1	66.4	71.8	82.3	91.8	95.3	93.4	87.7	77.3	64.7	56.3
		MCWB	38.2	39.7	44.1	49.4	53.5	56.7	58.6	57.8	54.3	50.2	44.0	40.3
	5%	DB	48.6	53.2	62.2	68.4	79.3	89.9	93.6	91.5	85.8	75.3	61.2	52.2
		MCWB	37.0	38.6	42.5	47.8	52.7	55.8	58.1	57.1	53.8	49.7	43.3	38.3
	10%	DB	45.8	49.7	58.8	65.9	76.9	87.8	91.7	89.5	83.8	72.9	57.5	48.6
		MCWB	35.8	37.3	41.2	46.8	52.0	55.4	57.4	56.5	53.1	48.6	42.0	37.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.8	44.4	48.0	52.9	57.1	61.6	62.7	62.2	57.7	53.6	48.7	46.2
		MCDB	51.2	54.6	62.1	70.3	79.0	87.6	91.7	90.4	84.2	75.0	61.5	55.4
	2%	WB	40.4	42.3	45.8	51.0	55.5	59.0	61.1	60.0	55.8	51.8	46.5	43.0
		MCDB	48.0	51.8	59.9	67.0	77.1	87.7	90.7	89.8	83.2	73.7	58.7	51.7
	5%	WB	38.4	40.4	44.4	49.5	54.1	57.6	59.8	58.7	54.6	50.4	44.9	40.6
		MCDB	46.0	49.9	57.9	64.5	75.3	86.1	89.4	88.2	82.1	71.6	56.6	49.1
	10%	WB	36.6	38.5	42.8	48.2	52.9	56.4	58.6	57.4	53.4	49.3	43.5	38.5
		MCDB	44.4	47.2	55.6	62.2	73.3	84.5	87.9	86.6	81.0	69.6	54.9	46.3
Mean Daily Temperature Range	5% DB	MDBR	25.8	24.9	28.1	27.4	32.2	38.3	35.1	36.8	39.6	34.7	27.2	27.0
		MCDBR	29.0	31.5	36.2	33.7	37.7	40.7	38.4	39.0	41.2	39.3	34.2	33.4
		MCWBR	18.1	18.5	19.0	15.9	15.6	15.5	14.0	14.9	17.0	19.4	18.2	20.1
	5% WB	MCDBR	23.2	24.4	28.2	27.3	34.0	37.7	35.3	36.0	38.5	35.1	26.1	26.2
		MCWBR	15.5	15.5	15.8	13.3	14.6	15.0	13.4	14.2	16.5	17.8	14.6	16.6
Clear-Sky Solar Irradiance	taub		0.262	0.300	0.355	0.435	0.432	0.412	0.452	0.408	0.352	0.351	0.302	0.263
	taud		2.468	2.365	2.178	1.967	2.007	2.081	1.985	2.111	2.262	2.242	2.406	2.500
	Ebn at Noon		309	304	292	272	273	277	265	276	289	280	289	303
	Edh at Noon		28	34	45	58	56	52	57	49	41	38	30	26
All-Sky Solar Radiation	RadAvg		1003	1287	1678	1915	2299	2654	2495	2359	2063	1578	1112	922
	RadStd		69	110	108	143	129	81	89	75	70	85	104	98

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	-1.78	N/A	N/A	+207	-176	-110

Nomenclature: See separate page