

SHAHRE KORD, Iran, Islamic Republic of

WMO: 407980

Lat: 32.2927N

Lon: 50.8396E

Elev: 2049

StdP: 79.01

Time Zone: 3.50 (IRN)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.8	-13.1	-22.3	0.7	-8.2	-19.5	0.9	-4.2	12.8	5.8	11.0	5.1	0.1	120	0.526

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.5	34.9	14.7	33.9	14.3	32.8	13.8	15.9	32.3	15.2	31.4	14.5	30.6	3.9	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
9.6	9.5	20.6	8.1	8.6	19.8	7.1	8.0	18.7	52.3	32.3	49.7	31.5	47.6	30.6	20.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	10.4	8.8	7.4	-21.4	36.5	6.5	0.9	-26.1	37.2	-29.9	37.7	-33.5	38.1	-38.3	38.8	
(5)				-21.8	16.8	6.2	1.0	-26.3	17.5	-30.0	18.2	-33.5	18.7	-38.0	19.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.4	-1.2	1.9	6.2	10.4	15.3	20.3	23.4	22.0	17.7	12.6	6.0	1.1
	DBStd	8.80	5.79	3.87	3.37	2.71	2.34	2.11	1.71	1.81	2.03	2.22	3.39	4.42
	HDD10.0	1132	348	226	126	28	0	0	0	0	4	124	276	
	HDD18.3	2903	607	459	377	238	97	6	0	1	35	179	370	534
	CDD10.0	1628	0	1	7	39	164	310	417	371	231	84	4	1
	CDD18.3	356	0	0	0	0	3	66	158	113	16	0	0	0
	CDH23.3	7879	0	0	1	9	287	1729	2668	2172	934	79	0	0
	CDH26.7	3642	0	0	0	0	45	781	1436	1079	299	2	0	0
Wind	WSAvg	2.4	2.2	2.7	3.2	3.0	2.7	2.3	2.3	2.1	2.0	2.2	2.0	1.9
Precipitation	PrecAvg	386	62	58	73	46	13	1	2	0	1	10	51	70
	PrecMax	571	140	145	155	107	53	10	22	2	7	60	202	209
	PrecMin	168	13	5	4	0	0	0	0	0	0	2	2	2
	PrecStd	97	32	35	36	29	13	2	4	0	2	14	46	48
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.2	16.2	22.0	24.9	30.0	34.9	36.2	35.4	32.1	26.8	20.2	16.2
		MCWB	4.1	5.7	7.8	10.4	12.5	14.3	15.3	15.0	12.1	10.8	7.3	6.3
	2%	DB	11.2	13.4	19.1	22.1	27.9	33.2	35.2	34.1	30.9	25.2	18.2	13.5
		MCWB	3.5	4.3	6.7	9.7	12.0	13.7	14.8	14.3	12.4	10.1	6.6	4.6
	5%	DB	9.2	11.8	16.8	20.2	26.3	32.1	34.2	33.1	29.9	24.0	16.2	11.2
		MCWB	2.8	3.7	5.8	8.8	11.5	13.2	14.5	14.0	12.1	9.8	6.3	3.5
	10%	DB	7.7	9.8	14.9	18.8	24.9	31.0	33.2	31.9	28.8	22.7	14.2	9.2
		MCWB	2.1	3.0	5.1	8.2	11.1	13.0	14.1	13.6	11.7	9.2	5.6	3.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.0	6.9	8.9	11.6	13.9	16.5	17.1	16.8	14.3	12.0	9.3	7.9
		MCDB	10.7	12.6	16.7	21.3	26.1	30.9	33.2	32.5	29.0	23.9	16.4	13.0
	2%	WB	4.7	5.7	7.7	10.6	13.0	15.0	16.1	15.6	13.2	11.0	8.1	6.1
		MCDB	8.9	11.0	15.5	19.4	25.1	31.0	32.6	32.1	28.4	23.2	14.8	10.9
	5%	WB	3.6	4.7	6.9	9.7	12.3	14.2	15.5	14.8	12.6	10.2	7.2	4.8
		MCDB	7.8	9.9	14.4	18.0	24.1	30.1	31.9	31.2	27.9	22.0	13.7	9.5
	10%	WB	2.6	3.6	6.0	9.0	11.6	13.5	14.8	14.1	11.9	9.6	6.4	3.6
		MCDB	6.9	8.5	13.1	16.8	23.0	29.2	31.0	30.3	27.2	20.9	12.7	7.9
Mean Daily Temperature Range	5% DB	MDBR	14.3	13.9	15.6	15.2	17.9	21.3	19.5	20.5	22.0	19.3	15.1	15.0
		MCDBR	16.1	17.5	20.1	18.7	20.9	22.6	21.3	21.7	22.9	21.9	19.0	18.6
		MCWBR	10.0	10.3	10.5	8.8	8.6	8.6	7.8	8.3	9.4	10.8	10.1	11.2
	5% WB	MCDBR	12.9	13.6	15.7	15.2	18.9	20.9	19.6	20.0	21.4	19.5	14.5	14.5
		MCWBR	8.6	8.6	8.8	7.4	8.1	8.3	7.5	7.9	9.2	9.9	8.1	9.2
Clear-Sky Solar Irradiance	taub	0.262	0.300	0.355	0.435	0.432	0.412	0.452	0.408	0.352	0.351	0.302	0.263	
	taud	2.468	2.365	2.178	1.967	2.007	2.081	1.985	2.111	2.262	2.242	2.406	2.500	
	Ebn at Noon	973	958	921	857	860	873	836	871	912	883	912	954	
	Edh at Noon	88	108	141	183	177	164	180	156	128	121	93	81	
All-Sky Solar Radiation	RadAvg	3.16	4.06	5.29	6.04	7.25	8.37	7.87	7.44	6.50	4.97	3.51	2.91	
	RadStd	0.22	0.35	0.34	0.45	0.41	0.26	0.28	0.23	0.22	0.27	0.33	0.31	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Regional (5 neighbors)		N/A	N/A	N/A	N/A	-0.99	N/A	N/A	+115	-98	-61

Nomenclature: See separate page