

AHWAZ, Iran, Islamic Republic of

WMO: 408110

Lat: 31.3443N

Lon: 48.7440E

Elev: 22

StdP: 101.06

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.9	6.2	-6.1	2.3	21.3	-4.0	2.7	20.4	9.5	17.5	8.2	17.5	1.3	280	0.443

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.6	48.1	23.5	47.1	23.3	46.1	22.9	28.8	36.7	27.4	37.7	26.1	39.3	3.4	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.0	22.8	33.6	24.9	20.0	33.7	22.2	16.9	34.8	94.1	35.6	87.4	37.0	81.4	38.8	33.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.4	7.1	6.1	DB	2.2	50.0	1.7	1.2	1.0	50.8	0.0	51.5	-1.0	52.1	-2.2	53.0	
			WB	0.6	30.2	1.7	1.6	-0.6	31.4	-1.6	32.3	-2.6	33.2	-3.9	34.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.5	13.2	15.6	20.2	25.8	32.6	36.7	38.5	38.1	34.0	28.4	19.9	14.5
	DBStd	9.52	2.75	2.98	3.03	3.25	2.79	1.87	1.50	1.55	2.30	2.96	3.47	2.88
	HDD10.0	11	6	2	0	0	0	0	0	0	0	0	0	3
	HDD18.3	401	161	83	14	1	0	0	0	0	0	0	22	121
	CDD10.0	6037	105	159	316	474	700	800	884	870	719	570	298	143
	CDD18.3	3387	1	7	72	225	442	550	626	612	469	312	70	3
	CDH23.3	55464	3	49	692	2716	7264	9942	11536	11019	7658	3968	594	23
(14) Wind	WSAvg	39724	0	3	226	1406	4990	7554	9056	8541	5421	2338	188	1
	PrecAvg	2.4	1.9	2.2	2.4	2.5	2.7	3.3	3.3	2.7	2.2	1.8	1.7	1.8
	PrecMax	205	42	24	28	21	3	0	0	0	0	7	34	46
	PrecMin	415	118	73	124	94	42	1	1	0	4	61	173	132
	PrecStd	78	0	0	0	3	0	0	0	0	0	0	0	0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	79	31	21	27	19	8	0	0	0	1	15	38	41
	0.4% DB	23.2	26.9	34.9	39.9	45.8	48.8	49.9	48.9	46.2	41.2	33.1	25.8	
	0.4% MCWB	14.2	15.3	16.4	19.1	21.9	23.0	24.1	23.5	22.8	20.6	19.5	15.6	
	2% DB	21.2	24.9	31.2	37.2	43.9	47.1	48.2	47.9	45.0	39.8	31.0	23.4	
	2% MCWB	14.0	14.7	16.4	18.8	21.2	22.5	23.6	23.7	22.6	21.0	18.3	15.3	
	5% DB	19.9	23.1	29.0	35.5	42.1	46.0	47.1	47.0	43.5	38.1	29.0	21.8	
	5% MCWB	13.5	14.2	15.9	18.1	20.5	21.9	23.3	23.6	22.0	20.3	17.7	15.3	
	10% DB	18.2	21.8	27.0	33.8	40.8	44.9	46.1	45.9	42.1	36.2	26.9	20.0	
	10% MCWB	13.1	13.5	15.2	17.8	20.3	21.4	22.9	23.4	21.4	19.8	16.8	14.5	
	0.4% WB	17.4	18.1	20.0	22.0	24.4	26.8	29.5	30.8	29.1	26.4	22.6	18.9	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% MCDB	20.0	22.5	25.4	31.5	40.2	40.1	38.3	36.4	33.9	32.0	28.4	21.6	
	2% WB	16.1	16.8	18.7	20.7	23.1	25.2	27.7	29.4	27.4	24.5	20.6	17.6	
	2% MCDB	19.0	21.1	25.3	31.0	38.9	40.3	39.0	36.0	34.9	32.1	26.8	20.7	
	5% WB	15.1	15.7	17.6	20.0	22.2	23.7	26.3	28.0	25.7	23.0	19.4	16.3	
	5% MCDB	18.0	20.3	24.7	30.3	37.4	41.5	40.8	37.7	36.8	31.7	25.5	19.6	
	10% WB	14.0	14.7	16.6	19.2	21.4	22.7	25.0	26.6	24.0	21.7	18.2	15.3	
	10% MCDB	17.4	19.6	24.3	29.6	36.7	41.6	41.6	38.8	37.4	32.1	24.0	18.7	
	MDBR	9.4	10.8	12.4	13.2	14.6	16.1	15.6	16.2	16.8	15.1	12.0	9.9	
(35) Mean Daily Temperature Range	5% DB	11.4	12.7	15.0	15.4	16.7	17.6	16.8	17.0	17.4	16.9	14.4	12.4	
	5% WB	6.1	5.7	5.3	4.6	5.3	5.7	5.7	6.4	6.5	6.4	6.2	6.4	
	MCDBR	8.4	9.9	11.7	12.8	14.8	17.0	16.1	15.7	15.8	13.9	10.8	8.9	
	MCWBR	5.7	5.6	5.4	4.9	5.5	6.4	6.9	7.7	8.0	7.5	6.0	5.6	
(40) Clear-Sky Solar Irradiance	taub	0.468	0.504	0.563	0.660	0.639	0.590	0.660	0.606	0.532	0.552	0.499	0.466	
	taud	1.917	1.835	1.697	1.560	1.596	1.660	1.561	1.655	1.785	1.762	1.872	1.938	
	Ebn at Noon	719	737	727	678	698	730	678	708	743	683	681	695	
	Edh at Noon	158	188	232	276	268	250	275	248	209	200	164	148	
(44) All-Sky Solar Radiation	RadAvg	3.14	4.11	5.31	5.97	7.07	8.10	7.61	7.16	6.29	4.83	3.53	2.93	
	RadStd	0.23	0.29	0.28	0.38	0.35	0.23	0.19	0.20	0.19	0.22	0.27	0.28	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	+0.30	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page