

ABADEH, Iran, Islamic Republic of

WMO: 408180

Lat: 31.1981N

Lon: 52.6161E

Elev: 2030

StdP: 79.20

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -7.9	(c) -5.9	(d) -22.0	(e) 0.7	(f) 7.9	(g) -19.2	(h) 0.9	(i) 7.4	(j) 13.8	(k) 10.0	(l) 12.0	(m) 8.9	(n) 1.3	(o) 330	(p) 0.478

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 14.3	(c) 35.3	(d) 14.4	(e) 34.4	(f) 14.0	(g) 33.3	(h) 13.5	(i) 15.8	(j) 32.4	(k) 15.0	(l) 32.0	(m) 14.3	(n) 31.2	(o) 3.3	(p) 240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
9.1	9.2	19.6	7.6	8.3	19.4	6.2	7.6	18.5	51.8	32.6	49.2	32.1	46.9	31.6	20.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 11.6	(b) 9.7	(c) 8.1	(e) -12.4	(f) 36.6	(g) 3.7	(h) 0.7	(i) -15.1	(j) 37.1	(k) -17.2	(l) 37.5	(m) -19.3	(n) 37.9	(o) -21.9	(p) 38.4		
(a) 11.6	(b) 9.7	(c) 8.1	(e) -13.6	(f) 16.9	(g) 3.2	(h) 1.6	(i) -15.9	(j) 18.1	(k) -17.7	(l) 19.1	(m) -19.5	(n) 20.0	(o) -21.8	(p) 21.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.7	3.2	5.1	9.7	13.9	19.1	24.3	26.2	24.2	21.1	15.4	8.5	5.0		
	DBStd	8.47	3.76	3.63	3.30	2.83	2.65	2.16	2.01	2.14	2.02	2.57	3.47	3.47		
	HDD10.0	630	213	140	45	4	0	0	0	0	0	1	68	159		
	HDD18.3	2076	471	371	267	136	24	0	0	0	3	94	296	414		
	CDD10.0	2342	1	3	37	120	281	430	503	441	332	169	23	3		
	CDD18.3	745	0	0	0	1	47	180	245	182	85	5	0	0		
	CDH23.3	10550	0	0	7	37	633	2535	3414	2542	1238	146	0	0		
	CDH26.7	4866	0	0	0	1	144	1257	1836	1207	412	9	0	0		
(14) Wind	WSAvg	2.7	2.7	3.2	3.4	3.3	2.9	2.8	2.8	2.8	2.2	2.1	2.0	2.1		
(15) Precipitation	PrecAvg	166	30	20	35	19	5	1	1	0	0	5	16	30		
	PrecMax	376	130	51	81	71	39	10	8	2	4	29	65	107		
	PrecMin	51	4	0	0	0	0	0	0	0	0	0	0	1		
	PrecStd	61	27	14	21	18	9	2	2	1	1	8	18	31		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.9	18.2	24.2	26.2	31.1	35.8	36.8	36.2	33.1	27.9	21.9	18.2		
		MCWB	4.8	5.9	8.3	10.2	11.8	14.4	14.8	14.9	12.4	10.5	7.3	6.6		
	2%	DB	13.9	15.8	21.0	24.2	29.4	34.8	35.9	34.5	31.2	26.3	19.9	15.6		
		MCWB	4.5	4.9	7.6	9.7	11.5	13.9	14.6	14.3	12.0	10.1	7.1	5.1		
	5%	DB	12.0	13.9	18.9	22.8	28.2	33.8	35.0	33.2	30.2	25.0	18.0	13.9		
		MCWB	3.5	4.2	6.4	8.8	11.2	13.3	14.4	13.6	11.7	9.7	6.8	4.4		
	10%	DB	10.2	12.1	17.0	21.1	27.0	32.5	34.0	32.0	29.1	23.5	16.1	12.0		
		MCWB	2.9	3.6	5.6	8.3	10.9	12.8	14.0	13.1	11.3	9.1	6.0	3.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.9	7.6	9.7	11.4	13.4	16.8	16.9	16.8	13.6	11.6	9.8	8.0		
		MCDB	12.3	14.1	17.3	23.0	26.4	31.4	33.4	32.2	29.7	24.5	17.6	15.4		
	2%	WB	5.8	6.2	8.7	10.6	12.6	15.2	15.8	15.3	12.7	10.8	8.5	6.4		
		MCDB	11.3	13.0	17.3	21.5	26.0	31.1	33.1	31.9	29.5	24.5	16.4	13.2		
	5%	WB	4.6	5.2	7.8	9.9	12.0	14.2	15.2	14.4	12.2	10.1	7.5	5.5		
		MCDB	10.1	11.8	16.1	19.8	25.5	31.3	32.5	31.3	28.8	23.2	15.5	11.3		
	10%	WB	3.6	4.4	6.7	9.2	11.4	13.5	14.6	13.7	11.7	9.5	6.7	4.6		
		MCDB	9.1	10.7	15.0	18.8	24.6	30.7	31.8	30.6	28.1	21.9	14.6	10.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.1	12.2	12.8	12.7	14.1	15.6	14.3	15.3	16.1	15.3	13.7	13.0		
		MCDBR	14.2	14.6	15.2	14.8	15.5	16.4	15.6	15.9	16.9	16.5	15.8	15.4		
		MCWBR	7.9	7.6	7.0	6.1	5.9	6.3	5.9	6.3	7.0	7.5	7.7	8.1		
		MCDBR	11.2	11.2	12.1	12.3	14.4	15.5	14.3	15.1	16.0	15.2	12.9	12.2		
	5% WB	MCWBR	6.9	6.5	6.5	5.3	5.4	6.2	5.5	6.0	6.8	7.2	6.5	6.9		
(40) Clear-Sky Solar Irradiance	taub		0.265	0.305	0.365	0.445	0.450	0.443	0.469	0.425	0.370	0.354	0.302	0.268		
	taud		2.471	2.346	2.128	1.923	1.934	1.966	1.916	2.036	2.179	2.209	2.393	2.482		
	Ebn at Noon		976	957	913	850	845	847	823	857	895	885	917	954		
	Edh at Noon		89	112	150	192	191	184	193	169	140	126	96	84		
(44) All-Sky Solar Radiation	RadAvg		3.50	4.44	5.75	6.43	7.47	8.32	7.87	7.51	6.61	5.28	3.90	3.33		
	RadStd		0.29	0.31	0.33	0.37	0.36	0.28	0.26	0.24	0.18	0.22	0.28	0.28		

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	-0.98	N/A	N/A	+94	-101	-60

Nomenclature: See separate page