

YAZD SADOOGHI INTL, Iran, Islamic Republic of

WMO: 408210

Lat: 31.9036N

Lon: 54.2890E

Elev: 4058

StdP: 12.66

Time Zone: 3.50 (IRN)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.4	30.1	-4.1	5.1	59.9	-0.1	6.3	57.5	21.6	55.7	17.6	54.0	4.3	120	0.451

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.2	107.5	62.8	105.6	62.1	103.6	61.4	65.5	100.7	64.2	99.3	63.0	98.1	6.4	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
52.4	67.9	71.8	50.0	62.1	73.4	47.9	57.4	73.2	32.6	100.8	31.5	99.5	30.5	98.2	71.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.5	15.2	13.0	21.8	110.0	4.2	1.0	18.8	110.7	16.3	111.3	14.0	111.9	10.9	112.6		
			18.4	66.9	3.1	1.9	16.2	68.2	14.4	69.3	12.7	70.4	10.4	71.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	69.0	45.4	50.5	59.6	68.8	79.2	88.3	91.7	87.7	81.3	70.3	55.6	47.8	(6)
(7)		DBStd	17.21	7.75	7.95	7.39	6.26	5.47	4.54	4.33	4.30	4.20	5.53	7.02	6.48	(7)
(8)		HDD50	421	185	80	11	0	0	0	0	0	0	0	26	119	(8)
(9)		HDD65	2084	608	409	195	33	0	0	0	0	0	17	287	535	(9)
(10)		CDD50	7339	42	94	310	565	905	1148	1292	1169	939	630	195	50	(10)
(11)		CDD65	3525	0	3	28	148	440	698	827	704	489	182	6	0	(11)
(12)		CDH74	51859	1	24	352	1567	5521	11009	13824	11003	6502	1945	101	10	(12)
(13)		CDH80	31641	0	2	79	511	2845	7149	9544	7119	3661	720	10	1	(13)
(14)	Wind	WSAvg	5.9	5.1	6.0	6.4	6.5	6.8	6.9	6.6	5.5	4.9	4.7	4.8	(14)	
(15)	Precipitation	PrecAvg	2.8	0.6	0.4	0.6	0.3	0.1	0.0	0.0	0.0	0.1	0.2	0.5	(15)	
(16)		PrecMax	5.2	1.8	1.1	2.6	0.8	0.6	0.2	0.1	0.0	0.3	1.3	1.6	(16)	
(17)		PrecMin	0.9	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
(18)		PrecStd	1.0	0.4	0.3	0.6	0.2	0.2	0.0	0.0	0.0	0.1	0.4	0.5	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.9	77.4	87.7	91.8	100.5	107.8	109.7	107.9	101.7	93.4	81.0	73.8	(19)
(20)		MCWB	48.3	50.2	52.5	55.8	58.9	62.5	63.8	63.1	59.5	56.6	52.2	48.6	(20)	
(21)		2%	DB	67.8	71.9	81.0	88.5	97.2	105.8	107.9	105.2	98.9	89.9	76.8	68.3	(21)
(22)		MCWB	46.3	48.2	51.1	55.1	58.4	61.5	63.0	62.3	58.9	55.9	50.9	46.5	(22)	
(23)		5%	DB	63.5	68.3	77.4	85.9	95.0	103.8	106.2	102.6	97.0	87.1	73.1	64.5	(23)
(24)		MCWB	44.6	47.0	49.6	54.6	58.1	60.7	62.4	61.3	58.4	55.1	50.2	45.0	(24)	
(25)		10%	DB	59.2	64.8	73.8	82.6	92.8	100.9	104.3	100.6	94.9	84.1	69.4	60.6	(25)
(26)		MCWB	42.5	45.5	48.9	53.3	57.7	60.0	62.0	60.5	57.6	54.1	48.6	43.6	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.0	53.1	56.3	58.9	62.8	66.7	67.4	66.4	62.1	58.4	54.7	51.1	(27)
(28)		MCDWB	64.3	68.2	70.5	76.7	91.2	96.4	102.7	101.2	96.5	86.4	72.9	67.3	(28)	
(29)		2%	WB	48.3	50.5	54.1	57.3	60.8	64.5	65.9	64.7	60.7	57.0	52.8	48.3	(29)
(30)		MCDWB	63.1	66.7	71.2	79.1	89.8	97.8	102.5	99.7	94.6	84.9	70.3	64.3	(30)	
(31)		5%	WB	45.9	48.8	52.4	56.3	59.5	62.9	64.6	63.2	59.5	55.9	51.3	46.4	(31)
(32)		MCDWB	60.3	64.7	72.1	78.7	88.5	97.3	100.8	98.1	93.1	83.1	68.3	61.0	(32)	
(33)		10%	WB	43.6	46.9	50.6	55.3	58.5	61.5	63.5	61.8	58.4	54.9	49.9	44.6	(33)
(34)		MCDWB	57.3	63.2	71.5	77.8	87.2	96.6	99.5	96.8	91.8	81.2	66.1	57.8	(34)	
(35)	Mean Daily Temperature Range		MDBR	21.4	22.2	23.0	22.7	22.7	23.7	23.2	24.9	25.9	25.0	22.1	22.1	(35)
(36)		5% DB	MCDBR	26.2	25.6	26.7	25.2	24.7	25.4	24.4	25.4	27.6	27.6	26.9	27.9	(36)
(37)			MCWBR	13.6	12.2	11.3	9.6	8.5	9.0	8.5	9.2	10.7	11.6	12.9	14.2	(37)
(38)			MCDBR	23.0	22.0	22.2	22.4	23.1	23.0	22.1	23.2	25.6	24.9	22.8	23.7	(38)
(39)		5% WB	MCWBR	12.7	11.4	10.7	8.5	8.0	8.8	8.4	9.0	10.2	10.9	11.2	12.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.304	0.344	0.408	0.488	0.498	0.488	0.490	0.446	0.401	0.393	0.340	0.303	(40)	
(41)		taud	2.409	2.267	2.045	1.869	1.863	1.895	1.911	2.028	2.130	2.133	2.310	2.428	(41)	
(42)		Ebn at Noon	292	288	275	257	255	257	255	266	274	266	274	286	(42)	
(43)		Edh at Noon	30	38	51	64	65	63	62	54	47	43	33	28	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1105	1382	1772	2032	2331	2614	2517	2389	2062	1636	1214	1032	(44)	
(45)		RadStd	83	97	84	110	98	83	59	67	51	56	77	77	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	+0.95	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	+0.95	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page