

ZABOL, Iran, Islamic Republic ofWMO: **408290**Lat: **31.0891N**Lon: **61.5431E**Elev: **1604**StdP: **13.86**Time Zone: **3.50 (IRN)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.0	30.4	2.9	6.8	44.7	6.8	8.3	45.3	29.4	43.1	27.0	44.9	7.8	330	0.634

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.4	113.4	68.9	111.4	68.2	109.3	67.7	72.3	105.1	70.6	105.1	69.3	104.1	14.1	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
60.7	84.2	85.9	57.7	75.3	84.1	55.9	70.6	83.1	37.1	104.9	35.6	105.5	34.4	104.3	81.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 40.4	35.9	32.0	DB	21.6	117.8	3.5	1.4	19.1	118.8	17.1	119.6	15.2	120.4	12.7	121.5	(4)
(5)			WB	17.7	73.9	3.9	3.1	14.9	76.2	12.6	78.0	10.4	79.7	7.6	81.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	74.1	48.4	54.0	65.6	76.2	87.1	94.2	97.7	94.2	86.0	74.4	60.1	50.2	(6)	
	DBStd	18.36	6.69	8.60	7.65	7.23	5.16	4.32	3.74	4.19	5.11	6.59	7.08	6.14	(7)	
	HDD50	243	107	53	4	0	0	0	0	0	0	0	9	70	(8)	
	HDD65	1566	516	316	86	10	0	0	0	0	0	6	175	457	(9)	
	CDD50	9044	57	164	487	787	1149	1325	1478	1369	1081	756	313	78	(10)	
	CDD65	4892	0	8	104	347	684	875	1013	904	631	297	29	0	(11)	
	CDH74	74089	6	164	1449	4206	9793	14304	17226	14533	8570	3406	419	13	(12)	
(13)	CDH80	49370	0	36	589	2307	6287	10114	12776	10148	5250	1742	121	0	(13)	
(14)	Wind	WSAvg	13.5	7.3	9.8	9.0	11.3	13.5	19.7	22.8	22.9	17.6	12.1	8.5	7.6	(14)
(15) Precipitation	PrecAvg	2.0	0.6	0.4	0.6	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.2	(15)	
	PrecMax	4.5	1.1	1.6	2.2	0.8	0.3	0.1	0.0	0.0	0.0	0.1	0.4	1.3	(16)	
	PrecMin	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
	PrecStd	1.0	0.3	0.4	0.6	0.2	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.4	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.4	84.6	97.0	103.9	111.5	116.4	116.6	114.0	109.1	102.5	90.0	75.4	(19)	
		MCWB	53.4	58.0	61.5	66.6	67.5	69.7	69.5	69.3	66.6	64.7	61.5	54.0	(20)	
	2%	DB	69.9	79.0	91.0	100.0	108.0	113.1	114.6	111.1	105.7	98.2	82.8	71.0	(21)	
		MCWB	51.5	56.3	59.8	65.3	67.0	69.0	68.9	68.2	65.3	63.8	57.3	52.1	(22)	
	5%	DB	66.4	73.8	86.3	96.4	105.4	110.5	112.0	108.2	102.6	93.6	78.7	67.6	(23)	
		MCWB	49.7	53.2	59.3	64.1	66.4	68.2	68.4	66.9	64.3	62.0	55.4	50.2	(24)	
	10%	DB	62.5	69.9	82.3	92.8	102.0	107.6	109.5	105.7	100.1	89.7	74.8	64.0	(25)	
		MCWB	47.7	52.0	58.0	62.7	66.0	67.3	68.1	66.3	63.7	60.1	54.1	48.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.6	60.5	66.1	68.7	70.7	75.2	75.8	72.5	69.9	66.4	63.1	56.1	(27)	
		MCDB	68.5	77.2	81.7	98.3	103.5	101.0	104.2	107.0	101.8	97.2	80.1	71.6	(28)	
	2%	WB	53.6	58.3	63.2	66.7	69.0	72.0	72.6	70.5	67.7	64.4	60.2	53.3	(29)	
		MCDB	66.5	73.8	81.1	94.8	102.1	103.9	105.6	105.2	100.2	95.5	79.3	68.2	(30)	
	5%	WB	51.3	55.8	61.1	65.3	67.7	70.0	70.9	69.1	65.9	62.8	57.6	51.2	(31)	
		MCDB	63.5	69.9	80.8	91.8	99.4	104.5	106.2	103.6	99.1	91.7	74.7	65.4	(32)	
	10%	WB	48.9	53.5	59.3	63.9	66.6	68.6	69.5	67.5	64.2	61.0	55.2	49.2	(33)	
		MCDB	60.3	67.5	78.4	88.6	97.7	103.5	105.3	101.9	97.1	88.1	72.4	61.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	25.6	25.9	28.0	27.6	27.0	25.5	23.4	22.8	25.8	27.9	26.6	26.1	(35)	
		MCDBR	30.8	31.7	34.4	32.5	31.5	29.8	25.7	24.4	30.4	32.5	31.6	30.3	(36)	
		MCWBR	17.5	15.8	14.2	10.8	9.9	10.3	9.0	8.9	12.1	13.7	15.3	16.5	(37)	
	5% WB	MCDBR	26.8	27.1	28.9	29.5	28.1	26.4	23.4	23.1	28.7	30.2	27.5	27.8	(38)	
		MCWBR	15.8	14.1	12.1	10.0	8.9	9.8	9.1	9.4	11.7	13.1	14.1	15.4	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.368	0.421	0.476	0.528	0.537	0.507	0.507	0.477	0.425	0.425	0.390	0.358	(40)	
	taud		2.162	2.005	1.862	1.781	1.776	1.829	1.835	1.898	2.002	2.000	2.107	2.201	(41)	
	Ebn at Noon		266	261	255	247	246	252	251	258	266	255	255	263	(42)	
	Edh at Noon		39	50	62	70	71	67	66	62	53	50	41	36	(43)	
(44)	RadAvg		1115	1363	1728	2093	2362	2541	2417	2286	2036	1636	1244	1059	(44)	
(45)	RadStd		62	82	89	75	59	67	77	73	41	41	49	56	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page