

ZABOL, Iran, Islamic Republic ofWMO: **408290**Lat: **31.0891N**Lon: **61.5431E**Elev: **489**StdP: **95.59**Time Zone: **3.50 (IRN)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.8	-0.9	-16.2	1.0	7.1	-14.0	1.2	7.4	13.2	6.2	12.1	7.2	3.5	330	0.634

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.0	45.2	20.5	44.1	20.1	42.9	19.8	22.4	40.6	21.5	40.6	20.7	40.0	6.3	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.0	12.0	29.9	14.3	10.8	28.9	13.3	10.1	28.4	68.4	40.5	64.8	40.9	62.2	40.2	27.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.1	16.0	14.3	DB	-5.8	47.7	1.9	0.8	-7.2	48.2	-8.3	48.7	-9.4	49.1	-10.7	49.7	
(5)			WB	-8.0	23.3	2.2	1.7	-9.5	24.5	-10.8	25.5	-12.0	26.5	-13.6	27.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	23.4	9.1	12.2	18.7	24.6	30.6	34.5	36.5	34.5	30.0	23.6	15.6	10.1	(6)
(7)		DBStd	10.20	3.72	4.78	4.25	4.02	2.86	2.40	2.08	2.33	2.84	3.66	3.93	3.41	(7)
(8)		HDD10.0	135	59	29	2	0	0	0	0	0	0	0	5	39	(8)
(9)		HDD18.3	870	287	176	48	6	0	0	0	0	0	3	97	254	(9)
(10)		CDD10.0	5024	32	91	271	437	638	736	821	761	601	420	174	43	(10)
(11)		CDD18.3	2718	0	4	58	193	380	486	563	502	351	165	16	0	(11)
(12)		CDH23.3	41161	3	91	805	2337	5441	7947	9570	8074	4761	1892	233	7	(12)
(13)		CDH26.7	27428	0	20	327	1282	3493	5619	7098	5638	2917	968	67	0	(13)
(14)	Wind	WSAvg	6.0	3.3	4.4	4.0	5.0	6.0	8.8	10.2	10.2	7.9	5.4	3.8	3.4	(14)
(15)	Precipitation	PrecAvg	52	14	10	14	4	1	0	0	0	0	2	6		(15)
(16)		PrecMax	114	29	41	56	20	7	2	0	0	0	3	10	34	(16)
(17)		PrecMin	10	1	0	0	0	0	0	0	0	0	0	0	0	(17)
(18)		PrecStd	26	8	11	16	6	2	0	0	0	0	1	3	9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.6	29.2	36.1	40.0	44.2	46.9	47.0	45.6	42.8	39.2	32.2	24.1	(19)
(20)			MCWB	11.9	14.4	16.4	19.2	19.7	21.0	20.8	20.7	19.2	18.2	16.4	12.2	(20)
(21)		2%	DB	21.1	26.1	32.8	37.8	42.2	45.1	45.9	44.0	41.0	36.8	28.2	21.7	(21)
(22)			MCWB	10.8	13.5	15.5	18.5	19.4	20.6	20.5	20.1	18.5	17.7	14.1	11.2	(22)
(23)		5%	DB	19.1	23.2	30.1	35.8	40.8	43.6	44.4	42.3	39.2	34.2	26.0	19.8	(23)
(24)			MCWB	9.8	11.8	15.2	17.9	19.1	20.1	20.2	19.4	18.0	16.7	13.0	10.1	(24)
(25)		10%	DB	17.0	21.0	27.9	33.8	38.9	42.0	43.1	41.0	37.8	32.1	23.8	17.8	(25)
(26)			MCWB	8.7	11.1	14.4	17.1	18.9	19.6	20.0	19.1	17.6	15.6	12.3	9.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.7	15.8	19.0	20.4	21.5	24.0	24.3	22.5	21.1	19.1	17.3	13.4	(27)
(28)			MCDWB	20.3	25.1	27.6	36.8	39.7	38.3	40.1	41.7	38.8	36.2	26.7	22.0	(28)
(29)		2%	WB	12.0	14.6	17.3	19.3	20.5	22.2	22.5	21.4	19.8	18.0	15.6	11.9	(29)
(30)			MCDWB	19.2	23.2	27.3	34.9	38.9	39.9	40.9	40.6	37.9	35.3	26.3	20.1	(30)
(31)		5%	WB	10.7	13.2	16.2	18.5	19.8	21.1	21.6	20.6	18.8	17.1	14.2	10.7	(31)
(32)			MCDWB	17.5	21.0	27.1	33.2	37.4	40.3	41.2	39.8	37.3	33.2	23.7	18.5	(32)
(33)		10%	WB	9.4	11.9	15.1	17.7	19.2	20.3	20.8	19.7	17.9	16.1	12.9	9.6	(33)
(34)			MCDWB	15.7	19.7	25.8	31.4	36.5	39.7	40.7	38.8	36.2	31.2	22.4	16.5	(34)
(35)	Mean Daily Temperature Range	MDBR		14.2	14.4	15.6	15.4	15.0	14.2	13.0	12.7	14.4	15.5	14.8	14.5	(35)
(36)		5% DB	MCDBR	17.1	17.6	19.1	18.0	17.5	16.5	14.3	13.5	16.9	18.0	17.5	16.8	(36)
(37)			MCWBR	9.7	8.8	7.9	6.0	5.5	5.7	5.0	5.0	6.7	7.6	8.5	9.2	(37)
(38)		5% WB	MCDWB	14.9	15.1	16.0	16.4	15.6	14.7	13.0	12.8	15.9	16.8	15.3	15.5	(38)
(39)			MCWBR	8.8	7.9	6.7	5.6	4.9	5.5	5.1	5.2	6.5	7.3	7.8	8.6	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.368	0.421	0.476	0.528	0.537	0.507	0.507	0.477	0.425	0.425	0.390	0.358	(40)
(41)		taud		2.162	2.005	1.862	1.781	1.776	1.829	1.835	1.898	2.002	2.000	2.107	2.201	(41)
(42)		Ebn at Noon		838	822	804	779	774	794	792	812	840	805	803	828	(42)
(43)		Edh at Noon		123	159	196	221	224	211	209	194	168	157	129	113	(43)
(44)	All-Sky Solar Radiation	RadAvg		3.51	4.30	5.45	6.60	7.45	8.01	7.62	7.21	6.42	5.16	3.92	3.34	(44)
(45)		RadStd		0.20	0.26	0.28	0.24	0.18	0.21	0.24	0.23	0.13	0.13	0.15	0.18	(45)