

ABADAN, Iran, Islamic Republic of

WMO: 408310

Lat: 30.3772N

Lon: 48.2143E

Elev: 20

StdP: 14.69

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	39.4	42.5	19.8	14.9	66.0	24.3	18.4	67.5	22.5	62.4	19.4	61.5	3.0	270	0.470

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	29.8	118.8	72.8	116.9	72.6	115.0	72.0	84.1	95.3	81.9	95.1	79.1	96.7	10.8	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.9	166.3	90.4	78.6	148.4	90.4	74.9	130.8	89.1	48.5	94.9	45.9	93.8	42.8	95.9	90.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.3	20.4	17.9	35.4	122.4	3.7	1.8	32.7	123.6	30.6	124.7	28.5	125.6	25.8	126.9		
(5)			32.5	86.6	3.7	2.6	29.8	88.4	27.7	90.0	25.6	91.4	22.9	93.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	79.8	55.8	60.5	69.2	79.0	90.8	97.7	100.4	99.9	93.0	83.3	67.9	58.7
	DBStd	16.86	5.46	5.68	5.46	5.61	4.96	3.57	3.29	2.99	4.30	5.34	6.59	5.86
	HDD50	22	14	3	0	0	0	0	0	0	0	0	0	5
	HDD65	701	288	143	21	1	0	0	0	0	0	0	43	205
	CDD50	10891	193	297	595	869	1266	1432	1561	1545	1290	1031	536	276
	CDD65	6095	2	17	151	420	801	982	1096	1080	840	566	129	11
	CDH74	96197	4	93	1339	4770	12664	17243	19568	18898	13329	7101	1128	60
	CDH80	67845	0	7	433	2396	8561	12957	15113	14447	9383	4191	354	3
Wind	WSAvg	7.1	5.6	6.7	7.1	7.4	7.7	10.5	9.7	7.8	7.1	5.5	5.0	5.3
Precipitation	PrecAvg	6.1	1.4	0.6	0.7	0.5	0.1	0.0	0.0	0.0	0.0	0.2	0.8	1.5
	PrecMax	11.3	4.7	2.5	3.3	2.7	1.0	1.1	0.5	0.0	0.0	3.0	3.5	4.6
	PrecMin	2.8	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	2.0	1.0	0.6	0.9	0.7	0.2	0.2	0.1	0.0	0.0	0.6	0.9	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.8	80.7	95.1	103.6	114.6	120.0	122.0	120.6	116.9	107.6	91.8	79.0
		MCWB	59.2	59.6	63.7	66.2	71.3	71.7	73.4	73.1	72.3	69.5	66.7	59.7
	2%	DB	70.7	76.9	88.2	98.4	110.8	116.8	119.3	118.6	113.4	103.9	87.7	75.3
		MCWB	58.2	57.9	61.4	65.6	69.7	71.3	72.8	73.3	71.5	69.3	64.5	60.4
	5%	DB	68.1	73.7	84.3	95.0	107.7	114.8	116.8	116.8	111.2	100.7	84.1	72.2
		MCWB	57.5	56.8	60.1	64.9	69.0	70.5	72.5	73.3	70.9	68.2	63.8	60.1
	10%	DB	65.8	71.3	80.9	91.5	105.0	112.6	114.8	114.8	108.2	98.0	80.6	69.6
		MCWB	56.5	56.2	59.1	64.2	68.5	69.9	72.1	72.9	70.0	67.9	63.9	59.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	64.9	64.7	68.3	72.8	76.0	80.1	85.0	87.3	85.1	81.0	75.3	68.3
		MCDB	69.2	72.1	79.7	88.5	94.7	97.8	96.1	95.2	93.6	88.5	80.9	72.8
	2%	WB	62.8	62.9	65.9	70.3	73.8	76.4	82.4	84.9	82.1	78.2	72.1	65.7
		MCDB	66.9	69.7	77.7	86.2	96.8	102.1	95.2	95.5	92.3	86.0	80.4	70.3
	5%	WB	60.5	61.1	64.2	68.7	72.3	73.8	79.2	83.0	79.0	76.4	69.0	63.5
		MCDB	65.1	68.0	76.8	85.0	96.8	105.1	99.5	96.2	94.0	85.0	78.5	68.4
	10%	WB	58.4	59.3	62.5	67.3	70.9	72.0	76.1	80.2	75.0	73.9	65.9	61.1
		MCDB	63.2	66.5	75.5	84.0	96.2	105.8	105.1	99.2	97.2	84.8	76.3	67.0
Mean Daily Temperature Range	5% DB	MDBR	17.5	19.1	21.9	22.6	25.6	29.3	29.8	31.2	31.7	27.8	22.5	19.0
		MCDBR	19.4	21.7	26.4	26.8	29.1	31.5	31.7	32.9	33.6	31.3	26.2	22.4
		MCWBR	10.2	8.8	8.2	7.5	8.3	8.8	9.3	10.3	10.1	10.3	10.7	11.5
	5% WB	MCDBR	13.9	15.1	20.0	21.0	25.2	29.8	29.3	29.3	29.0	22.8	18.8	14.5
MCWBR		9.7	9.0	8.8	8.1	8.7	9.8	11.4	12.5	12.5	11.2	10.3	10.2	
Clear-Sky Solar Irradiance	taub		0.490	0.529	0.587	0.681	0.674	0.612	0.662	0.612	0.548	0.568	0.525	0.491
	taud		1.879	1.793	1.661	1.537	1.541	1.617	1.554	1.642	1.757	1.735	1.823	1.889
	Ebn at Noon		223	228	226	211	214	227	215	224	233	214	210	215
	Edh at Noon		53	63	77	90	90	83	88	80	69	66	56	50
All-Sky Solar Radiation	RadAvg		1058	1358	1741	1920	2246	2527	2406	2267	2000	1553	1150	989
	RadStd		72	80	75	101	108	65	64	56	58	62	87	91

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	+1.35	N/A	N/A	+1.73	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)	+0.52	N/A	N/A	+0.79	N/A	N/A	N/A	N/A	+153	+149

Nomenclature: See separate page