

AGHAJARI, Iran, Islamic Republic of

WMO: 408330

Lat: 30.7429N

Lon: 49.6873E

Elev: 89

StdP: 14.65

Time Zone: 3.50 (IRN)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	39.0	41.5	12.5	10.5	98.4	19.3	14.5	86.5	27.5	65.5	23.5	65.7	3.2	330	0.500

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.0	119.4	72.6	117.1	72.1	115.2	71.6	83.5	97.8	81.3	98.3	78.9	100.5	13.7	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.4	158.1	92.0	76.7	139.7	93.7	72.6	121.4	93.1	47.7	96.8	45.3	98.3	42.5	100.0	93.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.1	22.6	19.8	33.8	122.3	3.1	1.8	31.7	123.6	29.9	124.7	28.1	125.7	25.9	127.0
			31.9	86.5	3.1	2.5	29.6	88.3	27.8	89.8	26.0	91.2	23.8	93.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	79.7	56.2	60.7	69.2	79.1	90.7	97.1	100.2	99.4	92.7	83.1	68.2	58.9	(6)
(7)		DBStd	16.66	6.18	6.35	5.86	5.99	4.69	3.38	2.85	2.89	4.39	5.32	6.57	5.95	(7)
(8)		HDD50	27	17	4	0	0	0	0	0	0	0	0	0	6	(8)
(9)		HDD65	693	278	146	25	1	0	0	0	0	0	0	41	202	(9)
(10)		CDD50	10876	209	302	595	874	1261	1413	1555	1532	1282	1026	546	281	(10)
(11)		CDD65	6066	5	24	155	424	796	963	1090	1067	832	561	137	12	(11)
(12)		CDH74	98942	30	199	1676	5319	13110	17280	19892	18982	13494	7476	1387	97	(12)
(13)		CDH80	70284	2	28	605	2876	9067	13039	15431	14534	9606	4580	511	5	(13)
(14)	Wind	WSAvg	8.0	6.9	7.9	8.5	9.0	9.4	9.9	9.5	8.3	7.8	7.0	6.0	6.3	(14)
(15)	Precipitation	PrecAvg	9.6	2.6	1.1	1.2	0.5	0.1	0.0	0.0	0.0	0.0	0.3	1.2	2.5	(15)
(16)		PrecMax	14.4	5.8	4.4	3.6	3.2	1.0	0.0	0.0	0.1	0.0	2.5	8.6	6.7	(16)
(17)		PrecMin	5.2	0.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	(17)
(18)		PrecStd	2.6	1.5	1.1	1.0	0.8	0.2	0.0	0.0	0.0	0.0	0.7	1.9	1.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.3	84.0	96.8	104.3	114.8	120.5	122.0	120.5	116.8	107.6	93.3	80.5	(19)
(20)		0.4%	MCWB	58.4	59.1	62.4	67.0	70.0	72.0	73.0	73.7	72.6	68.7	66.9	60.3	(20)
(21)		2%	DB	73.3	79.2	91.0	100.5	111.3	118.2	119.9	118.6	113.3	104.1	89.7	76.8	(21)
(22)		2%	MCWB	57.6	58.2	61.6	65.7	69.1	71.6	72.9	72.8	71.7	68.7	64.0	59.9	(22)
(23)		5%	DB	70.0	75.7	86.1	96.9	109.0	115.4	117.5	116.7	111.1	101.8	86.1	73.3	(23)
(24)		5%	MCWB	57.4	57.3	60.4	64.9	68.9	70.1	72.0	73.0	71.0	67.8	63.5	59.1	(24)
(25)		10%	DB	67.7	73.3	82.6	93.2	106.0	113.2	115.2	114.7	108.7	98.7	82.3	70.0	(25)
(26)		10%	MCWB	56.5	57.0	59.2	64.5	67.8	69.3	71.5	72.9	70.1	67.3	62.5	59.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.8	65.0	68.0	71.0	75.1	79.5	86.0	86.2	84.8	77.4	72.0	66.4	(27)
(28)		0.4%	MCDWB	69.7	73.3	80.1	92.0	102.0	98.4	98.4	97.0	96.0	90.5	84.2	72.2	(28)
(29)		2%	WB	61.9	62.8	66.1	69.5	72.7	76.2	81.7	84.0	82.4	75.0	69.2	63.9	(29)
(30)		2%	MCDWB	68.5	70.4	79.2	90.2	101.0	104.9	100.6	98.6	95.4	89.5	80.8	70.5	(30)
(31)		5%	WB	60.0	60.9	64.4	68.1	71.1	73.9	78.7	81.9	79.8	73.0	66.9	61.9	(31)
(32)		5%	MCDWB	66.7	71.0	77.5	88.0	100.5	107.7	103.5	97.9	96.7	89.4	79.6	68.9	(32)
(33)		10%	WB	58.2	59.1	62.4	66.8	69.9	72.1	76.1	79.6	76.7	70.8	64.7	60.2	(33)
(34)		10%	MCDWB	65.2	69.7	77.9	86.7	99.8	107.4	105.3	100.2	98.3	90.0	76.8	67.6	(34)
(35)	Mean Daily Temperature Range		MDBR	18.9	21.0	24.5	24.8	28.1	32.0	31.0	31.1	32.0	29.4	23.8	20.0	(35)
(36)		5% DB	MCDBR	21.4	23.9	29.6	29.4	32.1	34.7	33.5	33.2	33.3	32.0	28.7	24.1	(36)
(37)			MCWBR	11.0	10.1	10.8	9.3	10.2	10.6	10.6	11.7	12.6	12.5	12.6	12.0	(37)
(38)			5% WB	MCDBR	16.7	18.9	21.5	23.5	27.7	32.6	29.9	27.6	27.2	26.9	20.1	17.5
(39)		MCWBR		10.4	9.9	10.0	9.2	10.2	12.0	11.8	13.5	14.4	13.4	11.0	10.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.446	0.489	0.548	0.643	0.626	0.582	0.649	0.602	0.519	0.518	0.474	0.439	(40)	
(41)		taud	1.975	1.873	1.728	1.586	1.617	1.678	1.586	1.674	1.820	1.828	1.929	2.009	(41)	
(42)		Ebn at Noon	237	240	235	219	225	234	218	226	240	227	226	232	(42)	
(43)		Edh at Noon	48	58	71	85	83	78	85	77	64	60	49	44	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1028	1333	1717	1927	2323	2602	2461	2320	2043	1594	1150	961	(44)	
(45)		RadStd	70	97	86	123	90	54	53	51	46	59	87	94	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	+0.54	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page