

AGHAJARI, Iran, Islamic Republic of

WMO: 408330

Lat: 30.7429N

Lon: 49.6873E

Elev: 27

StdP: 101.00

Time Zone: 3.50 (IRN)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.9	5.3	-10.8	1.5	36.9	-7.1	2.1	30.3	12.3	18.6	10.5	18.7	1.4	330	0.500

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.2	48.5	22.6	47.3	22.3	46.2	22.0	28.6	36.6	27.4	36.8	26.0	38.0	6.1	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.9	22.6	33.4	24.8	20.0	34.3	22.6	17.3	34.0	93.1	36.0	87.4	36.9	81.0	37.8	34.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.7	10.1	8.8	1.0	50.2	1.7	1.0	-0.2	50.9	-1.2	51.5	-2.1	52.1	-3.4	52.8		
(5)			-0.1	30.3	1.7	1.4	-1.3	31.3	-2.3	32.1	-3.3	32.9	-4.6	33.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	26.5	13.4	15.9	20.7	26.2	32.6	36.2	37.9	37.5	33.7	28.4	20.1	14.9	(6)
(7)		DBStd	9.25	3.43	3.53	3.25	3.33	2.60	1.88	1.58	1.61	2.44	2.95	3.65	3.31	(7)
(8)		HDD10.0	15	9	2	0	0	0	0	0	0	0	0	0	3	(8)
(9)		HDD18.3	385	154	81	14	1	0	0	0	0	0	0	23	112	(9)
(10)		CDD10.0	6042	116	168	331	486	701	785	864	851	712	570	303	156	(10)
(11)		CDD18.3	3370	3	13	86	236	442	535	606	593	462	312	76	7	(11)
(12)		CDH23.3	54968	17	111	931	2955	7283	9600	11051	10546	7497	4153	771	54	(12)
(13)		CDH26.7	39047	1	16	336	1598	5037	7244	8573	8074	5337	2544	284	3	(13)
(14)	Wind	WSAvg	3.6	3.1	3.5	3.8	4.0	4.2	4.4	4.2	3.7	3.5	3.1	2.7	2.8	(14)
(15)	Precipitation	PrecAvg	245	65	28	30	13	2	0	0	0	8	31	63	(15)	
(16)		PrecMax	366	148	113	92	82	26	1	1	2	1	64	219	169	(16)
(17)		PrecMin	131	18	0	0	0	0	0	0	0	0	0	0	3	(17)
(18)		PrecStd	65	39	28	25	20	5	0	0	0	0	17	47	48	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.2	28.9	36.0	40.2	46.0	49.2	50.0	49.2	47.1	42.0	34.0	26.9	(19)
(20)		MCWB	14.6	15.1	16.9	19.5	21.1	22.2	22.8	23.2	22.6	20.4	19.4	15.7	(20)	
(21)		2%	DB	22.9	26.2	32.8	38.1	44.1	47.9	48.9	48.1	45.2	40.1	32.0	24.9	(21)
(22)		MCWB	14.2	14.6	16.5	18.7	20.6	22.0	22.7	22.6	22.1	20.4	17.8	15.5	(22)	
(23)		5%	DB	21.1	24.3	30.1	36.0	42.8	46.3	47.5	47.0	43.9	38.8	30.1	22.9	(23)
(24)		MCWB	14.1	14.1	15.8	18.3	20.5	21.2	22.2	22.8	21.7	19.9	17.5	15.1	(24)	
(25)		10%	DB	19.8	22.9	28.1	34.0	41.1	45.1	46.2	45.9	42.6	37.1	28.0	21.1	(25)
(26)		MCWB	13.6	13.9	15.1	18.0	19.9	20.7	22.0	22.7	21.2	19.6	16.9	15.1	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.7	18.4	20.0	21.7	24.0	26.4	30.0	30.1	29.3	25.2	22.2	19.1	(27)
(28)		MDCB	20.9	22.9	26.7	33.4	38.9	36.9	36.9	36.1	35.6	32.5	29.0	22.3	(28)	
(29)		2%	WB	16.6	17.1	19.0	20.8	22.6	24.5	27.6	28.9	28.0	23.9	20.6	17.7	(29)
(30)		MDCB	20.3	21.3	26.2	32.3	38.3	40.5	38.1	37.0	35.2	32.0	27.1	21.4	(30)	
(31)		5%	WB	15.6	16.1	18.0	20.1	21.7	23.3	25.9	27.7	26.6	22.8	19.4	16.6	(31)
(32)		MDCB	19.3	21.7	25.3	31.1	38.1	42.0	39.7	36.6	36.0	31.9	26.4	20.5	(32)	
(33)		10%	WB	14.5	15.1	16.9	19.3	21.0	22.3	24.5	26.4	24.8	21.6	18.2	15.7	(33)
(34)		MDCB	18.4	20.9	25.5	30.4	37.7	41.9	40.7	37.9	36.9	32.2	24.9	19.8	(34)	
(35)	Mean Daily Temperature Range	MDBR	10.5	11.7	13.6	13.8	15.6	17.8	17.2	17.3	17.8	16.4	13.2	11.1	(35)	
(36)		5% DB	MCDBR	11.9	13.3	16.4	16.3	17.8	19.3	18.6	18.5	18.5	17.8	16.0	13.4	(36)
(37)		MCWBR	6.1	5.6	6.0	5.2	5.7	5.9	5.9	6.5	7.0	6.9	7.0	6.7	(37)	
(38)		5% WB	MCDWR	9.3	10.5	11.9	13.1	15.4	18.1	16.6	15.4	15.1	14.9	11.2	9.7	(38)
(39)		MCWBR	5.8	5.5	5.5	5.1	5.6	6.7	6.6	7.5	8.0	7.5	6.1	5.8	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.446	0.489	0.548	0.643	0.626	0.582	0.649	0.602	0.519	0.518	0.474	0.439	(40)	
(41)		taud	1.975	1.873	1.728	1.586	1.617	1.678	1.586	1.674	1.820	1.828	1.929	2.009	(41)	
(42)		Ebn at Noon	748	756	742	691	708	737	686	713	757	717	712	731	(42)	
(43)		Edh at Noon	150	182	225	269	263	246	269	244	203	188	156	139	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.24	4.20	5.41	6.08	7.32	8.20	7.76	7.32	6.44	5.02	3.63	3.03	(44)	
(45)		RadStd	0.22	0.30	0.27	0.39	0.28	0.17	0.17	0.16	0.15	0.19	0.27	0.30	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (7 neighbors)	+0.30	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page