

GACHSARAN, Iran, Islamic Republic ofWMO: **408350**Lat: **30.3466N**Lon: **50.8198E**Elev: **2293**StdP: **13.52**Time Zone: **3.50 (IRN)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.1	37.5	5.1	7.8	77.1	11.2	10.6	84.8	16.3	54.1	14.0	55.0	0.3	270	0.415

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	28.2	111.9	65.2	110.3	65.1	108.3	65.0	74.4	95.8	72.1	96.0	70.1	96.7	7.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.8	111.1	88.9	64.0	97.3	87.8	60.6	86.0	82.7	39.7	94.7	37.4	96.0	35.6	96.5	83.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	17.4	14.5	12.7	DB	30.5	115.5	2.0	2.0	29.1	117.0	27.9	118.2	26.7	119.3	25.3	120.8
(5)				WB	28.3	77.8	2.4	2.2	26.6	79.4	25.2	80.7	23.9	81.9	22.2	83.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	73.8	51.4	55.0	62.3	71.1	83.1	90.9	94.5	93.7	87.0	77.0	63.4	55.1
	DBStd	16.10	5.29	5.76	5.90	5.69	4.81	3.31	3.11	2.76	3.71	4.58	5.77	4.80
	HDD50	78	47	18	2	0	0	0	0	0	0	0	0	11
	HDD65	1244	423	281	122	13	0	0	0	0	0	0	99	306
	CDD50	8769	89	159	382	634	1028	1226	1379	1354	1111	836	401	170
	CDD65	4460	0	2	37	196	563	776	914	889	661	371	50	1
	CDH74	72319	3	29	575	2447	8451	13514	16264	15414	10226	4761	595	40
	CDH80	48324	0	1	160	1025	5227	9528	11866	11076	6767	2538	133	3
Wind	WSAvg	3.1	2.2	2.7	3.0	3.5	3.9	4.4	4.3	3.8	3.3	2.5	2.0	1.8
Precipitation	PrecAvg	28.8	7.7	4.0	4.1	2.1	0.3	0.0	0.1	0.1	0.1	0.3	3.0	6.6
	PrecMax	42.7	20.0	10.2	11.9	4.4	2.0	0.2	0.3	0.5	1.0	1.5	12.5	20.6
	PrecMin	16.6	1.9	0.1	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	5.6	3.4	2.4	2.7	1.2	0.5	0.0	0.1	0.2	0.2	0.4	2.8	4.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.0	77.4	90.6	97.1	107.4	112.3	115.0	113.8	109.3	100.0	86.8	78.6
		MCWB	51.2	54.7	57.2	60.3	62.9	64.5	66.3	64.7	64.1	61.5	57.3	54.0
	2%	DB	68.3	73.4	84.3	93.1	103.6	110.0	112.9	111.5	106.0	97.0	83.9	73.3
		MCWB	50.3	53.9	56.6	60.3	62.5	63.8	66.2	64.8	64.4	60.6	56.1	52.1
	5%	DB	65.2	70.2	80.2	89.4	100.6	107.9	110.9	109.7	103.9	94.7	80.7	69.7
		MCWB	49.9	52.4	55.7	59.1	61.7	63.7	65.8	65.0	63.8	60.4	55.5	51.4
	10%	DB	62.4	67.6	76.6	86.0	98.3	105.9	108.7	107.8	101.9	91.7	77.1	66.3
		MCWB	49.7	52.0	54.7	58.2	61.2	63.3	65.9	65.4	63.5	59.9	55.0	51.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.5	59.2	62.6	64.7	67.6	71.4	76.3	77.0	76.8	69.7	63.8	60.0
		MCDB	62.6	67.5	69.6	80.8	95.5	98.2	100.3	94.3	89.5	83.0	71.9	65.7
	2%	WB	55.7	56.8	60.3	62.9	65.1	68.3	73.6	74.5	72.9	66.3	61.6	57.4
		MCDB	61.0	65.5	70.0	79.8	94.0	100.2	100.0	95.3	90.3	85.4	70.9	65.3
	5%	WB	53.9	55.5	58.8	61.7	63.8	66.3	71.3	72.2	70.0	64.2	59.7	55.6
		MCDB	59.8	64.8	71.1	79.7	93.4	101.8	100.8	95.2	90.8	83.9	70.1	63.3
	10%	WB	51.9	54.0	57.2	60.6	62.8	64.9	69.2	70.1	67.5	62.5	58.1	54.0
		MCDB	59.2	63.5	72.4	79.3	92.2	101.5	100.3	96.8	93.0	84.3	70.0	61.7
Mean Daily Temperature Range	5% DB	MDBR	20.2	21.3	24.9	25.8	27.3	29.8	28.2	29.1	29.8	28.5	23.7	22.3
		MCDBR	25.2	26.0	30.6	30.1	30.2	32.6	30.8	31.1	31.2	30.9	28.7	28.2
		MCWBR	11.7	11.2	12.0	9.6	9.0	9.9	9.3	9.1	10.2	10.7	10.5	11.7
	5% WB	MCDBR	16.9	19.2	22.5	23.5	27.3	30.3	27.9	27.0	27.5	27.0	19.2	19.2
		MCWBR	10.0	9.9	11.2	9.0	8.5	10.4	11.0	10.4	11.7	10.6	9.2	9.6
Clear-Sky Solar Irradiance	taub	0.373	0.422	0.482	0.566	0.544	0.511	0.578	0.535	0.452	0.438	0.400	0.369	
	taud	2.176	2.024	1.857	1.708	1.762	1.831	1.716	1.807	1.976	2.001	2.112	2.201	
	Ebn at Noon	266	262	254	238	244	251	234	243	259	253	253	260	
	Edh at Noon	39	50	63	75	72	67	75	68	55	50	41	36	
All-Sky Solar Radiation	RadAvg	1041	1318	1741	1958	2399	2662	2501	2368	2111	1683	1193	998	
	RadStd	77	105	122	139	80	54	61	62	44	67	101	106	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (7 neighbors)	N/A	-2.25	N/A	+0.94	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page