

YASOGE, Iran, Islamic Republic of

WMO: 408360

Lat: 30.6979N

Lon: 51.5545E

Elev: 6027

StdP: 11.77

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.6	24.9	-2.6	6.0	62.0	2.8	7.9	58.3	18.3	44.6	15.1	46.3	0.8	90	0.444

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	29.2	97.2	59.1	95.4	58.3	93.5	57.6	64.3	88.2	62.1	87.6	60.3	86.4	7.3	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.4	82.0	77.5	51.9	71.9	73.0	49.8	66.4	68.3	32.8	88.7	31.0	87.4	29.5	86.3	72.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.1	15.1	12.7	15.9	101.2	4.9	1.8	12.3	102.5	9.5	103.6	6.8	104.6	3.2	105.9		
			13.6	67.6	4.2	2.8	10.6	69.6	8.2	71.2	5.8	72.7	2.8	74.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	59.6	38.7	42.2	49.5	56.2	66.3	75.7	80.5	78.7	71.8	62.0	49.5	42.2
	DBStd	15.19	5.72	5.32	5.39	4.87	4.67	3.38	2.98	2.78	3.28	4.19	5.41	5.43
	HDD50	975	350	221	74	8	0	0	0	0	0	0	75	247
	HDD65	3518	814	638	481	264	41	0	0	0	0	109	464	707
	CDD50	4463	1	3	58	195	506	772	945	889	655	373	61	5
	CDD65	1532	0	0	0	2	81	323	480	424	205	17	0	0
	CDH74	20574	0	0	13	74	1351	4422	6166	5373	2668	506	1	0
	CDH80	10495	0	0	0	4	396	2379	3519	2973	1157	67	0	0
Wind	WSAvg	3.7	3.0	3.9	4.5	4.4	4.2	3.8	3.9	3.8	3.5	3.5	3.0	2.4
Precipitation	PrecAvg	36.1	8.0	6.1	6.2	3.3	0.5	0.0	0.1	0.1	0.0	0.4	3.5	8.0
	PrecMax	53.9	20.7	13.3	15.2	8.0	2.2	0.3	0.4	0.7	0.4	3.0	14.9	30.6
	PrecMin	17.8	2.5	0.8	0.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1
	PrecStd	8.3	3.7	3.7	4.0	2.2	0.7	0.1	0.1	0.2	0.1	0.7	3.4	5.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	61.4	64.5	75.4	80.4	90.0	97.8	100.7	98.7	93.3	84.4	73.1	65.5
		MCWB	42.7	44.8	50.2	51.3	54.7	58.2	61.3	61.2	56.2	54.0	46.9	44.3
	2%	DB	57.3	60.5	70.0	75.6	87.2	95.4	98.5	96.6	91.1	82.0	69.6	60.4
		MCWB	41.3	42.5	47.4	51.0	54.3	57.3	59.5	59.4	55.8	52.8	46.9	42.1
	5%	DB	53.4	56.9	66.0	73.0	84.4	93.4	96.6	94.8	89.3	79.4	66.3	56.9
		MCWB	39.9	41.1	45.4	50.2	53.3	56.6	58.9	58.3	55.4	51.5	45.6	41.1
	10%	DB	49.8	53.5	62.4	69.7	81.9	91.4	94.6	92.9	86.9	76.8	62.4	53.4
		MCWB	38.3	40.3	43.7	48.8	52.7	56.1	58.3	57.6	54.7	50.3	44.4	39.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.3	47.9	52.9	55.8	58.6	63.8	68.3	67.1	63.7	58.5	51.8	48.2
		MCDB	56.1	58.3	68.3	68.1	80.1	90.4	91.1	93.0	87.6	80.5	63.6	54.9
	2%	WB	43.9	45.6	49.9	53.9	56.7	61.1	64.9	64.0	59.4	55.2	49.9	45.3
		MCDB	50.7	54.1	60.8	68.2	78.7	89.4	88.4	87.5	82.3	76.8	59.7	53.2
	5%	WB	42.2	44.0	48.1	52.3	55.4	59.0	62.1	62.0	57.4	52.8	48.3	43.7
		MCDB	48.8	52.0	59.7	66.0	77.8	87.9	88.8	86.0	81.8	73.6	59.0	51.3
	10%	WB	40.3	42.3	46.3	51.1	54.3	57.4	60.4	60.1	55.8	51.2	46.6	42.2
		MCDB	47.2	49.5	56.7	64.1	76.4	86.9	87.4	85.2	81.9	71.3	57.9	49.9
Mean Daily Temperature Range	5% DB	MDBR	20.6	20.8	23.4	23.8	28.4	31.9	29.2	30.3	31.6	29.0	24.1	22.1
		MCDBR	26.3	26.8	29.8	29.1	32.1	33.5	31.7	32.0	32.6	31.7	29.8	27.9
		MCWBR	14.4	13.1	13.4	11.2	11.0	11.0	9.9	10.9	11.3	12.4	13.0	13.7
	5% WB	MCDBR	20.6	19.6	22.9	23.1	28.0	31.9	30.4	30.6	31.8	29.3	22.9	20.8
		MCWBR	12.9	11.1	12.5	10.4	10.3	12.1	11.4	12.3	13.1	12.8	11.0	11.6
Clear-Sky Solar Irradiance	taub	0.293	0.344	0.408	0.492	0.479	0.453	0.507	0.464	0.391	0.374	0.330	0.293	
	taud	2.370	2.203	1.995	1.814	1.872	1.946	1.834	1.934	2.118	2.146	2.291	2.395	
	Ebn at Noon	298	289	276	257	261	266	251	261	278	274	280	292	
	Edh at Noon	31	41	55	68	65	60	67	59	48	43	34	30	
All-Sky Solar Radiation	RadAvg	1005	1277	1734	1965	2402	2666	2489	2365	2129	1703	1201	981	
	RadStd	91	114	132	146	99	70	89	82	57	75	110	113	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	-2.25	N/A	+0.94	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page