

KERMAN, Iran, Islamic Republic of

WMO: 408410

Lat: 30.2496N

Lon: 56.9657E

Elev: 5736

StdP: 11.89

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 19.3	(c) 22.8	(d) -11.5	(e) 3.6	(f) 54.3	(g) -6.2	(h) 4.9	(i) 51.2	(j) 27.9	(k) 55.1	(l) 23.5	(m) 56.2	(n) 2.2	(o) 120	(p) 0.490

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 29.7	(c) 100.5	(d) 60.3	(e) 98.7	(f) 59.4	(g) 96.8	(h) 58.9	(i) 63.6	(j) 93.8	(k) 62.1	(l) 93.1	(m) 60.7	(n) 92.4	(o) 9.6	(p) 60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
51.7	70.6	71.4	48.9	63.5	70.2	46.6	58.1	67.9	31.9	93.6	30.7	93.1	29.6	92.5	69.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
23.2	19.7	16.8	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			11.1	103.4	5.3	1.9	7.3	104.8	4.2	105.9	1.2	107.0	-2.6	108.4
			8.9	65.6	4.1	2.6	5.9	67.5	3.5	69.1	1.2	70.5	-1.7	72.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.2	41.8	46.3	54.1	62.9	71.9	79.7	82.0	77.2	72.2	63.1	50.9	43.7	(6)
	DBStd	14.96	7.08	7.05	6.14	5.53	5.02	4.57	3.96	4.43	4.10	4.68	6.31	6.15	(7)
	HDD50	711	265	140	30	1	0	0	0	0	0	0	66	209	(8)
	HDD65	2869	720	522	338	103	6	0	0	0	4	93	423	660	(9)
	CDD50	5178	10	38	159	387	679	890	991	844	666	406	93	15	(10)
	CDD65	1861	0	0	2	40	220	440	526	379	220	34	0	0	(11)
	CDH74	30383	0	6	111	769	3338	6929	8190	6097	3798	1095	48	2	(12)
	CDH80	16297	0	0	20	166	1508	4089	4984	3418	1835	276	1	0	(13)
(14) Wind	WSAvg	6.7	5.8	7.3	8.1	7.9	7.6	7.5	7.8	7.4	6.2	5.3	4.8	4.6	(14)
(15) Precipitation	PrecAvg	5.2	0.9	1.1	1.1	0.6	0.2	0.0	0.1	0.1	0.0	0.1	0.3	0.7	(15)
	PrecMax	8.7	2.3	3.5	2.7	1.5	2.0	0.2	1.0	0.6	0.1	1.0	1.1	2.6	(16)
	PrecMin	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
	PrecStd	1.7	0.6	0.9	0.8	0.5	0.4	0.0	0.2	0.1	0.0	0.2	0.4	0.8	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.2	73.6	82.5	87.5	97.0	102.1	102.6	101.9	95.6	88.2	78.7	72.5	(19)
		MCWB	43.7	47.9	50.6	53.8	57.7	59.4	61.4	60.9	57.9	54.8	49.5	46.1	(20)
	2%	DB	64.6	68.3	76.8	84.4	93.4	100.2	100.8	98.4	93.4	85.9	75.1	66.4	(21)
		MCWB	43.1	46.0	48.7	53.1	56.6	59.4	60.8	60.1	56.7	54.3	49.2	43.9	(22)
	5%	DB	61.1	64.6	73.2	82.1	91.2	98.3	99.0	95.4	91.5	82.9	71.7	63.0	(23)
		MCWB	42.1	44.5	47.7	52.5	55.8	58.6	60.0	58.7	56.3	53.1	48.1	43.0	(24)
	10%	DB	57.4	61.1	69.7	78.9	88.0	95.5	97.1	93.3	89.6	80.5	68.0	60.0	(25)
		MCWB	40.8	42.7	46.3	51.4	55.1	57.7	59.5	58.1	55.8	52.1	46.8	42.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.3	50.5	53.4	57.0	60.4	63.0	66.3	65.2	61.9	57.8	53.5	49.3	(27)
		MCDB	59.1	64.7	69.8	77.5	88.8	93.7	96.5	93.1	91.6	83.3	73.1	61.7	(28)
	2%	WB	46.0	48.5	51.4	55.3	58.7	61.8	64.2	62.7	59.7	56.1	51.2	47.0	(29)
		MCDB	57.0	61.0	69.0	76.7	88.7	94.0	94.8	91.8	89.6	82.5	68.5	59.3	(30)
	5%	WB	44.3	46.7	49.8	54.0	57.3	60.4	62.7	61.2	58.1	54.6	49.4	45.3	(31)
		MCDB	56.1	58.6	67.0	75.9	86.4	93.4	94.1	91.6	88.1	80.8	66.8	58.1	(32)
	10%	WB	42.4	45.1	48.4	52.8	56.0	59.2	61.2	59.7	56.7	53.0	47.8	43.6	(33)
		MCDB	55.0	57.7	64.9	74.3	84.1	92.2	93.2	90.6	86.5	78.0	64.3	56.5	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	27.4	25.9	27.3	27.6	30.1	30.8	29.7	32.7	34.6	33.8	31.6	30.1	(35)
		MCDBR	33.7	31.1	33.0	31.8	33.5	32.6	32.1	33.1	36.1	36.3	36.3	36.7	(36)
	5% WB	MCWBR	18.0	15.5	15.1	12.9	12.8	12.6	12.7	13.4	16.4	17.3	18.8	19.9	(37)
		MCWBR	25.1	23.6	26.5	27.2	30.8	30.2	28.4	31.2	33.6	34.2	30.2	27.7	(38)
(40) Clear-Sky Solar Irradiance	taub		0.281	0.326	0.378	0.450	0.475	0.473	0.456	0.416	0.387	0.377	0.315	0.282	(40)
		taud	2.494	2.347	2.149	1.962	1.914	1.928	1.998	2.107	2.167	2.176	2.408	2.507	(41)
	Ebn at Noon		305	297	287	269	262	261	265	275	280	274	288	299	(42)
		Edh at Noon	28	36	47	59	62	61	56	50	45	42	30	27	(43)
(44) All-Sky Solar Radiation	RadAvg		1158	1388	1788	2062	2314	2544	2484	2405	2102	1711	1308	1115	(44)
	RadStd		93	107	116	117	112	106	75	92	68	70	74	91	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page