

SHIRAZ SHAHID DASTGHAIB INTL, Iran, Islamic Republic of

WMO: 408480

Lat: 29.539N

Lon: 52.589E

Elev: 1500

StdP: 84.56

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.1	-0.9	-16.0	1.1	18.3	-13.2	1.4	16.8	9.4	11.1	8.0	11.5	0.3	300	0.434

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.8	39.2	17.2	38.2	16.7	37.3	16.4	20.1	34.8	19.1	34.4	18.2	33.8	2.9	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.9	12.7	30.1	13.1	11.3	27.8	11.9	10.4	25.7	65.0	34.5	61.2	34.4	58.0	33.7	26.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.7	7.4	6.1	-4.6	40.8	1.7	1.0	-5.8	41.6	-6.8	42.2	-7.7	42.8	-9.0	43.5		
(5)			-6.2	21.1	1.5	2.2	-7.3	22.7	-8.2	24.0	-9.0	25.2	-10.1	26.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.6	6.7	9.1	12.8	17.6	23.4	27.9	30.3	29.1	25.2	19.8	12.5	8.2		
	DBStd	8.59	2.77	2.85	2.74	2.91	2.57	1.76	1.68	1.62	2.02	2.25	2.93	2.53		
	HDD10.0	237	107	46	7	0	0	0	0	0	0	0	10	67		
	HDD18.3	1343	362	259	171	48	2	0	0	0	0	12	175	314		
	CDD10.0	3373	4	20	95	227	414	538	629	591	456	303	85	11		
	CDD18.3	1438	0	0	1	26	157	288	371	333	206	57	1	0		
	CDH23.3	22001	0	0	41	359	2128	4516	5992	5165	2904	874	22	0		
	CDH26.7	12657	0	0	4	70	978	2728	3874	3207	1532	262	0	0		
(14) Wind	WSAvg	1.8	1.4	1.8	2.3	2.3	2.5	2.3	2.2	1.9	1.7	1.5	1.2	1.1		
(15) Precipitation	PrecAvg	362	93	69	57	29	5	0	0	1	0	5	33	69		
	PrecMax	662	248	212	147	115	40	3	2	11	1	30	108	300		
	PrecMin	137	13	5	4	0	0	0	0	0	0	0	0	0		
	PrecStd	111	56	54	40	27	10	1	1	2	0	8	38	72		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.8	21.2	27.0	30.2	36.2	39.2	40.9	40.0	37.0	32.0	25.2	20.8		
		MCWB	7.6	9.2	11.6	13.4	15.4	16.6	18.0	18.3	15.4	13.4	11.1	9.1		
	2%	DB	16.2	19.0	24.1	28.8	34.2	38.1	39.9	38.8	35.8	30.8	23.9	18.1		
		MCWB	6.7	8.4	10.4	13.1	14.8	16.0	17.6	17.2	15.3	13.1	10.3	8.1		
	5%	DB	14.9	17.1	22.0	27.1	33.0	37.1	39.0	37.8	34.9	29.7	22.0	16.2		
		MCWB	6.5	7.5	9.7	12.4	14.3	15.7	17.2	16.6	15.0	12.7	10.3	7.4		
	10%	DB	13.0	15.8	20.1	25.2	31.8	36.1	38.1	36.8	33.8	28.1	20.0	14.8		
		MCWB	5.7	7.1	9.0	11.8	13.9	15.4	16.8	16.5	14.7	12.3	9.5	7.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.1	11.5	13.6	15.2	16.9	20.4	21.5	21.4	18.6	14.7	13.2	11.3		
		MCDB	13.6	16.3	19.9	25.3	32.3	36.2	36.0	34.6	33.2	27.9	20.7	16.0		
	2%	WB	8.7	10.3	12.4	14.3	15.9	18.1	20.1	20.2	17.2	14.0	12.1	10.1		
		MCDB	13.2	14.9	18.4	24.6	31.3	34.6	35.5	34.1	32.0	27.6	19.1	14.2		
	5%	WB	7.7	9.4	11.4	13.5	15.2	17.0	19.2	19.2	16.2	13.4	11.2	9.1		
		MCDB	11.8	14.0	17.6	23.5	30.3	34.1	35.1	33.7	31.1	26.6	18.5	13.8		
	10%	WB	6.9	8.5	10.4	12.9	14.6	16.2	18.3	18.2	15.4	12.9	10.5	8.2		
		MCDB	11.1	13.3	17.4	22.4	29.3	33.5	34.7	32.8	30.5	25.7	17.6	12.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.9	12.3	13.5	13.9	15.4	16.6	15.8	16.1	17.1	16.5	14.0	12.8		
		MCDBR	14.9	14.9	16.6	15.9	17.3	17.7	16.8	16.8	17.6	17.6	16.5	15.4		
	5% WB	MCWBR	7.8	7.1	7.0	5.9	6.1	5.8	5.2	5.2	5.8	6.2	7.0	7.8		
		MCWBR	11.2	10.8	12.9	14.0	15.8	16.7	15.5	15.9	16.8	16.3	13.3	11.8		
(40) Clear-Sky Solar Irradiance	taub		0.314	0.366	0.421	0.495	0.482	0.470	0.524	0.481	0.412	0.382	0.342	0.310		
	taud		2.362	2.180	1.990	1.834	1.876	1.911	1.809	1.904	2.064	2.142	2.282	2.388		
	Ebn at Noon		920	892	861	810	820	825	780	811	858	861	876	907		
	Edh at Noon		102	135	174	211	203	195	216	194	159	138	110	95		
(44) All-Sky Solar Radiation	RadAvg		3.62	4.41	5.72	6.47	7.67	8.25	7.74	7.38	6.58	5.48	4.02	3.47		
	RadStd		0.28	0.35	0.41	0.38	0.29	0.21	0.20	0.22	0.18	0.21	0.29	0.30		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	-1.25	N/A	+0.52	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	N/A	-1.25	N/A	+0.52	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page