

SIRJAN, Iran, Islamic Republic of

WMO: 408510

Lat: 29.4707N

Lon: 55.6611E

Elev: 5705

StdP: 11.91

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.3	25.3	-1.0	6.4	38.7	3.0	7.9	40.6	25.9	54.9	22.4	49.8	1.9	0	0.461

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.6	99.7	62.3	98.1	61.6	96.3	60.7	65.8	91.8	64.5	91.4	63.2	90.7	9.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.6	84.6	81.4	53.7	75.9	82.2	50.9	68.4	79.3	34.0	92.2	32.8	91.1	31.8	90.4	70.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	22.9	19.8	17.3	DB	16.1	102.9	2.9	1.5	14.0	103.9	12.3	104.8	10.7	105.6	8.7	106.7
(5)				WB	13.1	67.6	2.7	1.5	11.2	68.7	9.7	69.6	8.2	70.4	6.3	71.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	64.2	43.2	47.3	55.1	63.5	73.1	82.4	84.9	81.3	75.6	64.9	52.7	45.3	(6)
(7)		DBStd	15.53	6.60	7.05	5.65	5.32	4.63	3.94	3.82	3.88	4.24	4.51	6.06	6.12	(7)
(8)		HDD50	580	226	122	19	1	0	0	0	0	0	0	42	170	(8)
(9)		HDD65	2612	675	495	310	89	2	0	0	0	0	59	371	611	(9)
(10)		CDD50	5759	16	47	175	405	717	973	1083	969	768	461	121	24	(10)
(11)		CDD65	2315	0	0	1	43	253	523	618	504	318	55	0	0	(11)
(12)		CDH74	31424	0	0	60	558	3149	7380	8818	6602	3982	858	17	0	(12)
(13)		CDH80	16669	0	0	6	89	1331	4331	5251	3650	1844	167	0	0	(13)
(14)	Wind	WSAvg	6.8	6.7	7.7	7.6	7.4	7.2	7.1	8.0	8.5	6.1	4.8	4.9	6.1	(14)
(15)	Precipitation	PrecAvg	5.7	1.2	1.1	1.2	0.6	0.2	0.0	0.1	0.0	0.0	0.1	0.4	0.7	(15)
(16)		PrecMax	10.6	3.3	5.7	3.3	3.6	2.1	0.2	0.4	0.7	0.2	1.0	1.2	4.9	(16)
(17)		PrecMin	1.9	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	2.4	0.9	1.2	1.0	0.7	0.4	0.0	0.1	0.2	0.0	0.2	0.4	1.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.9	71.6	79.9	85.4	94.9	100.7	102.3	100.8	95.4	87.0	76.3	71.5	(19)
(20)		0.4%	MCWB	44.3	49.3	50.5	55.0	58.3	62.0	63.8	62.9	59.3	56.1	50.8	48.9	(20)
(21)		2%	DB	62.5	67.0	74.6	82.7	91.9	99.1	100.2	97.8	92.9	84.1	73.2	65.2	(21)
(22)		2%	MCWB	44.4	46.7	49.1	54.1	57.3	61.4	63.0	62.0	59.0	55.1	49.6	45.6	(22)
(23)		5%	DB	59.2	63.5	71.3	80.1	89.8	97.4	98.6	95.6	91.1	81.7	70.2	62.0	(23)
(24)		5%	MCWB	42.6	45.1	48.0	53.4	57.1	60.7	62.1	60.7	58.4	54.3	48.9	43.6	(24)
(25)		10%	DB	55.9	60.2	68.1	77.3	87.5	95.6	97.0	93.5	89.1	79.1	66.8	58.8	(25)
(26)		10%	MCWB	41.3	43.7	47.0	52.3	56.5	59.8	61.2	59.7	57.7	53.2	47.7	42.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.5	50.8	54.0	57.3	60.7	66.1	67.0	68.2	63.2	58.3	53.3	49.5	(27)
(28)		0.4%	MCDWB	57.8	65.5	66.3	79.5	88.3	91.7	93.5	90.9	87.6	80.5	70.2	63.6	(28)
(29)		2%	WB	46.7	49.0	52.2	55.9	59.2	64.1	65.7	66.1	61.5	56.5	51.6	47.3	(29)
(30)		2%	MCDWB	56.1	60.6	64.4	77.6	87.5	93.0	93.8	89.0	87.8	80.7	67.7	59.8	(30)
(31)		5%	WB	44.8	47.5	50.6	55.0	58.2	62.7	64.6	64.3	60.1	55.2	50.3	45.8	(31)
(32)		5%	MCDWB	55.1	57.9	63.4	75.8	86.0	92.5	92.9	88.6	87.0	79.0	65.6	57.5	(32)
(33)		10%	WB	43.1	46.0	49.1	53.7	57.2	61.1	63.5	62.7	58.9	53.9	48.8	44.2	(33)
(34)		10%	MCDWB	53.5	56.4	63.0	72.8	84.4	92.4	91.9	88.3	86.0	76.9	63.4	56.0	(34)
(35)	Mean Daily Temperature Range		MDBR	23.5	22.5	23.7	23.9	26.0	26.2	23.6	25.3	28.0	29.0	27.1	26.9	(35)
(36)		5% DB	MCDBR	27.5	26.4	28.5	27.7	28.3	26.8	24.2	25.7	28.1	30.8	30.4	31.5	(36)
(37)			MCWBR	15.0	12.9	12.5	10.7	11.0	9.9	8.8	9.7	11.4	14.2	15.6	17.2	(37)
(38)			MCDBR	20.4	18.1	21.0	24.4	26.5	24.1	22.2	23.5	25.7	28.0	24.7	24.7	(38)
(39)		5% WB	MCWBR	12.2	9.5	9.8	9.5	10.4	8.9	8.0	8.6	10.9	12.9	12.9	13.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.282	0.328	0.376	0.438	0.446	0.464	0.488	0.441	0.395	0.362	0.307	0.279	(40)	
(41)		taud	2.458	2.309	2.127	1.968	1.955	1.921	1.891	2.009	2.113	2.198	2.397	2.476	(41)	
(42)		Ebn at Noon	305	297	288	273	270	263	257	268	278	280	292	301	(42)	
(43)		Edh at Noon	30	37	48	58	60	61	63	56	48	41	31	28	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1207	1431	1822	2075	2352	2493	2379	2341	2067	1728	1328	1155	(44)	
(45)		RadStd	80	109	118	110	82	107	85	104	66	55	70	84	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page