

SIRJAN, Iran, Islamic Republic of

WMO: 408510

Lat: 29.4707N

Lon: 55.6611E

Elev: 1739

StdP: 82.11

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.4	-3.7	-18.3	0.9	3.7	-16.1	1.1	4.8	11.6	12.7	10.0	9.9	0.8	0	0.461

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.1	37.6	16.9	36.7	16.4	35.7	15.9	18.8	33.2	18.0	33.0	17.4	32.6	4.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
13.7	12.1	27.5	12.0	10.8	27.9	10.5	9.8	26.3	61.3	33.4	58.4	32.8	56.0	32.5	21.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
10.2	8.9	7.7	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-8.8	39.4	1.6	0.8	-10.0	40.0	-10.9	40.4	-11.8	40.9	-13.0	41.5
			-10.5	19.8	1.5	0.8	-11.5	20.4	-12.4	20.9	-13.2	21.4	-14.3	22.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	17.9	6.2	8.5	12.8	17.5	22.8	28.0	29.4	27.4	24.2	18.3	11.5	7.4	(6)
(7)		DBStd	8.63	3.66	3.92	3.14	2.95	2.57	2.19	2.12	2.16	2.35	2.50	3.37	3.40	(7)
(8)		HDD10.0	322	126	68	11	1	0	0	0	0	0	23	94	(8)	
(9)		HDD18.3	1451	375	275	172	49	1	0	0	0	33	206	339	(9)	
(10)		CDD10.0	3199	9	26	97	225	398	541	602	538	427	256	67	13	(10)
(11)		CDD18.3	1286	0	0	1	24	141	291	343	280	177	31	0	0	(11)
(12)		CDH23.3	17458	0	0	33	310	1749	4100	4899	3668	2212	477	9	0	(12)
(13)		CDH26.7	9261	0	0	3	49	739	2406	2917	2028	1024	93	0	0	(13)
(14)	Wind	WSAvg	3.1	3.0	3.4	3.4	3.3	3.2	3.2	3.6	3.8	2.7	2.1	2.2	2.7	(14)
(15)	Precipitation	PrecAvg	146	31	27	31	15	5	1	2	1	2	10	18	(15)	
(16)		PrecMax	269	84	145	85	92	54	4	11	18	6	25	30	124	(16)
(17)		PrecMin	48	2	0	0	0	0	0	0	0	0	0	0	0	(17)
(18)		PrecStd	62	24	30	25	19	11	1	3	4	1	6	11	28	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.9	22.0	26.6	29.6	34.9	38.2	39.1	38.2	35.2	30.5	24.6	22.0	(19)
(20)			MCWB	6.8	9.6	10.3	12.8	14.6	16.7	17.6	17.2	15.2	13.4	10.4	9.4	(20)
(21)		2%	DB	16.9	19.4	23.7	28.2	33.3	37.3	37.9	36.6	33.8	29.0	22.9	18.4	(21)
(22)			MCWB	6.9	8.2	9.5	12.3	14.1	16.3	17.2	16.7	15.0	12.8	9.8	7.5	(22)
(23)		5%	DB	15.1	17.5	21.8	26.7	32.1	36.3	37.0	35.3	32.9	27.6	21.2	16.7	(23)
(24)			MCWB	5.9	7.3	8.9	11.9	14.0	15.9	16.7	16.0	14.7	12.4	9.4	6.4	(24)
(25)		10%	DB	13.3	15.7	20.1	25.2	30.9	35.4	36.1	34.2	31.7	26.2	19.4	14.9	(25)
(26)			MCWB	5.2	6.5	8.3	11.3	13.6	15.5	16.2	15.4	14.3	11.8	8.7	5.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.2	10.5	12.2	14.1	16.0	19.0	19.5	20.1	17.3	14.6	11.9	9.7	(27)
(28)			MCD B	14.3	18.6	19.0	26.4	31.3	33.2	34.2	32.7	30.9	27.0	21.2	17.6	(28)
(29)		2%	WB	8.2	9.5	11.2	13.3	15.1	17.8	18.7	18.9	16.4	13.6	10.9	8.5	(29)
(30)			MCD B	13.4	15.9	18.0	25.3	30.8	33.9	34.3	31.6	31.0	27.0	19.9	15.4	(30)
(31)		5%	WB	7.1	8.6	10.3	12.8	14.6	17.0	18.1	18.0	15.6	12.9	10.2	7.7	(31)
(32)			MCD B	12.9	14.4	17.4	24.3	30.0	33.6	33.8	31.4	30.6	26.1	18.7	14.2	(32)
(33)		10%	WB	6.1	7.8	9.5	12.1	14.0	16.2	17.5	17.1	14.9	12.2	9.3	6.8	(33)
(34)			MCD B	11.9	13.5	17.2	22.7	29.1	33.5	33.3	31.3	30.0	24.9	17.4	13.3	(34)
(35)	Mean Daily Temperature Range	MDBR	13.1	12.5	13.2	13.3	14.4	14.5	13.1	14.1	15.6	16.1	15.1	15.0	(35)	
(36)		5% DB	MCD BR	15.3	14.7	15.8	15.4	15.7	14.9	13.4	14.3	15.6	17.1	16.9	17.5	(36)
(37)			MCWBR	8.3	7.2	6.9	5.9	6.1	5.5	4.9	5.4	6.3	7.9	8.7	9.6	(37)
(38)		5% WB	MCD BR	11.3	10.1	11.7	13.6	14.7	13.4	12.3	13.0	14.3	15.5	13.7	13.7	(38)
(39)			MCWBR	6.8	5.3	5.4	5.3	5.8	4.9	4.4	4.8	6.1	7.2	7.2	7.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.282	0.328	0.376	0.438	0.446	0.464	0.488	0.441	0.395	0.362	0.307	0.279	(40)	
(41)		taud	2.458	2.309	2.127	1.968	1.955	1.921	1.891	2.009	2.113	2.198	2.397	2.476	(41)	
(42)		Ebn at Noon	963	936	907	860	850	830	809	845	876	884	922	950	(42)	
(43)		Edh at Noon	93	118	152	184	188	193	199	175	152	130	98	87	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.81	4.51	5.75	6.54	7.42	7.86	7.50	7.38	6.51	5.45	4.19	3.64	(44)	
(45)		RadStd	0.25	0.34	0.37	0.35	0.26	0.34	0.27	0.33	0.21	0.17	0.22	0.26	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page