

BAFT, Iran, Islamic Republic ofWMO: **408530**Lat: **29.233N**Lon: **56.583E**Elev: **2280**StdP: **76.77**Time Zone: **3.50 (IRN)**Period: **95-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.4	-2.8	-20.2	0.8	7.2	-18.2	1.0	6.4	13.5	2.7	11.7	8.0	2.6	0	0.481

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	33.1	14.2	32.2	13.8	31.2	13.5	16.7	27.6	15.9	27.5	15.2	27.6	4.7	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
12.8	12.2	22.5	11.2	11.0	23.7	9.6	9.9	23.8	56.3	27.5	53.4	27.1	51.0	27.3	20.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.2	10.3	9.1	-8.0	35.1	2.4	1.1	-9.7	35.9	-11.1	36.5	-12.4	37.1	-14.1	37.9		
(5)			-10.0	17.4	1.9	1.3	-11.3	18.4	-12.4	19.1	-13.5	19.9	-14.8	20.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.7	4.4	5.9	10.1	14.8	20.2	25.3	26.4	24.9	22.2	16.7	10.1	6.6
	DBStd	8.18	3.16	3.31	3.00	2.94	2.71	1.84	1.65	1.72	1.85	2.39	2.92	2.95
	HDD10.0	479	174	120	36	3	0	0	0	0	0	0	36	111
	HDD18.3	1833	432	349	256	110	13	0	0	0	1	61	248	363
	CDD10.0	2550	1	5	38	147	315	459	507	462	364	208	38	6
	CDD18.3	862	0	0	0	4	70	209	249	204	116	11	0	0
	CDH23.3	8015	0	0	2	22	543	2147	2538	1812	876	75	0	0
CDH26.7	2882	0	0	0	0	102	878	1088	633	178	2	0	0	
Wind	WSAvg	3.7	3.3	3.8	3.7	3.9	4.1	3.9	4.4	4.7	3.6	3.0	2.8	2.9
Precipitation	PrecAvg	253	56	49	50	26	8	3	5	8	2	4	12	31
	PrecMax	410	106	197	169	95	57	24	17	56	10	27	64	151
	PrecMin	126	13	5	0	0	0	0	0	0	0	0	0	0
	PrecStd	63	29	41	39	23	12	6	4	13	2	7	15	38
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.9	18.3	22.8	25.2	30.6	33.9	34.6	33.6	30.8	26.7	21.4	18.9
		MCWB	4.1	6.9	8.2	10.3	12.3	13.9	15.1	14.1	12.8	11.2	8.0	6.5
	2%	DB	13.8	15.7	19.7	23.9	29.0	32.7	33.5	32.1	29.7	25.2	19.8	16.2
		MCWB	3.8	5.4	6.9	9.9	12.1	13.8	14.5	13.6	12.6	10.7	7.6	4.9
	5%	DB	12.1	13.8	18.1	22.6	27.8	31.9	32.5	31.0	28.7	24.0	18.2	14.5
		MCWB	3.2	4.6	6.4	9.3	11.8	13.6	14.2	13.2	12.1	10.2	7.1	4.0
	10%	DB	10.3	11.9	16.3	21.1	26.5	30.9	31.5	29.9	27.7	22.7	16.6	12.8
		MCWB	2.5	3.4	5.7	8.6	11.3	13.3	13.9	12.8	11.8	9.8	6.4	3.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.5	7.8	9.5	11.5	14.0	17.7	17.9	17.4	15.4	13.0	10.7	7.3
		MCDB	10.3	14.8	16.4	22.6	26.7	30.6	28.8	24.7	27.4	23.5	18.6	15.9
	2%	WB	5.4	6.8	8.4	10.7	13.1	16.2	16.8	16.2	14.3	12.1	8.9	6.0
		MCDB	9.3	12.2	14.9	21.2	26.5	27.3	28.2	26.5	26.5	22.5	15.6	12.9
	5%	WB	4.4	5.9	7.6	10.1	12.5	15.2	16.1	15.3	13.6	11.4	8.0	5.2
		MCDB	9.0	10.9	14.2	20.1	25.8	28.0	28.0	26.8	25.9	21.7	15.3	11.4
	10%	WB	3.6	5.0	6.9	9.4	11.8	14.3	15.4	14.6	12.9	10.6	7.1	4.3
		MCDB	8.8	9.5	13.5	18.8	24.9	28.5	27.9	26.8	25.4	20.9	15.0	10.4
Mean Daily Temperature Range	5% DB	MDBR	10.0	10.1	10.6	10.1	10.9	10.9	10.3	10.4	11.0	11.5	11.1	10.9
		MCDBR	12.2	12.5	12.7	11.3	11.7	11.6	11.3	11.1	11.6	11.9	12.8	12.9
		MCWBR	6.4	6.1	5.5	4.6	4.5	4.1	3.9	4.0	4.2	4.9	6.0	6.4
	5% WB	MCDBR	8.8	8.9	9.6	10.2	11.4	10.9	10.4	10.8	11.3	11.4	10.7	10.2
		MCWBR	5.4	4.8	4.7	4.4	4.6	4.2	4.0	4.1	4.6	5.2	5.6	5.7
Clear-Sky Solar Irradiance	taub	0.261	0.305	0.351	0.411	0.430	0.460	0.476	0.438	0.393	0.354	0.289	0.261	
	taud	2.538	2.403	2.228	2.059	2.021	1.952	1.937	2.037	2.139	2.244	2.481	2.557	
	Ebn at Noon	994	965	934	884	865	834	819	849	879	895	948	979	
	Edh at Noon	86	108	137	168	176	187	190	170	148	124	90	80	
All-Sky Solar Radiation	RadAvg	3.76	4.45	5.74	6.63	7.36	7.72	7.31	7.22	6.39	5.44	4.26	3.67	
	RadStd	0.32	0.39	0.42	0.38	0.39	0.43	0.33	0.39	0.29	0.24	0.24	0.31	