

BAM, Iran, Islamic Republic ofWMO: **408540**Lat: **29.0802N**Lon: **58.3523E**Elev: **3084**StdP: **13.13**Time Zone: **3.50 (IRN)**Period: **95-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	33.0	36.9	0.9	6.4	54.2	5.3	8.1	56.6	27.5	58.3	23.4	57.5	6.7	300	0.469

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.0	109.5	65.7	107.6	64.9	105.4	64.1	69.9	99.7	67.9	99.9	66.2	99.7	9.1	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
58.6	82.4	88.6	54.8	71.5	84.1	51.8	64.1	80.8	36.0	99.0	34.2	99.2	32.7	99.5	76.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
25.6	21.5	17.9	DB	30.8	112.7	3.5	1.2	28.2	113.6	26.2	114.3	24.2	115.0	21.7	115.9	
			WB	24.8	70.6	3.4	3.7	22.4	73.2	20.4	75.3	18.5	77.4	16.1	80.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	75.8	53.0	57.8	68.1	77.0	87.1	94.5	95.1	91.3	86.8	77.5	63.8	55.9
	DBStd	16.24	8.51	8.98	7.92	6.83	5.38	4.42	3.93	3.57	4.19	6.04	7.74	7.70
	HDD50	130	66	30	2	0	0	0	0	0	0	0	4	28
	HDD65	1089	382	229	61	7	0	0	0	0	0	1	112	297
	CDD50	9531	157	249	564	810	1150	1334	1399	1281	1103	853	419	212
	CDD65	5017	9	28	158	367	685	884	934	816	653	389	78	16
	CDH74	73303	48	187	1365	4011	9908	14865	15858	13071	9258	4064	560	108
	CDH80	46606	5	34	450	1832	6047	10581	11406	8704	5522	1873	129	23
(14) Wind	WSAvg	7.9	6.7	7.5	8.3	8.8	8.7	8.4	8.8	9.2	8.2	7.3	6.6	6.1
(15) Precipitation	PrecAvg	4.1	0.8	0.9	1.0	0.4	0.2	0.0	0.0	0.0	0.0	0.1	0.1	0.4
	PrecMax	8.3	2.1	2.5	3.9	2.1	1.2	0.3	0.3	0.2	0.1	0.7	0.7	1.6
	PrecMin	1.7	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	1.6	0.5	0.7	0.9	0.5	0.3	0.1	0.1	0.0	0.0	0.2	0.2	0.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.5	84.1	93.3	98.7	107.0	112.3	111.5	109.4	103.9	98.6	87.4	82.9
		MCWB	52.2	55.1	57.4	61.2	63.0	66.3	66.5	65.3	62.0	60.6	56.9	54.6
	2%	DB	73.8	79.5	88.2	95.4	103.7	109.8	109.6	105.3	101.7	95.3	83.7	76.2
		MCWB	51.6	53.6	56.5	60.4	63.1	65.4	66.3	65.0	61.6	59.9	55.5	51.8
	5%	DB	70.1	75.3	84.8	92.7	101.3	107.9	107.6	103.1	99.9	92.5	80.5	72.2
		MCWB	50.0	52.2	55.2	59.3	62.5	64.7	65.2	63.8	61.6	59.0	54.6	50.2
	10%	DB	66.7	71.8	81.3	89.8	98.9	105.6	105.5	101.1	97.8	89.5	76.9	68.6
		MCWB	48.6	51.1	54.3	58.3	61.8	63.9	64.5	62.8	60.8	57.8	53.6	48.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.4	57.1	61.8	65.6	69.9	71.9	72.9	72.0	67.1	63.0	60.1	55.4
		MCDB	73.5	76.1	83.1	92.8	96.6	100.8	103.0	96.3	95.2	90.4	77.3	77.4
	2%	WB	53.0	55.2	59.0	61.8	66.4	69.0	69.6	69.0	64.7	61.1	57.6	53.1
		MCDB	70.2	73.2	80.3	89.2	94.8	100.4	102.4	98.4	95.0	89.6	78.9	71.9
	5%	WB	51.3	54.0	57.4	60.5	64.1	66.7	67.5	66.5	62.9	60.1	56.1	51.5
		MCDB	68.4	71.5	78.2	88.4	95.4	101.0	101.4	99.2	95.4	88.6	77.2	69.4
	10%	WB	49.5	52.6	55.8	59.3	62.7	64.9	66.0	64.5	61.7	58.9	54.5	49.8
		MCDB	65.6	69.9	76.7	85.7	95.8	101.4	101.0	98.4	94.8	87.1	74.8	66.7
(35) Mean Daily Temperature Range	5% DB	MDBR	18.5	18.8	19.5	19.1	18.9	18.7	18.0	18.7	20.0	19.4	18.6	19.0
		MCDBR	20.8	21.5	22.3	21.7	20.9	21.0	20.4	20.0	21.3	21.0	21.1	21.9
		MCWBR	9.9	9.1	8.4	7.6	7.2	7.3	7.3	8.0	8.3	8.1	8.6	9.7
		MCDBR	19.5	18.4	19.1	19.6	20.1	19.6	19.5	19.3	20.4	20.0	19.3	20.0
	5% WB	MCWBR	10.1	8.3	7.8	7.5	8.3	7.9	7.5	8.5	8.9	8.4	8.4	9.2
(40) Clear-Sky Solar Irradiance	taub	0.371	0.443	0.514	0.593	0.628	0.635	0.614	0.574	0.548	0.513	0.409	0.364	
	taud	2.216	1.996	1.808	1.675	1.627	1.624	1.682	1.741	1.774	1.837	2.101	2.247	
	Ebn at Noon	270	258	247	232	225	222	226	234	234	232	253	266	
	Edh at Noon	38	52	67	79	83	82	78	73	68	60	43	35	
(44) All-Sky Solar Radiation	RadAvg	1230	1449	1813	2103	2337	2495	2423	2339	2065	1719	1355	1177	
(45)	RadStd	81	98	113	100	106	92	64	81	54	56	49	69	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A