

BAM, Iran, Islamic Republic ofWMO: **408540**Lat: **29.0802N**Lon: **58.3523E**Elev: **940**StdP: **90.53**Time Zone: **3.50 (IRN)**Period: **95-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.6	2.7	-17.3	0.9	12.3	-14.8	1.2	13.7	12.3	14.6	10.4	14.1	3.0	300	0.469

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	43.1	18.7	42.0	18.3	40.8	17.9	21.0	37.6	20.0	37.7	19.0	37.6	4.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.8	11.8	31.5	12.6	10.2	29.0	11.0	9.2	27.1	65.8	37.2	61.7	37.3	58.3	37.5	24.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.5	9.6	8.0	-0.7	44.8	1.9	0.7	-2.1	45.3	-3.2	45.7	-4.3	46.1	-5.7	46.6		
(5)			-4.0	21.4	1.9	2.0	-5.3	22.9	-6.4	24.1	-7.5	25.2	-8.8	26.7	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.3	11.6	14.4	20.1	25.0	30.6	34.7	35.1	33.0	30.4	25.3	17.7	13.3
	DBStd	9.02	4.73	4.99	4.40	3.79	2.99	2.45	2.19	1.98	2.33	3.35	4.30	4.28
	HDD10.0	72	37	17	1	0	0	0	0	0	0	0	2	16
	HDD18.3	605	212	127	34	4	0	0	0	0	0	1	62	165
	CDD10.0	5295	87	138	313	450	639	741	777	712	613	474	233	118
	CDD18.3	2787	5	16	88	204	381	491	519	453	363	216	43	9
	CDH23.3	40724	27	104	758	2228	5504	8258	8810	7262	5143	2258	311	60
	CDH26.7	25892	3	19	250	1018	3359	5878	6337	4836	3068	1041	72	13
Wind	WSAvg	3.5	3.0	3.4	3.7	3.9	3.9	3.8	3.9	4.1	3.6	3.3	3.0	2.7
Precipitation	PrecAvg	105	21	23	26	11	5	1	1	0	1	2	3	9
	PrecMax	212	53	64	99	54	30	8	8	5	2	17	17	40
	PrecMin	43	6	0	1	0	0	0	0	0	0	0	0	0
	PrecStd	40	12	17	23	13	7	2	2	1	1	4	5	12
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.4	28.9	34.1	37.0	41.7	44.6	44.2	43.0	39.9	37.0	30.8	28.3
		MCWB	11.2	12.8	14.1	16.2	17.2	19.1	19.1	18.5	16.7	15.9	13.8	12.5
	2%	DB	23.2	26.4	31.2	35.2	39.8	43.2	43.1	40.7	38.7	35.2	28.7	24.5
		MCWB	10.9	12.0	13.6	15.8	17.3	18.5	19.0	18.4	16.5	15.5	13.1	11.0
	5%	DB	21.2	24.1	29.3	33.7	38.5	42.2	42.0	39.5	37.7	33.6	26.9	22.3
		MCWB	10.0	11.2	12.9	15.2	16.9	18.2	18.5	17.7	16.4	15.0	12.6	10.1
	10%	DB	19.3	22.1	27.4	32.1	37.1	40.9	40.8	38.4	36.6	31.9	24.9	20.3
		MCWB	9.2	10.6	12.4	14.6	16.6	17.7	18.1	17.1	16.0	14.4	12.0	9.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.0	13.9	16.6	18.6	21.0	22.2	22.7	22.2	19.5	17.2	15.6	13.0
		MCDB	23.1	24.5	28.4	33.8	35.9	38.2	39.5	35.7	35.1	32.4	25.2	25.2
	2%	WB	11.7	12.9	15.0	16.6	19.1	20.5	20.9	20.5	18.1	16.2	14.2	11.7
		MCDB	21.2	22.9	26.8	31.8	34.9	38.0	39.1	36.9	35.0	32.0	26.1	22.1
	5%	WB	10.7	12.2	14.1	15.8	17.9	19.3	19.7	19.2	17.2	15.6	13.4	10.9
		MCDB	20.2	22.0	25.7	31.3	35.2	38.3	38.5	37.3	35.2	31.4	25.1	20.8
	10%	WB	9.7	11.4	13.2	15.2	17.0	18.3	18.9	18.0	16.5	14.9	12.5	9.9
		MCDB	18.7	21.0	24.9	29.9	35.5	38.6	38.3	36.9	34.9	30.6	23.8	19.3
Mean Daily Temperature Range	5% DB	MDBR	10.3	10.4	10.8	10.6	10.5	10.4	10.0	10.4	11.1	10.8	10.3	10.6
		MCDBR	11.6	11.9	12.4	12.0	11.6	11.7	11.3	11.1	11.8	11.6	11.7	12.2
		MCWBR	5.5	5.1	4.7	4.2	4.0	4.1	4.1	4.4	4.6	4.5	4.8	5.4
	5% WB	MCDBR	10.8	10.2	10.6	10.9	11.2	10.9	10.8	10.7	11.3	11.1	10.7	11.1
		MCWBR	5.6	4.6	4.3	4.2	4.6	4.4	4.2	4.7	4.9	4.7	4.7	5.1
Clear-Sky Solar Irradiance	taub	0.371	0.443	0.514	0.593	0.628	0.635	0.614	0.574	0.548	0.513	0.409	0.364	
	taud	2.216	1.996	1.808	1.675	1.627	1.624	1.682	1.741	1.774	1.837	2.101	2.247	
	Ebn at Noon	850	812	778	732	708	700	713	737	738	731	797	839	
	Edh at Noon	120	163	210	248	261	260	245	229	214	189	134	111	
All-Sky Solar Radiation	RadAvg	3.88	4.57	5.71	6.63	7.37	7.87	7.64	7.37	6.51	5.42	4.27	3.71	
	RadStd	0.25	0.31	0.36	0.32	0.33	0.29	0.20	0.26	0.17	0.17	0.16	0.22	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page