

ZAHEDAN INTL, Iran, Islamic Republic ofWMO: **408560**Lat: **29.4720N**Lon: **60.9006E**Elev: **1370**StdP: **85.91**Time Zone: **3.50 (IRN)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.0	-3.1	-24.0	0.5	7.2	-20.2	0.7	8.9	13.4	15.0	12.2	15.8	1.4	170	0.489

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.3	39.2	16.5	38.1	16.2	37.1	15.6	18.5	34.7	17.4	35.2	16.6	34.7	4.7	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
12.2	10.5	23.2	10.5	9.3	20.8	9.1	8.5	20.6	58.4	34.1	54.5	35.6	51.8	34.6	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.4	9.7	8.3	DB	-8.6	41.8	2.3	1.7	-10.3	43.1	-11.6	44.1	-12.9	45.1	-14.5	46.3	(4)
(5)			WB	-10.8	19.9	2.3	1.8	-12.5	21.2	-13.8	22.2	-15.1	23.2	-16.8	24.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.3	7.9	10.6	15.7	20.9	25.5	28.4	29.4	27.2	23.7	19.5	13.1	8.8	(6)	
	DBStd	8.29	4.42	4.88	4.31	3.73	2.92	2.39	2.04	2.11	2.58	3.04	4.17	4.05	(7)	
	HDD10.0	237	95	48	7	0	0	0	0	0	0	0	16	72	(8)	
	HDD18.3	1151	324	219	104	18	1	0	0	0	2	23	163	297	(9)	
	CDD10.0	3617	29	64	183	328	482	551	600	533	411	293	109	33	(10)	
	CDD18.3	1487	0	2	22	96	224	301	342	275	162	58	6	0	(11)	
	CDH23.3	22930	3	21	255	1220	3071	4690	5586	4418	2527	1019	113	7	(12)	
	CDH26.7	12957	0	2	53	478	1643	2867	3554	2649	1326	371	14	0	(13)	
(14) Wind	WSAvg	3.5	3.7	4.4	4.3	3.8	3.5	3.8	3.8	3.3	2.9	2.6	2.9	3.0	(14)	
(15) Precipitation	PrecAvg	85	22	13	13	9	3	2	1	0	0	3	4	14	(15)	
	PrecMax	215	109	64	58	41	17	23	20	4	2	34	28	102	(16)	
	PrecMin	15	3	0	0	0	0	0	0	0	0	0	0	0	(17)	
	PrecStd	49	23	17	13	11	5	4	4	1	0	8	6	23	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.0	26.1	30.8	34.8	38.5	40.7	40.8	39.2	36.9	34.0	28.2	24.2	(19)	
		MCWB	9.2	11.0	11.8	14.7	16.5	16.4	16.8	16.4	15.1	14.2	11.7	10.3	(20)	
	2%	DB	20.1	23.1	28.0	32.9	36.9	39.0	39.4	37.9	35.3	32.1	26.3	21.2	(21)	
		MCWB	8.8	10.3	11.3	13.8	15.5	16.2	16.8	15.8	14.4	13.8	11.0	9.0	(22)	
	5%	DB	18.2	21.0	26.1	31.2	35.2	37.9	38.2	36.8	34.2	30.2	24.4	19.2	(23)	
		MCWB	7.7	9.5	10.9	13.1	14.9	15.9	16.4	15.2	14.0	13.1	10.7	8.2	(24)	
	10%	DB	16.2	19.1	24.1	29.8	33.9	36.8	37.2	35.8	33.1	28.8	22.2	17.3	(25)	
		MCWB	7.2	8.7	10.5	12.8	14.6	15.3	16.0	14.9	13.6	12.4	9.9	7.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.4	12.6	14.2	15.5	17.8	19.1	21.2	19.9	16.7	16.3	13.6	11.6	(27)	
		MCDB	17.6	20.7	23.6	30.9	34.3	31.8	31.6	31.0	33.2	29.0	22.5	19.7	(28)	
	2%	WB	10.2	11.5	13.1	14.7	16.5	17.6	19.0	17.4	15.7	14.6	12.5	10.3	(29)	
		MCDB	17.1	19.6	22.5	29.2	33.3	35.4	34.3	35.1	32.9	28.9	22.6	18.5	(30)	
	5%	WB	9.3	10.6	12.3	14.1	15.7	16.7	17.8	16.3	14.8	13.8	11.7	9.5	(31)	
		MCDB	16.3	18.5	21.6	28.0	32.6	35.1	35.9	34.7	32.3	28.2	21.9	17.4	(32)	
	10%	WB	8.2	9.9	11.5	13.4	15.1	16.0	16.9	15.5	14.1	13.0	10.7	8.5	(33)	
		MCDB	15.1	17.5	21.0	26.8	31.7	34.9	35.3	34.0	31.6	27.2	20.6	15.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	13.7	13.4	13.4	14.2	14.5	15.1	15.3	16.7	17.9	17.3	15.9	15.3	(35)	
		MCDBR	15.3	13.9	15.3	16.2	16.6	16.9	16.7	17.4	18.9	18.4	17.4	17.0	(36)	
	5% WB	MCWBR	8.3	6.6	6.5	6.4	6.6	6.5	6.5	6.9	8.2	8.5	8.4	9.1	(37)	
		MCWBR	11.4	10.9	11.8	13.7	14.9	14.9	14.4	15.2	17.2	16.7	14.5	13.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.319	0.370	0.422	0.486	0.505	0.481	0.465	0.429	0.393	0.390	0.339	0.308	(40)	
		taud	2.388	2.202	2.019	1.882	1.850	1.908	1.961	2.049	2.131	2.131	2.316	2.416	(41)	
	Ebn at Noon		916	888	861	818	801	816	828	857	878	853	881	910	(42)	
		Edh at Noon	100	132	169	201	208	196	185	168	149	139	107	93	(43)	
(44) All-Sky Solar Radiation	RadAvg		3.82	4.53	5.67	6.67	7.36	7.98	7.72	7.46	6.67	5.42	4.26	3.67	(44)	
	RadStd		0.25	0.30	0.33	0.29	0.26	0.28	0.26	0.28	0.15	0.15	0.17	0.22	(45)	

Historical Trends

	DBAvg	Heating		Cooling
--	-------	---------	--	---------