

BANDAR BUSHEHR, Iran, Islamic Republic ofWMO: **408570**Lat: **28.9036N**Lon: **50.8208E**Elev: **26**StdP: **14.68**Time Zone: **3.50 (IRN)**Period: **97-17**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	48.6	50.8	33.8	28.4	52.9	37.6	33.1	55.3	32.5	62.7	26.9	62.3	7.0	30	0.435

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.6	100.8	85.7	99.3	85.6	98.0	85.2	89.5	97.2	88.7	96.3	87.9	95.6	9.1	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
87.8	202.1	95.5	86.9	196.2	95.1	86.0	190.5	94.6	55.5	97.3	54.4	96.4	53.3	95.5	93.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.0	23.1	20.2	43.9	105.7	3.0	3.2	41.7	107.9	40.0	109.8	38.3	111.6	36.1	113.8		
(5)			39.4	91.3	3.4	1.2	36.9	92.1	35.0	92.9	33.1	93.6	30.6	94.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	78.0	59.7	61.8	68.5	76.7	85.7	88.5	92.3	93.0	89.5	82.8	72.2	63.8	(6)	
(7)		DBStd	12.49	4.85	4.80	4.39	4.98	3.71	2.81	2.44	2.39	3.08	3.48	5.07	4.98	(7)	
(8)		HDD50	1	1	0	0	0	0	0	0	0	0	0	0	0	(8)	
(9)		HDD65	390	175	109	15	0	0	0	0	0	0	0	7	84	(9)	
(10)		CDD50	10210	302	331	573	801	1106	1156	1312	1335	1184	1016	667	427	(10)	
(11)		CDD65	5124	10	20	123	351	641	706	847	870	734	551	224	47	(11)	
(12)		CDH74	70193	9	32	345	2700	8567	10498	13666	14407	11570	6929	1395	75	(12)	
(13)		CDH80	41028	0	1	28	714	4304	6186	9202	9943	7269	3118	260	3	(13)	
(14)	Wind	WSAvg	7.9	7.8	8.9	8.2	8.0	8.3	8.4	8.3	7.8	7.6	6.9	7.6	7.4	(14)	
(15)	Precipitation	PrecAvg	10.4	3.3	1.1	0.8	0.2	0.0	0.0	0.0	0.0	0.0	0.3	1.8	2.5	(15)	
(16)		PrecMax	24.0	9.2	3.3	5.4	0.7	0.6	0.0	0.1	0.5	0.0	3.0	8.4	9.8	(16)	
(17)		PrecMin	5.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
(18)		PrecStd	4.2	2.6	1.0	1.1	0.2	0.1	0.0	0.0	0.1	0.0	0.6	2.2	2.3	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.1	77.6	83.2	94.9	99.5	99.6	103.6	102.6	100.8	96.5	87.5	79.2	(19)	
(20)			MCWB	64.7	63.9	67.0	70.9	74.3	81.0	85.4	87.0	85.6	81.7	75.5	68.2	(20)	
(21)		2%	DB	71.8	73.8	79.7	90.0	95.6	96.9	100.5	100.8	98.6	93.7	84.8	75.9	(21)	
(22)			MCWB	64.0	63.1	67.0	71.6	76.4	81.4	85.6	87.2	84.9	80.3	73.9	67.0	(22)	
(23)		5%	DB	69.5	70.9	77.5	86.4	93.5	95.2	98.8	99.6	97.2	91.7	82.9	74.0	(23)	
(24)			MCWB	62.8	62.5	66.6	71.5	76.6	81.6	85.8	87.0	84.3	79.4	72.5	66.2	(24)	
(25)		10%	DB	67.4	68.9	75.5	83.9	91.5	93.6	97.1	98.3	96.0	90.0	81.1	72.2	(25)	
(26)			MCWB	61.2	61.8	66.0	71.2	76.4	81.1	85.3	86.7	83.8	78.8	70.9	65.0	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.0	67.1	71.4	77.4	83.1	86.3	90.2	91.5	89.2	85.4	78.4	71.0	(27)	
(28)			MCD B	71.6	73.1	78.0	86.1	91.7	93.9	97.8	98.8	97.5	92.4	84.9	76.3	(28)	
(29)		2%	WB	65.4	65.5	69.5	75.9	81.2	85.1	89.1	89.9	88.0	83.4	76.4	69.3	(29)	
(30)			MCD B	70.1	70.5	76.8	84.4	90.7	93.0	96.5	97.5	96.2	91.0	83.0	74.4	(30)	
(31)		5%	WB	63.7	64.1	68.2	74.4	79.9	84.0	88.2	89.1	87.0	82.0	74.4	67.5	(31)	
(32)			MCD B	68.7	69.0	75.5	83.1	89.7	92.2	95.6	96.7	95.1	89.6	81.4	72.8	(32)	
(33)		10%	WB	61.9	62.8	67.1	72.8	78.8	82.8	87.2	88.3	85.9	80.7	72.1	65.6	(33)	
(34)			MCD B	66.6	67.9	74.0	81.6	88.8	91.3	94.7	96.0	93.9	88.5	79.6	71.1	(34)	
(35)	Mean Daily Temperature Range			MDBR	10.7	10.1	10.5	11.0	10.3	8.7	8.8	9.6	11.6	13.1	12.6	12.1	(35)
(36)		5% DB	MCD BR	12.2	11.9	13.0	14.4	13.7	11.9	12.0	11.6	12.3	14.3	14.1	13.6	(36)	
(37)			MCWBR	9.4	8.5	9.0	9.9	10.5	9.2	9.2	7.6	8.5	10.4	10.5	9.8	(37)	
(38)		5% WB	MCD BR	11.2	10.4	11.6	11.8	11.1	10.6	10.5	10.3	11.5	12.8	12.5	11.9	(38)	
(39)			MCWBR	9.5	8.4	9.0	10.6	10.4	9.7	8.3	7.1	8.3	9.9	10.4	9.7	(39)	
(40)	Clear-Sky Solar Irradiance	taub		0.461	0.507	0.564	0.640	0.627	0.594	0.664	0.625	0.539	0.512	0.480	0.450	(40)	
(41)		taud		2.016	1.903	1.762	1.655	1.678	1.747	1.654	1.742	1.887	1.931	2.005	2.056	(41)	
(42)		Ebn at Noon		238	238	233	221	225	231	215	222	237	233	230	234	(42)	
(43)		Edh at Noon		47	57	70	80	79	73	80	73	61	55	47	43	(43)	
(44)	All-Sky Solar Radiation	RadAvg		1131	1391	1784	2016	2401	2627	2468	2346	2100	1698	1224	1063	(44)	
(45)		RadStd		82	103	115	125	69	59	60	54	41	60	101	105	(45)	