

BANDAR BUSHEHR AP, Iran, Islamic Republic of

WMO: 408580

Lat: 28.9625N

Lon: 50.8194E

Elev: 68

StdP: 14.66

Time Zone: 3.50 (IRN)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 47.9	(c) 50.0	(d) 31.6	(e) 26.0	(f) 58.9	(g) 34.2	(h) 29.0	(i) 59.7	(j) 28.4	(k) 65.2	(l) 25.1	(m) 63.4	(n) 5.0	(o) 30	(p) 0.444

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 13.5	(c) 102.5	(d) 79.6	(e) 100.7	(f) 81.0	(g) 100.0	(h) 81.3	(i) 87.8	(j) 96.7	(k) 86.6	(l) 95.8	(m) 85.5	(n) 95.0	(o) 11.2	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
85.9	190.1	95.0	84.3	180.5	93.8	82.7	171.2	93.3	53.0	96.5	51.5	95.8	50.1	95.3	91.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 23.2	(b) 20.6	(c) 18.1	(e) 42.8	(f) 108.9	(g) 2.1	(h) 3.0	(i) 41.3	(j) 111.1	(k) 40.0	(l) 112.9	(m) 38.8	(n) 114.6	(o) 37.3	(p) 116.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	78.1	59.7	62.4	68.8	77.3	86.0	89.6	92.5	93.4	89.7	82.7	71.4	62.8
	DBStd	12.80	5.40	5.71	5.06	5.37	3.77	3.14	2.65	2.16	3.00	4.08	5.21	4.62
	HDD50	1	1	0	0	0	0	0	0	0	0	0	0	0
	HDD65	411	179	107	19	0	0	0	0	0	0	0	7	99
	CDD50	10259	303	348	582	818	1116	1188	1317	1344	1192	1014	641	396
	CDD65	5193	16	34	136	368	651	738	852	879	742	549	198	30
	CDH74	72947	34	123	646	3224	8926	11444	13895	14539	11669	6998	1373	76
CDH80	43760	1	19	150	1080	4738	7161	9432	10075	7409	3386	302	7	
Wind	WSAvg	7.6	8.1	8.6	8.4	7.9	8.2	8.6	7.8	6.8	6.6	5.9	7.0	7.3
Precipitation	PrecAvg	10.4	3.3	1.1	0.8	0.2	0.0	0.0	0.0	0.0	0.0	0.3	1.8	2.5
	PrecMax	24.0	9.2	3.3	5.4	0.7	0.6	0.0	0.1	0.5	0.0	3.0	8.4	9.8
	PrecMin	5.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	4.2	2.6	1.0	1.1	0.2	0.1	0.0	0.0	0.1	0.0	0.6	2.2	2.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.3	82.7	88.8	97.1	103.6	104.0	106.2	104.3	102.2	97.2	89.3	79.2
		MCWB	59.9	60.9	62.6	65.1	71.4	75.9	75.8	81.3	80.9	76.8	71.9	64.3
	2%	DB	73.8	77.4	84.2	92.8	98.6	100.4	102.3	102.3	100.2	95.1	86.1	75.5
		MCWB	61.0	60.3	62.8	66.2	70.8	76.9	79.5	81.9	81.9	77.0	71.2	63.5
	5%	DB	71.4	73.6	80.5	89.2	95.2	98.3	100.4	100.7	98.6	93.2	83.4	73.4
		MCWB	61.3	61.0	62.9	67.2	73.0	78.1	80.8	83.2	81.5	77.4	70.0	62.7
	10%	DB	68.3	71.2	77.1	85.9	93.1	96.5	98.6	100.0	97.1	91.3	80.9	71.3
		MCWB	59.7	60.7	63.1	68.0	73.6	78.3	81.4	83.5	81.0	76.2	68.5	61.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	65.5	67.2	69.1	74.9	82.4	86.1	88.2	89.8	87.8	82.8	77.1	68.7
		MCDB	71.5	72.7	78.2	84.6	91.9	95.6	97.0	98.2	97.2	91.7	85.9	75.5
	2%	WB	63.7	64.9	67.4	72.8	79.9	84.0	86.5	88.4	86.2	81.2	74.1	66.4
		MCDB	70.2	71.6	76.6	82.6	90.6	94.2	95.7	97.1	96.1	90.3	82.8	72.6
	5%	WB	62.3	63.3	66.0	71.6	78.4	82.4	85.2	87.3	84.8	80.0	72.2	64.3
		MCDB	68.4	70.0	75.4	81.7	89.6	92.7	94.8	96.2	94.9	89.3	80.9	71.4
	10%	WB	60.6	61.8	64.9	70.2	76.8	81.0	84.1	86.4	83.6	78.9	70.0	62.7
		MCDB	67.0	68.5	74.3	81.0	88.3	92.1	94.2	95.4	93.9	88.5	79.1	69.3
Mean Daily Temperature Range	5% DB	MDBR	13.0	13.1	14.3	15.1	14.4	13.1	12.9	13.5	15.3	16.4	14.5	13.4
		MCDBR	16.3	16.8	19.5	19.7	18.5	16.9	16.0	14.8	15.7	17.1	17.7	17.3
		MCWBR	10.2	9.0	9.6	9.6	10.9	10.9	10.1	9.0	9.7	10.6	11.5	10.7
	5% WB	MCDBR	14.3	13.8	15.7	15.4	14.7	14.9	13.9	13.3	15.3	16.3	16.3	14.5
		MCWBR	10.1	8.9	10.0	9.9	10.9	10.8	9.6	8.8	10.3	11.0	11.6	10.0
Clear-Sky Solar Irradiance	taub	0.459	0.505	0.562	0.638	0.624	0.592	0.662	0.623	0.536	0.510	0.478	0.447	
	taud	2.019	1.906	1.765	1.656	1.680	1.748	1.654	1.743	1.888	1.931	2.006	2.059	
	Ebn at Noon	239	239	234	222	226	232	215	222	238	234	230	235	
	Edh at Noon	47	57	70	80	78	73	80	73	61	55	47	43	
All-Sky Solar Radiation	RadAvg	1128	1390	1784	2016	2404	2630	2472	2348	2100	1697	1222	1061	
	RadStd	81	102	114	125	68	58	59	54	40	60	100	105	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	-2.25	N/A	+0.94	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page