

BANDAR UDARA FASA, Iran, Islamic Republic of

WMO: 408590

Lat: 28.8989N

Lon: 53.7195E

Elev: 4226

StdP: 12.59

Time Zone: 3.50 (IRN)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.8	31.7	4.8	8.2	53.5	10.0	10.7	53.6	20.1	53.8	17.3	56.5	1.5	330	0.437

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	29.8	105.7	64.6	104.1	64.0	102.4	63.8	69.9	95.2	68.0	95.7	66.5	95.8	8.6	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
61.2	94.7	85.7	57.6	82.8	84.0	55.1	75.6	78.2	36.8	96.2	35.1	95.2	33.7	95.6	78.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
19.0	16.2	13.6	DB	25.1	108.7	2.2	1.3	23.5	109.7	22.2	110.4	20.9	111.2	19.3	112.1	
			WB	21.5	72.2	2.5	3.3	19.7	74.6	18.3	76.5	16.9	78.3	15.1	80.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.5	46.4	50.0	57.1	65.1	76.3	84.8	88.3	85.8	79.2	69.3	56.8	49.7
	DBStd	15.26	4.35	4.74	4.68	5.08	4.70	3.35	2.85	2.88	3.54	4.08	5.17	4.39
	HDD50	250	128	53	4	0	0	0	0	0	0	0	6	59
	HDD65	2035	577	420	248	60	1	0	0	0	0	8	247	474
	CDD50	6635	16	53	223	454	816	1043	1186	1110	875	598	210	51
	CDD65	2947	0	0	3	64	352	593	721	645	425	142	2	0
	CDH74	46895	1	3	215	1219	5291	9662	11727	10038	6163	2394	177	5
	CDH80	29291	0	0	41	383	3000	6548	7996	6644	3720	950	9	0
(14) Wind	WSAvg	4.2	3.0	3.9	4.5	4.8	5.8	4.9	5.1	4.8	4.1	3.5	3.0	2.7
(15) Precipitation	PrecAvg	11.5	3.3	2.0	2.0	0.7	0.1	0.0	0.0	0.1	0.0	0.0	0.7	2.1
	PrecMax	22.8	10.1	6.6	5.9	3.7	1.2	0.2	0.3	0.3	0.3	0.6	3.4	9.8
	PrecMin	4.3	0.3	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	4.4	2.2	1.8	1.5	0.9	0.3	0.0	0.1	0.1	0.0	0.1	0.9	2.8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.3	73.5	84.5	90.0	100.8	106.2	108.0	106.1	100.8	93.2	81.0	73.6
		MCWB	48.4	51.5	55.8	58.6	60.8	64.0	64.8	64.3	61.7	58.3	54.0	50.9
	2%	DB	64.8	69.6	79.1	87.2	98.5	104.4	106.0	104.1	98.8	90.3	78.6	69.6
		MCWB	46.3	49.8	53.6	57.7	60.4	63.3	65.2	63.8	61.7	57.9	53.5	49.8
	5%	DB	62.2	66.4	75.4	84.4	95.9	103.3	104.4	102.3	97.0	88.1	75.6	66.1
		MCWB	45.3	48.6	52.0	56.6	59.6	63.1	64.8	63.6	61.2	57.4	53.0	47.9
	10%	DB	58.9	63.0	71.8	81.4	93.4	101.2	102.9	100.5	95.2	85.8	72.0	62.7
		MCWB	44.7	47.2	50.7	55.9	58.9	62.5	64.7	63.3	60.7	57.0	51.2	46.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.1	54.5	58.8	61.7	63.2	69.9	74.4	72.6	66.5	62.0	57.7	54.8
		MCDB	58.4	65.9	72.2	80.6	93.7	100.0	99.7	94.1	93.6	84.6	70.5	64.5
	2%	WB	50.7	52.7	56.8	60.1	61.9	67.4	70.1	70.1	64.5	60.0	55.9	52.2
		MCDB	57.3	62.2	68.4	78.9	92.4	97.4	96.4	92.5	93.4	85.3	71.4	61.6
	5%	WB	48.8	51.2	55.2	58.7	61.0	65.6	68.3	67.8	63.0	58.7	54.5	50.9
		MCDB	56.0	60.3	67.3	78.1	90.9	96.6	97.1	92.4	93.0	84.1	69.9	60.3
	10%	WB	47.1	49.7	53.7	57.5	60.1	63.8	66.9	66.0	61.7	57.5	53.1	49.4
		MCDB	55.4	58.8	65.8	75.9	89.5	97.4	97.0	94.2	92.1	82.9	67.7	58.9
(35) Mean Daily Temperature Range	5% DB	MDBR	24.3	25.0	27.9	29.4	31.8	33.3	29.8	30.5	32.8	32.2	28.2	26.5
		MCDBR	30.0	29.9	34.0	33.1	34.1	34.5	31.6	32.1	33.3	33.8	32.3	31.0
		MCWBR	15.6	14.6	15.0	12.5	12.4	12.6	11.3	11.6	12.9	14.4	15.6	15.3
	5% WB	MCDBR	21.3	22.1	24.6	29.1	32.4	32.7	29.1	29.6	31.9	32.0	27.3	24.5
		MCWBR	12.6	12.2	12.6	11.6	11.8	13.4	11.4	11.5	13.1	14.2	13.9	13.1
(40) Clear-Sky Solar Irradiance	taub		0.314	0.366	0.414	0.475	0.466	0.471	0.527	0.485	0.420	0.381	0.336	0.309
	taud		2.381	2.202	2.031	1.894	1.922	1.918	1.813	1.912	2.056	2.160	2.318	2.404
	Ebn at Noon		293	284	276	263	265	262	247	257	271	275	282	290
	Edh at Noon		32	42	53	63	62	62	68	61	51	43	34	30
(44) All-Sky Solar Radiation	RadAvg		1217	1453	1831	2092	2413	2551	2384	2283	2056	1742	1322	1148
(45)	RadStd		76	112	135	114	80	69	55	74	53	58	77	82

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	N/A	-2.25	N/A	+0.94	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page